



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F6/DFS/MS/2025/WZ/College/ 31

Dated: 11/09/2025

FIRE SAFETY CERTIFICATE

Certified that the Rukmani Devi Institute of Advance Studies, 2-A & 2-B, A-Block, Madhuban, Chowk, Rohini, Delhi-110085, comprised of Basement + Ground + 03 upper floors has already been issued FSC by this department vide letter No. F.6/DFS/MS/2022/WZ/College/17 dated 18.10.2022. The premises was re-inspected by the officer concerned of this department on 25.08.2025 in the presence of Dr. Raman Garg (Director) and found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the premises fit for occupancy class "Group B Educational" with effect from 11/09/2025 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subjected to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 11/09/2025 at New Delhi by


(Virendra Singh)
Chief Fire Officer
Delhi Fire Service

Copy to :-

1. The Director, Rukmani Devi Institute of Advance Studies, 2-A & 2-B, A-Block, Madhuban, Chowk, Rohini, Delhi-110085.

Conditions for the validity of fire safety certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on
8. All the means of escape shall be kept free of any obstruction all the time to evacuate the occupant, in a safe manner, in the event of emergency.

[http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Fire+Safety+Acts+and+Rule
s/](http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Fire+Safety+Acts+and+Rule+s/) http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Forms

INSPECTION REPORT

1. Name & address of the building : Rukmini Devi Institute of Advance Studies, 2A & 2B, A-Block, Madhuban Chowk, Block-A, Outer Ring Road, Phase-I, Delhi-85.
2. Type of Occupancy : Educational (B+G+3 upper floor) Only for A-Block
3. Type of Case : Renewal
4. Details of Previous NOC : F.6/DFS/MS/2022/WZ/College/17 dated 18.10.2022
5. Fire Safety directives letter No : F.6/DFS/MS/BP/99/2883 dated 11.03.1999
6. Date of inspection : 25.08.2025
7. Name of Inspecting Officer : A.K.Sharma ADO(Rohini)
8. Name and designation of officers
From the building side : Dr. Raman Garg (Director)
9. Year of Construction : 1999
10. Applicant's letter No. : OD No.3837 dated 17.07.2025.

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Rule 35(6)	Provided at site	Remarks MR/NMR
1.	Access to building			
	• Road width	09m	18m	MR
	• Gate width	4.5m	5.0m	MR
	• Width of internal road	-NA-	-NA-	-NA-
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	02nos.	03nos.	MR
	• Upper Floors	01 SC &	Provided	MR
	• Basements	01 ramp		
	b. Width of staircases	1.5m (each)	1.5m (each)	MR
	• Upper Floor	1.5m & 01 ramp	1.6m & ramp 1.5m	MR
	• Basements			
	c. Protection of exits	Required	Provided(only basement)	MR
	Fire check door	Required	Provided	MR
	• Pressurization	01nos.	Provided	
	d. No. of continuous staircases to terrace	-NA-	-NA-	-NA-
	e. Width of Corridor	1.0m	1.0m	MR
	f. Door Size			
3.	Compartmentation			
	• Fire check door	Required	Provided(only basement)	MR
	• Sealing of electrical shafts	Required	Provided	MR
	• Fire Rating of shaft door	Required	Provided	MR
	• Water Curtain	-NA-	-NA-	-NA-
	• Fire Dampers	-NA-	-NA-	-NA-
4.	Smoke Management System			
	• Basements	30 a/c per hour	Exhaust fan	MR
	• Upper floors	12 a/c per hour	Natural ventilated	MR
5.	Fire Extinguishers			
	• Total numbers	24nos.	25nos.	MR
	• Types	ABC/CO2	ABC-25	MR
	• ISI marking	ISI marked	Yes	MR
6.	First-Aid Hose Reels			
	• Total numbers on each floor	01nos.	Provided	MR
	• Length of hose reel hose	30mm	Provided	MR
	• Nozzle diameter	5m	Provided	MR
7.	Automatic fire detection and alarming system			
	• Type of detectors	-NA-	-NA-	-NA-
	• Location of Main Panel	-NA-	-NA-	-NA-
	• Location of Repeater Panel	-NA-	-NA-	-NA-
	• Alternate source of power	-NA-	-NA-	-NA-

	• Hooters' Location	-NA-	-NA-	-NA-
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	• Basement	Required	Provided	MR
	• Ground & Upper Floors	-NA-	-NA-	-NA-
	• Sprinkler above false ceiling	-NA-	-NA-	-NA-
11.	Internal Hydrants			
	• Size of riser/down-comer	Required	Provided	MR
	• Number of hydrants per floor	-NA-	01nos.	-NA-
	• Hose Box	-NA-	01nos.	-NA-
12.	Yard Hydrants			
	• Total number of hydrants	-NA-	-NA-	-NA-
	• Hose Box	-NA-	-NA-	-NA-
13.	Pumping Arrangements			
	• Ground Level			
	➤ Discharge of main Pump	-NA-	-NA-	-NA-
	➤ Head of Main pump	-NA-	-NA-	-NA-
	➤ Number of main pumps	-NA-	-NA-	-NA-
	➤ Jockey Pump out put	-NA-	-NA-	-NA-
	➤ Jockey pump head	-NA-	-NA-	-NA-
	➤ Standby Pump out put	-NA-	-NA-	-NA-
	➤ Standby Pump Head	-NA-	-NA-	-NA-
	➤ Auto Starting/Manual Stopping	-NA-	-NA-	-NA-
	➤ Pump House Access	-NA-	-NA-	-NA-
	• Terrace level			
	➤ Discharge of pump	900lpm	900lpm	MR
	➤ Head of the pump	40m	40m	MR
	➤ Power Supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR
14.	Captive Water Storage for fire fighting			
	• Underground tank capacity	25,000ltr	25,000ltr	MR
	➤ Draw-off connection	Required	Provided	MR
	➤ Fire service inlet	Required	Provided	MR
	➤ Access to tank	Required	Provided	MR
	• Overhead Tank capacity	12,500ltr	12,500ltr	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	• Pressurization of Lift Shaft	-NA-	-NA-	-NA-
	• Pressurization of Lift lobby	-NA-	-NA-	-NA-
	• Communication In lift Car	Required	Provided	MR
	• Fireman's Grounding Switch	Required	Provided	MR
	• Lift Signage	Required	Provided	MR
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area.			
	➤ Total Area	-NA-	-NA-	-NA-
	➤ Location	-NA-	-NA-	-NA-
19.	Fire Control Room			
	• Detector System Panel	-NA-	-NA-	-NA-
	• Flow Switch Panel	-NA-	-NA-	-NA-
	• PA System Panel	-NA-	-NA-	-NA-
	• Battery backup	-NA-	-NA-	-NA-
	• Building Floor Plans	-NA-	-NA-	-NA-

N/26

Special Fire Protection System for
Protection of special Risks, if any:

-NA-

-NA-

-NA-

Accordingly, the fire protection systems provided in the building were tested/ checked randomly and found in working condition at the time of inspection.

In view of the deemed compliance of the minimum standards of the fire prevention and fire safety measures as required under the rules the FSC issued vide letter no. F.6/DFS/MS/2022/WZ/College/17 dated 18.10.2022 is recommended for renewal of FSC under rule 37 of the Delhi Fire Service rules 2010.

(Signature)

Signature of the Inspecting Officer
Name Ajay Kumar Sharma
Designation ADO (Rohini)

DO (NW)

(Signature)
25/02/2025

(Signature)
25/02/2025

(Signature)
25/02/2025

CFO/
21/01/2025

Principal Director

CFO to Secy.
(Signature)
02/02/25

CFO/
61/01/2025

(Signature)
25/02/2025

put up FT.

(Signature)
25/02/2025

ADD (Rohini)

FT letter is put up for
kind perusal and sigs.

CFO/
25/02/2025

(Signature)

DCFO/...
Dated 29/02/2025

DCFO/...
Dated 01/03/2025