

C-55



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001



No. F6/DFS/MS/2025/WZ/School/ 1031

Dated: 20/08/2025

FIRE SAFETY CERTIFICATE

Certified that the **Rukmini Devi Public School, B-5, Sector-4, Rohini, Delhi-85**, comprised of **Basement + Ground + 02 upper floors** has already been issued FSC by this department vide letter No. **F.6/DFS/MS/2022/WZ/School/827** dated **01.08.2022**. The premises was re-inspected by the officer concerned of this department on **27.07.2025** in the presence of **Dr. Parveen Gupta (Vice-Chairman)** and found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the premises fit for occupancy '**Group-B Educational**' with effect from 20/08/2025 for a period of **three years** in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subjected to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 20/08/2025 at New Delhi by


(Virendra Singh)
Chief Fire Officer
Delhi Fire Service

Copy to :-

1. The Principal, Rukmini Devi Public School, B-5, Sector-4, Rohini, Delhi-85.
2. The Director, Education, Government of N.C.T of Delhi. Old Sect. Delhi - 54.

Conditions for the validity of fire safety certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on
8. All the means of escape shall be kept free of any obstruction all the time to evacuate the occupant, in a safe manner, in the event of emergency.

http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Fire+Safety+Acts+and+Rule/s/ http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Forms

INSPECTION REPORT

1. Name & address of the building : Rukmini Devi Public School, B-5, Sector-4, Rohini, Delhi-85.
2. Type of Occupancy : Educational
3. Type of Case : Renewal (Basement + Ground + 02 upper floors)
4. Details of Previous NOC : F.6/DFS/MS/2022/WZ/School/827 dated 01.08.2022
5. Fire Safety directives letter No : NBC Part-IV
6. Date of inspection : 27.07.2025
7. Name of Inspecting Officer : A.K.Sharma ADO(Rohini)
8. Name and designation of officers
From the building side : Dr. Parveen Gupta (Vice-Chairman)
9. Year of Construction : 2002 & 2014
10. Applicant's letter No. : OD No.3251 dated 30.06.2025.


S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1.	Access to building	Accessible	Accessible	MR
	<ul style="list-style-type: none"> Road width Gate width Width of internal road 	4.5m -NA-	4.0m -NA-	MR(Old Case) -NA-
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	02nos.	02nos.	MR
	<ul style="list-style-type: none"> Upper Floors Basements 	02nos.	02nos.	MR
	b. Width of staircases	1.5m	1.5m & 1.15m	MR
	<ul style="list-style-type: none"> Upper Floor Basements 	1.5m	1.5m & 1.15m	MR
	c. Protection of exits			
	Fire check door	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Pressurization 	-NA-	-NA-	-NA-
	d. No. of continuous staircases to terrace	01nos.	01nos.	MR
	e. Width of Corridor	-NA-	-NA-	-NA-
	f. Door Size	1.0m	1.0m	MR
3.	Compartmentation			
	<ul style="list-style-type: none"> Fire check door Sealing of electrical shafts Fire Rating of shaft door Water Curtain Fire Dampers 	-NA- -NA- -NA- -NA- -NA-	-NA- -NA- -NA- -NA- -NA-	-NA- -NA- -NA- -NA- -NA-
4.	Smoke Management System			
	<ul style="list-style-type: none"> Basements 	30 a/c per hour	Exhaust fan	MR
	<ul style="list-style-type: none"> Upper floors 	12 a/c per hour	Natural ventilated	MR
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers Types IS marking 	08nos. ABC/CO2 ISI marked	09nos. ABC-09 Yes	MR MR MR
6.	First-Aid Hose Reels			
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	01nos. 30mm 5m	Provided Provided Provided	MR MR MR
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power 	-NA- -NA- -NA- -NA-	-NA- -NA- -NA- -NA-	-NA- -NA- -NA- -NA-

	• Hooters' Location	-NA-	-NA-	-NA-
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	• Basement	Required	Provided	MR
	• Ground & Upper Floors	-NA-	-NA-	-NA-
	• Sprinkler above false ceiling	-NA-	-NA-	-NA-
11.	Internal Hydrants			
	• Size of riser/down-comer	Required	Provided	MR
	• Number of hydrants per floor	01nos.	Provided	MR
	• Hose Box	01nos	orivuded	MR
12.	Yard Hydrants			
	• Total number of hydrants	-NA-	Provided	-NA-
	• Hose Box	-NA-	-NA-	-NA-
13.	Pumping Arrangements			
	• Ground Level			
	➤ Discharge of main Pump	-NA-	-NA-	-NA-
	➤ Head of Main pump	-NA-	-NA-	-NA-
	➤ Number of main pumps	-NA-	-NA-	-NA-
	➤ Jockey Pump out put	-NA-	-NA-	-NA-
	➤ Jockey pump head	-NA-	-NA-	-NA-
	➤ Standby Pump out put	-NA-	-NA-	-NA-
	➤ Standby Pump Head	-NA-	-NA-	-NA-
	➤ Auto Starting/Manual Stopping	-NA-	-NA-	-NA-
	➤ Pump House Access	-NA-	-NA-	-NA-
	• Terrace level			
	➤ Discharge of pump	450lpm & 180lpm	450lpm & 180lpm	MR
	➤ Head of the pump	40m	40m	MR
	➤ Power Supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR
14.	Captive Water Storage for fire fighting			
	• Underground tank capacity	-NA-	-NA-	-NA-
	➤ Draw-off connection	-NA-	-NA-	-NA-
	➤ Fire service inlet	-NA-	-NA-	-NA-
	➤ Access to tank	-NA-	-NA-	-NA-
	• Overhead Tank capacity	10,000ltr	10,000ltr	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	• Pressurization of Lift Shaft	-NA-	-NA-	-NA-
	• Pressurization of Lift lobby	-NA-	-NA-	-NA-
	• Communication In lift Car	-NA-	-NA-	-NA-
	• Fireman's Grounding Switch	-NA-	-NA-	-NA-
	• Lift Signage	-NA-	-NA-	-NA-
17.	Standby power supply	-NA-	-NA-	-NA-
18.	Refuge Area.			
	➤ Total Area	-NA-	-NA-	-NA-
	➤ Location	-NA-	-NA-	-NA-
19.	Fire Control Room			
	• Detector System Panel	-NA-	-NA-	-NA-
	• Flow Switch Panel	-NA-	-NA-	-NA-
	• PA System Panel	-NA-	-NA-	-NA-
	• Battery backup	-NA-	-NA-	-NA-
	• Building Floor Plans	-NA-	-NA-	-NA-

20.	Special Fire Protection System for Protection of special Risks, if any:	-NA-	-NA-	-NA-
-----	---	------	------	------


Accordingly, the fire protection systems provided in the building were tested/ checked randomly and found in working condition at the time of inspection.


In view of the deemed compliance of the minimum standards of the fire prevention and fire safety measures as required under the rules the FSC issued vide letter no. F.6/DFS/MS/2022/WZ/School/827 dated 01.08.2022 is recommended for renewal under rule 37 of the Delhi Fire Service rules 2010.



 Signature of the Inspecting Officer
 Name Ajay Kumar Sharma
 Designation ADO(Rohini)

DO (NW)

Drawn: 238-NW
 Dated: 01/08/25


 31/07/2025
 By CPO (WZ)



 01/08/2025

CFO/

 9/8/2025


Principal Director


CFO to Secy.


 12/08/25

ADO (Rohini)

 1/8/25

FT letter is put up for kind perusal and
 Signature please.


 18/8/25

CFO/

 19/8/2025

MS