



C 42

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI – 110001





No F 6/DFS/MS/2025/School/WZ/ 984

Dated: 11 / 08 / 2025

FIRE SAFETY CERTIFICATE

Certified that the **Ryan International School, Block-G, Nursery Building, Sector-11, Rohini, New Delhi-85**, comprised of **Ground + One upper floor** owned/occupied by **Ryan International School** was granted FSC by this department vide letter No. **F.6/DFS/MS/2022/School/WZ/688 dated 23.06.2022**. The premises was re-inspected by the officer concerned of this department on **28.07.2025** in the presence of **Mrs. Shephali Sharma (Principal)** and observed that all the fire prevention and fire safety arrangements as provided in the premises found in good working condition. The premises have deemed complied with requirements of circular issued by **Director of Education letter no 3298-3398 dated 01.03.2011** and the building/ premise is fit for occupancy Group B Educational with effect from 11/08/2025 for a period of **three years**, subject to compliance of the conditions mentioned below:

Issued on 11/08/2025 at New Delhi


(Virendra Singh)
Chief Fire Officer


Copy to: -

1. The Director, Education, Government of N.C.T of Delhi. Old Sect. Delhi - 54.
2. The Principal, Ryan International School, Block-G, Nursery Building, Sector-11, Rohini, New Delhi-85.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/ http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Forms

INSPECTION REPORT


1. Name & address of the building : Ryan International School, Block-G, Nursery Building, Sector-11, Rohini, New Delhi-110085.
2. Type of Occupancy : Educational
3. Type of Case : Renewal (**Ground + 01 upper floors**)
4. Details of Previous NOC : F.6/DFS/MS/2022/School/WZ/688 dated 23.06.2022
5. Fire Safety directives letter No : Director of Education Cir. dated 01.03.2011
6. Date of inspection : 28.07.2025
7. Name of Inspecting Officer : A.K.Sharma ADO(Rohini)
8. Name and designation of officers
From the building side : Mrs. Shephali Sharma (Principal)
9. Year of Construction : 2005
10. Applicant's letter No. : OD No.2965 dated 23.06.2025

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Director of Education Cir. dated 01.03.2011	Provided at site	Remarks MR/NMR
1.	Access to building			
	<ul style="list-style-type: none"> Road width 	Accessible	Accessible	MR
	<ul style="list-style-type: none"> Gate width 	Accessible	4.5m	MR
	<ul style="list-style-type: none"> Width of internal road 	-NA-	-NA-	-NA-
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	<ul style="list-style-type: none"> Upper Floors 	01nos.	01nos.	MR
	<ul style="list-style-type: none"> Basements 	-NA-	-NA-	-NA-
	b. Width of staircases			
	<ul style="list-style-type: none"> Upper Floor 	1.5m	1.5m	MR
	<ul style="list-style-type: none"> Basements 	-NA-	-NA-	-NA-
	c. Protection of exits			
	Fire check door	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Pressurization 	-NA-	-NA-	-NA-
	d. No. of continuous staircases to terrace	-NA-	01nos.	-NA-
	e. Width of Corridor	-NA-	-NA-	-NA-
	f. Door Size	1.0m	1.0m	MR
3.	Compartmentation			
	<ul style="list-style-type: none"> Fire check door 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Sealing of electrical shafts 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Fire Rating of shaft door 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Water Curtain 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Fire Dampers 	-NA-	-NA-	-NA-
4.	Smoke Management System			
	<ul style="list-style-type: none"> Basements 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Upper floors 	12 a/c per hour	Natural ventilated	MR
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers 	04nos.	09nos.	MR
	<ul style="list-style-type: none"> Types 	ABC/CO2	ABC-09	MR
	<ul style="list-style-type: none"> ISI marking 	ISI marked	Yes	MR
6.	First-Aid Hose Reels			
	<ul style="list-style-type: none"> Total numbers on each floor 	-NA-	01 Provided	-NA-
	<ul style="list-style-type: none"> Length of hose reel hose 	-NA-	30m Provided	-NA-
	<ul style="list-style-type: none"> Nozzle diameter 	-NA-	5mm Provided	-NA-
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> Type of detectors 	-NA-	-NA-	-NA-

	• PA System Panel	-NA-	-NA-	-NA-
	• Battery backup	-NA-	-NA-	-NA-
	• Building Floor Plans	-NA-	-NA-	-NA-
20.	Special Fire Protection System for Protection of special Risks, if any:	-NA-	-NA-	-NA-

Accordingly, the fire protection systems provided in the building were tested/ checked randomly and found in working condition at the time of inspection.


Keeping in view of the deemed compliance of the minimum standards of the fire prevention and fire safety measures required stipulated in **Director of Education Circular**, the FSC issued vide letter no. F.6/DFS/MS/2022/School/WZ/688 dated 23.06.2022, is recommended for renewal under rule 37 of the Delhi Fire Service rules 2010.


Signature of the Inspecting Officer
Name Ajay Kumar Sharma
Designation ADO(Rohini)


DO (NW)


30/07/2025


CFO (WZ)


30/7

CFO/192-NW...
dated 30/07/25


4/8/2025

Principal Director

CFO to Sme.


CFO 05/08/25

(ADO Rohini)

Fi letter is put up for kind
perusal and signature please.


7/08/25


8/8/2025

MS