

444

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001

No F 6 / DFS / MS / 2025 / CNG / WZ / 345

Dated 24/06/2025

FIRE SAFETY CERTIFICATE

Certified that the CNG Station, Service Centre No. S-18 located at Pitampura Sub-Zone, H-4, Delhi comprised of Ground plus first floor owned/occupied by CNG Station, Service Centre No. S-18 was issued FSC by this department vide letter No.F6/DFS/MS/WZ/2022/247 dated 03.06.2022. The premise was re-inspected by the officer concerned of this department on 13.06.2025 in the presence of Sh. Shubham and observed that the building have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and the building/ premise is fit for occupancy "CNG Filling Station Group J" with effect from 24/06/2025 for a period of three years in accordance with OISD/ 179/ Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 24/06/2025 at New Delhi by


 (Atul Garg)
 Director

Ph. 011-23414000

Copy to:-

1. Sh. Ajay Khatri, G.M. (Fire & Safety), Indraprastha Gas Limited, IGL Bhawan, Plot no-4, Community Centre, R.K. Puram, Sec-09, New Delhi-110022.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
8. All the means of escape shall be kept free of any obstruction all the time to evacuate the occupant, in a safe manner, in the event of emergency.
9. Only fire protection facilities were checked as per OISD 179 (Para 19). The other safety requirement must be ascertained by licensing authority.

INSPECTION REPORT

1. Name & address of the building : CNG Station, Service Centre No. 18 located at Pitampura, Sub Zone, H-4, Delhi.
2. Type of Occupancy : CNG Filling Station, Group J
3. Building Comprised of : Ground and first floor
4. Type of Case : Renewal
5. Details of Previous NOC : F6/DFS/MS/WZ/2022/CNG/247 dated 03/06/2022
6. Fire Safety directives letter No : F5(3A)DFS/CNG/09/170 dated 16/05/2009
7. Date of inspection : 13/06/2025
8. Name of Inspecting Officer : R.K.Sinha, ADO (BW)
9. Name and designation of officers
From the building side : Mr. Shubham
10. Year of Construction : 2009
11. Applicant's letter No. : IGL/F&S/2024/15/90/1 dated 20/05/2025

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	OISD/ 179 Requirements/ Inspection report dated 28/04/2022	Provided at site	Remarks MR/NMR
1.	Access to building			
	• Road width	6 m	30 m	MR
	• Gate width	NA	NA	NA
	• Width of internal road	NA	NA	NA
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	01	Provided	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper Floor	1.25 m	Provided	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	NA	NA	NA
	e. Width of Corridor	NA	NA	NA
	f. Door Size	1 m	Provided	MR
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke Management System			
	• Basements	NA	NA	NA
	• Upper floors	Required	Naturally Ventilated	MR
5.	Fire Extinguishers			
	• Total numbers	12	Provided	MR
	• Types	10 Kg DCP & 75 kg Co2	Provided	MR
	• IS marking	Required	Provided	MR
6.	First-Aid Hose Reels			
	• Total numbers on each floor	NA	NA	NA
	• Length of hose reel hose	NA	NA	NA
	• Nozzle diameter	NA	NA	NA
7.	Automatic fire detection and alarming system			
	• Type of detectors	Hand held detector	Provided	MR
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA

				NA MR NA
8.	• Hooters' Location MOEFA	NA	NA Provided	
9.	Public Address System	Required NA	NA	
10.	Automatic Sprinkler System			MR NA NA
	• Ground floor	Water mist trolley	Provided NA	
	• Upper floors	NA	NA	
	• Sprinkler above false ceiling	NA		
11.	Internal Hydrants			NA NA NA
	• Size of riser/down-comer	NA	NA	
	• Number of hydrants per floor	NA	NA	
	• Hose Box	NA		
12.	Yard Hydrants			NA NA
	• Total number of hydrants	NA	NA	
	• Hose Box	NA		
13.	Pumping Arrangements			NA NA
	• Ground Level		NA	
	➤ Discharge of main Pump	NA	NA	
	➤ Head of Main pump	NA		NA
	➤ Number of main pumps	NA	NA	
	➤ Jockey Pump out put	NA	NA	
	➤ Jockey pump head	NA	NA	
	➤ Standby Pump out put	NA	NA	
	➤ Standby Pump Head	NA	NA	
	➤ Auto Starting/Manual Stopping	NA	NA	
	➤ Pump House Access	NA		NA
	• Terrace level			NA
	➤ Discharge of pump	NA	NA	
	➤ Head of the pump	NA		NA
	➤ Power Supply	NA	NA	
	➤ Auto Starting of pump	NA	NA	
14.	Captive Water Storage for fire fighting			NA
	• Underground tank capacity	NA	NA	
	➤ Draw-off connection	NA	NA	
	➤ Fire service inlet	NA	NA	
	➤ Access to tank	NA	NA	
	• Overhead Tank capacity	NA	NA	
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	• Pressurization of Lift Shaft	NA	NA	NA
	• Pressurization of Lift lobby	NA	NA	NA
	• Communication In lift Car	NA	NA	NA
	• Fireman's Grounding Switch	NA	NA	NA
	• Lift Signage	NA	NA	NA
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area.			
	➤ Total Area	NA	NA	NA
	➤ Location	NA	NA	NA

NA	MR	NA	Control Room			
			• Detector System Panel	NA	NA	NA
			• Flow Switch Panel	NA	NA	NA
			• PA System Panel	NA	NA	NA
			• Battery backup	NA	NA	NA
			• Building Floor Plans	NA	NA	NA
20.			Special Fire Protection System for Protection of special Risks, if any:	Fire buckets filled with sand, No Smoking boards in Hindi and English, No loose electric wiring seen & Co2 flooding system	Provided	MR

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

Only fire protection facilities were checked as per OISD 179 (Para 19). The other safety requirement must be ascertained by licensing authority.

Keeping in view of deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules it is recommended to renew the Fire Safety Certificate issued vide letter number F6/DFS/MS/WZ/2022/CNG/247 dated 03/06/2022 under rule 37 of the Delhi Fire Service Rules, 2010.

Signature of Inspecting Officer
Name : Rajeev Kumar Sinha
Designation : ADO/B.W.

Dr. C. P. (F.P.W.)

25/06/22
19/6/22

CFO

20/6/2025

Director

Dr. J. T. L. is present at the place

Director (F.P.W.)
23/6/22

23/6/22