

cl19

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No. F.6/DFS/MS/2025/BP/ 387

Dated: 18/08/2025

To,

Dr. Sandeep Kumar Agarwal
Medical Superintendent Nursing Homes
Directorate General of Health Services, GNCTD,
3rd floor, DGD Building, S-1, School Block
Shakarpur, New Delhi - 110092.

Subject: Regarding clearance from fire safety point of view in r/o S-2 Hospital situated at Plot No. L-356, Mahipal Pur, New Delhi.

Sir,

Please refer your letter No. F.24/New/NDD/DGHS/NHC/2025/275 dated 16.05.2025 on the above cited subject. In this connection, this is to inform you that the matter is examined and following shortcomings are observed:

1. Fire Check door are not proposed in Staircase, Lift lobby, panel room, etc. as per clause 8.4.6 of UBBL 2016.
2. Door size of patient ward is not proposed as per clause 7.12.2 of UBBL 2016.
3. Opening of store room is not permitted in staircase landing as per clause 7.11(K) of UBBL 2016.
4. Width of corridor is proposed as per clause 7.11.2 of UBBL 2016 and also not marked at some place.
5. Fire pump room not shown on the plans.

Accordingly the case is rejected.

Yours faithfully


(Virendra Singh)
Chief Fire Officer
011 23414333

e