

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001**

No.F6/DFS/MS/School/2025/305

Dated: 08/07/2025

To

The Principal,  
S.D. Public School, Patel Nagar,  
New Delhi-110008.

**Sub: Regarding issuing of FSC in r/o S.D. Public School, Patel Nagar, New Delhi-110008.**

Sir,

This has reference to your letter no. letter no. SDPS/264/25 dated 19.06.2025, on the subject cited above. In this regard, it is to inform you that the site was inspected by officer concerned of this department on 02.07.2025 in the presence of Ms. Rita Sachdeva and the following shortcomings were observed.

1. Hose reel found nonfunctional.
2. Pump found nonfunctional.

In view of above, fire safety certificate (FSC) cannot be considered at this stage. Therefore, it is requested to rectify the above shortcomings at the earliest for further consideration in the matter.

Yours faithfully,

(Atul Garg)  
**DIRECTOR**  
Delhi Fire Service

Copy to:-

1. The Director (Education), Govt. of NCT, Old Sectt. Delhi - 54.