

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

C-17 SPA
7/5
+ F.T
आज़ादी का
अमृत महोत्सव

No. F6/DFS/MS/School/NDZ/2025/ 588

Dated: 11/07/2025

To,

The Principal,
Sadbhawna Shiksha Sadan,
C - 39/40, Patel Chowk, Gali No. 01,
Shanti Nagar, Delhi - 110094.

**Subject: - Regarding grant of Fire Safety Certificate in r/o Sadbhawna Shiksha Sadan located at
C - 39/40, Patel Chowk, Gali No. 01, Shanti Nagar, Delhi – 110094.**

Sir,

This has a reference to Outdoor diary No. 2961 dated 23/06/2025, on the subject cited above. In this connection, it is to inform you that premises was inspected by the officers concerned of this department on 05/07/2025 in the presence of Mrs. Gita Rathore (Principal) and observed that building comprised of Ground plus one upper floor only.

Following shortcomings were observed during time of inspection:

1. Only one staircase of width 1.0 meter found provided, 2nd staircase found removed.
2. Fire extinguisher found empty.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(ATUL GARG)

DIRECTOR

DELHI FIRE SERVICE

Copy to: -

1. The Dy. Director of Education, D - Block, Anand Vihar, Delhi – 110092.