



No. F6/DFS/MS/School/NDZ/2025/263

Dated: 22/04/2025

To,

The Principal,  
Sagar Public School,  
H. No. 101, C – Block,  
Harijan Basti, Gharoli Vistar,  
Delhi – 110096.

**Subject: - Regarding grant of Fire Safety Certificate in r/o Sagar Public School located at H. No. 101, C – Block, Harijan Basti, Gharoli Vistar, Delhi – 110096.**

Sir,

This has a reference to your Outdoor Diary No. 120 dated 02/04/2025, on the subject cited above. In this connection, it is to inform you that premises was inspected by the officer concerned of this department on 12/04/2025 in the presence of Mrs. Hemlata (Principal) and observed that building comprised of ground plus one upper floor.

**Following shortcomings were observed during time of inspection:**

1. Single staircase of width 0.85 meter is provided second fire exit of width 0.95 mtr. found removed.
2. All fire extinguishers found empty.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(ATUL GARG)  
DIRECTOR

DELHI FIRE SERVICE

**Copy to:-**

1. The Director of Education, East Delhi Municipal Corporation, 419, Udyog Sadan, Patparganj Industrial Area, Delhi - 110092.