



2/11

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001

No.F.6/DFS/MS/EH/WZ/2025/ 419

Dated: 29/10/2025

To,
The Manger,
M/s Sagar Ratna Restaurants Pvt. Ltd
Shop No.- SH/2F/16, Second Floor, Pacific Mall,
Tagore Garden, Subhash Nagar,
New Delhi-110018

**Subject:-Regarding issuance of Fire Safety Certificate in r/o M/s Sagar Ratna Restaurants Pvt. Ltd
at Shop No.- SH/2F/16, Second Floor, Pacific Mall, Tagore Garden, Subhash Nagar, New
Delhi-110018.**

Sir,

This has reference to MCD application ID No. 2025091913584 & 2025092613766 dated 30/09/2025 on the subject cited above. In this connection, the premises was inspected by the officer concerned of this department on dated 23/10/2025 of the above-mentioned Restaurant from fire safety point of view in presence of Mrs. Jyoti Arora (Manager). The following shortcoming was observed during the time of inspection.

1. Fire Check Doors are not provided in the kitchen.
2. Fire extinguishers not provided in the restaurant.
3. Exit signages are not provided.

In view of above shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire Safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

29/10/25
(S. K. DUA)

o/c 2.
DY. CHIEF FIRE OFFICER
DELHI FIRE SERVICE

MCD ID NO. 2025091913584 & 2025092613766