

C-149

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

NO. F-6/DFS/MS/GH/2025/ 138

Dated 26/03/2025

To

The Joint Commissioner of Police/ Lic,
1st Floor, Licensing Unit, Police Station
Defence Colony, New Delhi.

Sub: - Regarding renewal of fire safety certificate in r/o M/s Sahni Guest House located at F-14,
D.B. Gupta Market, Main Road, Karol Bagh, Delhi-110005.

Sir,

This has reference to online MCD Portal I.D no. 2025022602466 dated 11.03.2025 on the subject cited above. In this connection this is to inform you that the above mentioned site was visited by the officer concerned of this department on 20.03.2025 in the presence of Sh. Mohan Lal Sahni (owner) to check the existing fire safety measures. During inspection it has been observed that building is comprised of ground & 04 upper floor but guest house running at 1st floor to 3rd floor with 33 guest rooms only. The request for FSC is rejected is rejected under Rule 37 (3) due to following shortcomings.

- 1 Fire check doors are not provided.
- 2 Carbon Monoxide detectors are provided but not functional.
- 3 Terrace level fire pump is not an auto mode.
- 4 Standby power supply is not functional.

Keeping in view of above renewal of Fire Safety Certificate cannot be considered at this stage & rejected. Applicant is requested to rectify the above mentioned shortcomings under intimation to this department: till such time running of guest house is at your own risk & responsibility.

Yours faithfully



(Atul Garg)
Director

Ph: 011-23414000



Copy to:-

1. The Commissioner Municipal Corporation of Delhi: to ensure the occupancy as detailed above deviation and if any.
2. Online ID No. 2025022602466 dated 11.03.2025