

C/21

FORM 'H': FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[See sub-rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No.F.6/DFS/MS/School/2025/870

Dated: 04/07/2025

FIRE SAFETY CERTIFICATE

Certified that the Sai International Public School located at G-5/248, Main Road, 5th Pusta, Sonia Vihar, Delhi-110094, building comprised of Ground plus two Upper Floors only owned / occupied by Sai International Public School have complied with the fire prevention and fire safety requirements in accordance with DOE. Cir. No. 3298-3398 dated 01/03/2011 and verified by the officer concerned of Fire Service on 16.06.2025 in presence of Sh. Sanjay Kumar Sharma (Manager) and that the building / premises is fit for occupancy class "Educational" (Group B) with effect from 04/07/2025 for a period of 3 (Three) years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 04/07/2025 at New Delhi by.

(ATUL GARG)
DIRECTOR

DELHI FIRE SERVICE.

Copy to :-

1. The Manager, Sai International Public School, G-5/248, Main Road, 5th Pusta, Sonia Vihar, Delhi-94.
2. The Dy. Director of Education, MCD, 419, Udyog Sadan Patparganj Industrial Area, Delhi-92.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided their in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non-functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc. shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. "The owner / Occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in

INSPECTION REPORT

1.	Name & address of the building	Sai International Public School, G-5/248, Main Road, 5 th Pusta, Sonia Vihar, Delhi-94.		
2.	Type of Occupancy	Educational		
3.	Building Comprised of	Ground plus two upper floors only		
4.	Type of Case	New		
5.	Details of previous NOC	Nil		
6.	Fire Safety directives Letter No	DOE Cir. 3298-3398 dated 01/03/2011		
7.	Date of Inspection	16.06.2025		
8.	Name of the Inspecting Officer	D.O. (East)		
9.	Name and Designation of Officer from the building side	Sh. Sanjay Kumar Sharma (Manager)		
10.	Year of Construction	2008		
11.	Applicant's letter No.	SIPS/2025-26/6/001 dated 09/06/2025		
S. No	Minimum standards on fire prevention and fire safety U/R 33	Cir. Dt. 1/3/11 Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	6m	6m	MR
	• Gate width	NA	NA	NA
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	1	2	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors	1.50m	1.50m & 0.90m	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	1	1	MR
	e. Width Of Corridor	1.5m	Provided	MR
	f. Door Size	1m	Provided	MR
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke managements System			
	• Basements	NA	NA	NA
	• Upper floors	NA	NA	NA
5.	Fire Extinguishers			
	• Total numbers	6	8	MR
	• Types	ABC / CO ₂	Provided	MR
	• ISI marking	ISI Marked	Provided	MR
6.	First – Aid Hose Reels			
	• Total numbers on each floor	1	1	MR
	• Length of hose reel hose	30m	30m	MR
	• Nozzle diameter	5mm	5mm	MR

7.	Automatic fire detection and alarming system	NA	NA	NA
	• Type of detector	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8.	MOEFA	NA	NA	NA
9.	Public Address System	NA	NA	NA
10.	Automatic Sprinkler System	NA	NA	NA
	• Basements	NA	NA	NA
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants	NA	NA	NA
	• Size of riser/down- comer	NA	NA	NA
	• Number of hydrants per floor	NA	NA	NA
	• Hose Box	NA	NA	NA
12.	Yard Hydrants	NA	NA	NA
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13.	Pumping Arrangements	NA	NA	NA
	• Ground Level	NA	NA	NA
	➤ Discharge of main pump	NA	NA	NA
	➤ Head of main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Staring/Manual stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	• Terrace level	450 LPM	Provided	MR
	➤ Discharge of pump	40 m	Provided	MR
	➤ Head of the pump	Required	Provided	MR
	➤ Power supply	NA	NA	NA
	➤ Auto starting of pump	NA	NA	NA
14.	Captive water Storage for fire fighting	NA	NA	NA
	• Underground tank capacity	NA	NA	NA
	➤ Draw of connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	10,000 ltr	10,000 ltr	MR
15.	Exit Signage	Required	Provided	MR
16.	Provision of Lifts	NA	NA	NA
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	NA	NA	NA
	➤ Fireman's Grounding Switch	NA	NA	NA
	➤ Lift Signage	NA	NA	NA
17.	Standby power supply	NA	NA	NA
18.	Refuge Area	NA	NA	NA
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA


N/9

19.	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA

Note:- Shortcomings issued by this department vide letter No. F6/DFS/MS/School/2014/1298 dated 04/06/2014 have been complied.

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

Keeping in view of the substantial compliance of the minimum standards of fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010 is recommended.


 Signature of the Inspecting Officer
 Name : Ashok Kumar Jaiswal
 Designation: D.O. (East)

Dy. C.F.O. (NDZ)

dmp
 17/06/25

C.F.O.



 26/6/25

Director


 11/07/25



As Approved, F.T. Letter is put up for sign. please


 Director
 21/7/25


 21/7/25