



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001



No: F6/DFS/MS/WZ/2026/ 129
To,

Dated: 17/04/2026

The Medical Superintendent,
Saifi Hospital Private Limited,
100 GF, Khasra No. 10/2, Arjun Nagar,
Niharl Vihar, Nangloi, Delhi – 110041

Sub: - Surprise inspection report in r/o M/s Saifi Hospital Private Limited, 100 GF, Khasra No. 10/2, Arjun Nagar, Nihal Vihar, Nangloi, Delhi – 110041.

Sir,

As per directions of the Competent Authority vide office order no. F6/DFS/HQ/2026/494 dated 20/03/2026, it is to inform you that the surprise inspection of above said Hospital building has been carried out by the officer concerned on 07.04.2026 to verify the compliance of the requisite fire safety measures installed in the building in the presence of Dr. Noor was present at the time of inspection. During the visit of the following observation were noticed:-

1. Fire check door found removed at some places.
2. Internal hydrant found removed at ground floor.
3. Pumping system not found in auto mode.
4. Overhead tank found empty.
5. Exit Signage found removed at some places.
6. Pressurization of lift lobby found removed.

You are advised to rectify the above-mentioned shortcoming under intimation to this department, till than the occupancy of the Building/ Premise in absence of requisites fire safety arrangements shall be at the risk and liabilities of the Owner/ Occupier.

Yours Faithfully


16/04/26

S.K. Dua

Chief Fire Officer
Delhi Fire Service