

248

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI- 110001

No. F6/DFS/MS/School/2025/SZ/ 825

Dated: 20/11/2025

To,

The Principal
Salwan Junior School
A-Block, Naraina Vihar,
New Delhi- 110028.

Sub: - Regarding renewal of "FSC" from fire safety point of view in r/o Salwan Junior School located at A-Block, Naraina Vihar, New Delhi- 110028.


Sir,

Please refer to your letter No. SJS/120/NOC-FireDept/2025-26 dated 06.10.2025, on the subject cited above. In this connection, it is to inform you that officer concerned of this department inspected the school building on dated 05.11.2025 to verify the fire safety arrangements in accordance with the rules. At the time of inspection Ms. Sonia Wadhwa (Principal) was present and it was observed that school building comprised of ground plus two upper floors, and have following shortcomings: -

1. Hose reels found provided but not functional.
2. Terrace fire pump of 450 LPM found provided but not functional.
3. Overhead water storage tank of 10,000 ltrs. Found provided with domestic connections.
4. Exit signage's are found removed at some places.

In view of the above, renewal of 'Fire Safety Certificate' cannot be granted at this stage. You are requested to rectify the above-mentioned shortcomings under intimation to this department for taking further necessary action in this matter and running school in absence of requisite fire safety arrangements shall be at the risk & liability of the school management.

Yours faithfully


(A. K. Malik)
Dy. Chief Fire Officer
20/11/25

Copy to: -

1. Director of Education, Govt. NCT of Delhi, Old Secretariat, New Delhi- 110054.