

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**


No. F6/DFS/MS/School/SZ/2025/1351

Dated: 26/11/2025

**FIRE SAFETY CERTIFICATE**

Certified that Salwan Public School located at Girdhari Lal Salwan Marg, Rajendra Nagar, New Delhi- 110060, having five blocks namely Block- A, Block-B, Block-D, Block-E & Block-F. Block- A, E & F are comprised of ground floor plus one upper floor. Block B & Block D are comprised of ground plus two upper floors, was issued Fire Safety Certificate vide this department No. F.6/DFS/MS/School/SZ/2023/209 dated 24.03.2023. The school building was re-inspected by the concerned officer of Delhi Fire Service on dated 05.11.2025 in the presence of Sh. Kallu Singh (admin officer) and found that the school management have complied with the fire prevention and fire safety requirements in accordance with Rule 33 of Delhi Fire Service Rules 2010 under Delhi Fire Service Act- 2007 and found that the school complex (Block- A, Block-B, Block-D, Block-E & Block-F) (Except Block- C & M.P Hall) is fit for occupancy class "Educational" with effect from 26/11/2025 for a period of 03 years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010, printed below.

Issued on 26/11/2025 at New Delhi by.

  
 (A.K. Malik)  
 Dy. Chief Fire Officer  
 South Zone

Copy to: -

1. The Principal, Salwan Public School, Rajendra Nagar, New Delhi- 110060.
2. The Directorate of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi- 54.

**Conditions for the Validity of Fire Safety Certificate**

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non-functional of fire safety measures shall be at the risk & responsibility of the management.
3. The trained firefighting staffs should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form "J" [ sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
8. All the means of escapes /exits shall not be locked/blocked at any time for safe evacuation of the occupants in case of emergency.



**INSPECTION REPORT**

1. Name & address of the building : Salwan Public School, Girdhari Lal Salwan Marg, Rajendra Nagar, New Delhi- 110060.
2. Type of Occupancy : Educational
3. Building Composition : The School building complex is comprised of five blocks. Block A, E & F (ground plus one upper floor each), Block-B & D (ground plus two upper floors each).
4. Type of Case : Renewal
5. Details of previous NOC : F.6/DFS/MS/School/SZ/209 dated 24.03.2023
6. Fire Safety directives letter No : Dt. of Education circular no. 262-362 dt. 17.01.2005
7. Date of inspection : 03.11.2025
8. Name of the Inspecting Officers : R.K. Yadav, ADO(SRD)
9. Name and designation of officers from the building side : Mr. Kallu Singh (Admin Officer)
9. Year of Construction : Before 2007 (1956, 1970) as per previous inspection Performa
10. Applicant's letter No. : SPS/674/2025 dated 13.10.2025

Sr. No.	Minimum Standards on fire prevention and fire safety U/R 33	Requirements as per FSC dt. 24.03.2023	Provided at site	Remarks MR/NMR
1	<b>Access to building</b>			
	• Road width	Accessible	Provided (9.0 mts)	MR
	• Gate width	Old Case	390 cms x 02 nos.	MR, old case
	• Width of internal road	N/A	N/A	N/A
2	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases	-	-	-
	• Upper Floors	2 each block	Provided	MR
	• Basements	N/A	N/A	N/A
	b. Width of staircases	-	-	-
	• Upper Floors	1.5 mts or less & 0.75 mt	Block A- 1.52, 1.47, Block B- 1.47, 1.50 mts, Block D- 1.35, 0.92 mts Block E- 1.50, 1.49, Block F- 1.54, 0.68-1.30 mts.	MR
	• Basements	N/A	N/A	N/A
	c. Protection of exits	-	-	-
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	e. No. of continuous staircases to terrace	01 each block	Provided	MR
	g. Width of Corridor	150 Cms	165, 215, 235 Cms	MR
	h. Door Size	1.0 mt	Provided	MR
3	<b>Compartmentation.</b>			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire Rating of shaft door	N/A	N/A	N/A
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4	<b>Smoke Management System.</b>			
	• Basements	30 a/c per hour (N/A)	N/A	N/A
	• Upper floors	12 a/c per hour	Natural ventilation	MR
5	<b>Fire Extinguishers</b>			
	• Total numbers	60 nos.	Provided	MR
	• Types	ABC, CO <sub>2</sub> type	Provided	MR
	• IS marking	ISI marked	Provided	MR



6	<b>First-Aid Hose Reels.</b>			
	• Total numbers on each floor	06	Provided	MR
	• Length of hose reel hose	30 m	Provided	MR
	• Nozzle diameter	5 mm	Provided	MR
7	<b>Automatic fire detection and alarming system.</b>			
	• Type of detectors	N/A	N/A	N/A
	• Location of Main Panel	N/A	N/A	N/A
	• Location of Repeater Panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooters' Location	N/A	N/A	N/A
8	<b>MOEFA</b>	Required	Provided	MR
9	<b>Public Address System.</b>	Required	Provided	MR
10	<b>Automatic Sprinkler System</b>			
	• Basement	N/A	N/A	N/A
	• Upper Floor	N/A	N/A	N/A
	• Sprinkler above false ceiling	N/A	N/A	N/A
11	<b>Internal Hydrants</b>			
	• Size of riser/down-comer	N/A	100 mm	N/A
	• Number of hydrants per floor	N/A	06 Nos.	N/A
	• Hose Box	N/A	06 Nos.	N/A
12	<b>Yard Hydrants.</b>			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13	<b>Pumping Arrangements</b>			
	• Ground Level	---	-----	-----
	➤ Discharge of main Pump	N/A	N/A	N/A
	➤ Head of Main pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey Pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby Pump out put	N/A	N/A	N/A
	➤ Standby Pump Head	N/A	N/A	N/A
	➤ Auto Starting/ Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace level	----	-----	-----
	➤ Discharge of pump	450 LPM each block	450 LPM × 2 each block	MR
	➤ Head of the pump	40 mts each	Provided	MR
	➤ Power Supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR
14	<b>Captive Water Storage for fire fighting</b>			
	• Underground tank capacity	N/A	N/A	N/A
	➤ Draw-off connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	N/A	N/A
	➤ Access to tank	N/A	N/A	N/A
	• Overhead Tank capacity	10000 lts	10000 lts	MR
15	<b>Exit Signage.</b>	Required	Provided	MR
16	<b>Provision of Lifts.</b>			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication In lift Car	N/A	N/A	N/A
	• Fireman's Grounding Switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A

Handy power supply		Required	Provided	MR
MR	Refuge Area.			
MR	➤ Total Area	N/A	N/A	N/A
MR	➤ Location	N/A	N/A	N/A
19	<b>Fire Control Room</b>			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Batter backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

Note: - As per undertaking submitted by the school management (placed at C- 131) that the school having 06 blocks, namely block- A, B, C, D, E & F. Block A, E & F are comprised of ground plus one upper floor only and Block B & D are comprised of ground plus two upper floors and Block C is under demolition and MP Hall is not being used for any educational purpose.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the Fire Safety Certificate issued vide letter No. F.6/DFS/MS/School/SZ/209 dated 24.03.2023, is **recommended to be renewed** under rule 37, of the Delhi Fire Service Rules, 2010.

Signature of the Inspecting Officer

Name: - R.K. Yadav

Designation: - ADO (SRD)

DO (SW)

*[Signature]*

11/11/23

RAJINDER ATWAL

Dy. CFS (SZ)

*[Signature]*  
A.R. MALIK

*[Signature]*  
Principal Director

*[Signature]*  
by CFS to SSM.

Dy. CFS (SZ)

18/11/23

*[Signature]*  
21/11/23  
A.K. MALIK

*[Signature]*  
25/11

Adm - DSK