

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No. F.6/DFS/MS/Institutional/2025/SZ/ 377  
To

Dated: 11/08/2025

Mr. Rajat Sikka,  
E-522, Greater Kailash-II,  
New Delhi 110048

Sub: Regarding issuance of Fire Safety Certificate in r/o M/s SAMA Hospital located at  
Plot No- E-522, Greater Kailash Part -II, New Delhi.  
Sir,


This has reference with letter received through Email dated 17/06/2025 on the subject cited above. In this connection, it is to inform you that the premise has been inspected by officers concerned of this department on 24.07.2025 in the presence of Mr. Nitin Kumar to check the compliance of fire safety arrangements from fire safety point of view and following shortcomings were observed:

1. The Staircase is not segregated at stilt floor.
2. The exit door width of patient room is 1.10 mtr against the required width of 1.25 mtr each.
3. Fire check door not provided in staircase and lift lobbies
4. Smoke management system not provided in the basement and upper floors.
5. Fire fighting pumps are not on auto mode.
6. Underground water storage tank capacity 75.000 ltrs measurement not provided.
7. Exit signage not provided at some places.

The same observations has already been issued and communicated earlier by this department vide letter of even no 217 dated 09/05/2025.

Keeping in view of above, the application for issuance of Fire Safety Certificate is rejected. The occupancy of the building/ premise in absence of requisite fire safety certificate shall be at the risk and liability of owner/ occupier.

Yours faithfully

  
(VIRENDRA SINGH)  
CHIEF FIRE OFFICER  
DELHI FIRE SERVICE

Copy to:

1. M/s Nursing Home located at Plot No- E-522, Greater Kailash Part -II, New Delhi.