



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001



No F6/DFS/MS/Bldg/SZ/2026/ 61

Dated: 13/04/2026

FIRE SAFETY CERTIFICATE

Certified that the M/s. Samavar (A unit Of Kashmir Educational Culture and Science Society) located B-36 Pamposh Enclave Greater Kailash-1 New Delhi-110048, in the building comprised of Basement and Ground Floor only. Owned/Occupied by Kashmiri Education Culture and Science Society, Was earlier issued Fire Safety Certificate by this department vide letter no-F.6/DFS/MS/Bldg/2023/SZ/203 dated 04/05/2023. The premises was re-inspected by the officer concerned of this department on 06/04/2026 in the presence Sh. Ramesh Kitchloo and found that the said premise have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the premise is fit for occupancy class "Assembly Building" (Community Centre/Club only) and validity upto 31/03/2029 in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010. Conditions mentioned below.

Issued on 13/04/2026 at New Delhi by.

(A.K. Malik)
Chief Fire Officer

Copy to:

1. The Commissioner MCD, Civic Centre, Minto Road, New Delhi- 110002.-to ensure the occupancy as detailed above & deviation if any.
2. The authorized signatory, M/s Samavar A Unit Of Kashmir Educational Culture and Science Society located B-36 Pamposh Enclave Greater Kailash-1 New Delhi-110048. (Online Portal ID No. -2026031402885 dated 14/03/2026.)

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management/occupier.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on
8. All the means of escape shall be kept free of any obstruction all the time to evacuate the occupant, in a safe manner, in the event of emergency.
9. Basement shall be used as per building bylaws strictly.

2/21

INSPECTION REPORT				
1. Name & address of the building	M/s. Samavar A unit Of Kashmir Educational Culture and Science Society/located B-36 Pamposh Enclave Greater Kailash-1 New Delhi-110048.			
2. Type of Occupancy	Community Centre /Club "Assembly Building" (Basement And Ground Floor)			
3. Type of Case	Renewal			
4. Details of Previous NOC	F.6/DFS/MS/Bldg/2023/SZ/203 dated 04/05/2023			
5. Fire Safety directives letter No	Nil			
6. Date of inspection	06/04/2026			
7. Name of Inspecting Officer	Sarabjeet Singh ADO (BCP)			
8. Name and designation of officers From the building side	Sh. Ramesh Kitchloo			
9. Year of Construction	2002 (as per online application)			
10. Applicant's letter No.	Online-ID No-2026031402885 dated 14/03/2026			
S. No	Minimum Standards on fire prevention and fire safety U/R 33	BBL/NBC/ Rule 35(6) of DFS Rule 2010	Provided at site	Remarks MR/NMR
1.	Access to building			
	• Road width	09m	09m	MR
	• Gate width	Required	4.3m & 3.0m x 03	MR (old case)
	• Width of internal road	NA	NA	NA
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	NA	NA	NA
	• Basements	04 nos.	03 no (enclosed) & SC ramp open	MR (old case)
	b. Width of staircases			
	• Upper Floor	NA	NA	NA
	• Basements	1.50m	1.3m, 1.3m, 1.3m, 1.9m & 2m ramp	MR
	c. Protection of exits			
	• Fire check door	Required	Provided	MR
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	Required	Provided	MR
	e. Width of Corridor	NA	NA	NA
	f. Door Size	1.50m	2.0m & 1.50m	MR
3.	Compartmentation			
	a) Fire check door	Required	Provided	MR
	b) Sealing of electrical shafts	Required	Provided	MR
	c) Fire Rating of shaft door	NA	NA	NA
	d) Water Curtain	NA	NA	NA
	e) Fire Dampers	NA	NA	NA
4.	Smoke Management System			
	a) Basements	Required	Provided	MR
	b) Upper floors	Required	Natural Ventilation	MR
5.	Fire Extinguishers			
	a) Total numbers	10 nos.	10 nos.	MR
	b) Types	ABC/CO2	ABC/CO2	MR
	c) IS marking	ISI marked	Provided	MR

6.	First-Aid Hose Reels			
	a) Total numbers on each floor	01 nos.	01 nos.	MR
	b) Length of hose reel hose	30m	30m	MR
	c) Nozzle diameter	5mm	Provided	MR
7.	Automatic fire detection and alarming system			
	a) Type of detectors	NA	NA	NA
	b) Location of Main Panel	NA	NA	NA
	c) Location of Repeater Panel	NA	NA	NA
	d) Alternate source of power	NA	NA	NA
	e) Hooters' Location	NA	NA	NA
8.	MOEFA	Required	Provided	MR
9.	Public Address System	NA	NA	NA
10.	Automatic Sprinkler System			
	a) Basement	Required	Provided	MR
	b) Ground & Upper Floors	NA	NA	NA
	c) Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants			
	a) Size of riser/down-comer	100mm	100mm	MR
	b) Number of hydrants per floor	01 nos.	01 nos.	MR
	c) Hose Box	01 nos.	01 nos.	MR
12.	Yard Hydrants			
	a) Total number of hydrants	NA	NA	NA
	b) Hose Box	NA	NA	NA
13.	Pumping Arrangements			
	• Ground Level			
	➤ Discharge of main Pump	NA	NA	NA
	➤ Head of Main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey Pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Starting/Manual Stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	Terrace level			
	➤ Discharge of pump	450 & 180 LPM	450 & 180 LPM	MR
	➤ Head of the pump	30m	30m	MR
	➤ Power Supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR
14.	Captive Water Storage for fire fighting			
	• Underground tank capacity	NA	NA	NA
	➤ Draw-off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	15,000 ltrs	15,000 ltrs	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	a) Pressurization of Lift Shaft	NA	NA	NA
	b) Pressurization of Lift lobby	NA	NA	NA

n/22

	c) Communication In lift Car	NA	NA	NA
	d) Fireman's Grounding Switch	NA	NA	NA
	e) Lift Signage	NA	NA	NA
17.	Standby power supply	Required	Provided DG set	MR
18.	Refuge Area.			
	a) Total Area	NA	NA	NA
	b) Location	NA	NA	NA
19.	Fire Control Room			
	a) Detector System Panel	NA	NA	NA
	b) Flow Switch Panel	NA	NA	NA
	c) PA System Panel	NA	NA	NA
	d) Battery backup	NA	NA	NA
	e) Building Floor Plans	NA	NA	NA
20.	Special Fire Protection System for Protection of special Risks, if any:	NA	NA	NA

The fire protection systems provided in the building were checked and found functional at the time of inspection. Earlier all the shortcomings issued by this department vide letter No. F6/DFS/MS/EH/SZ/2026/361 dated 03/03/2026 have been rectified.


Keeping in view of the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the rules, the FSC issued vide letter no F.6/DFS/MS/Bldg/2023/SZ/203 dated 04/05/2023, renewal under rule 37 of the Delhi Fire Service rules, 2010 is recommended.

Accordingly, DFA is put up for approval and signatures please.
Last Date of Disposal-13/04/2026.

Name - Sarabjeet Singh
Designation - ADO(BCP)

DO (SD) 
9/4/26
Ravinder Singh


10/4/26
A.K. MALIK


Principal Director

By. c/o to Team.


10/04/26


By. c/o (c2)


10/4/26