

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI - 110001**

Dated: 09/05/2025

No. F6/DFS/MS/GH/NDZ/2025/ 329

**FIRE SAFETY CERTIFICATE**

Certified that the M/s Samir Guest House located at 5937-38, Ballimaran, Delhi, comprised of **Ground + 04 upper floors: Ground floor** - (reception + 08 guest rooms), **1<sup>st</sup> to 2<sup>nd</sup> floor** - (11 guest rooms at each floor), **3<sup>rd</sup> floor** - (03 guest rooms + 01 store + office/staff room) & **4<sup>th</sup> floor** - (not in use). FSC was granted by this department vide letter no. F6/DFS/MS/GH/NDZ/2021/333 dated 24.08.2021 for total 33 guest rooms upto 3<sup>rd</sup> floor. The building/premises was re-inspected by officer concerned of this department on 03.05.2025 in presence of Mohd. Shanstavrej (Staff Member) and found that the building has deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of Delhi Fire Service Rules, 2010. The owner has submitted an undertaking on 05.05.2025 stating not to use any floor above third floor for any purpose. Accordingly, the premises is fit for occupancy class **"Residential" Sub Division-A-1, ground floor** - (reception + 08 guest rooms), **1<sup>st</sup> floor** - (11 guest rooms), **2<sup>nd</sup> floor** - (11 guest rooms) & **3<sup>rd</sup> floor** - (03 guest rooms) for **total 33 guest rooms upto 3<sup>rd</sup> floor only**, with effect from 09/05/2025 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to conditions under rule 38 of Delhi Fire service Rules, 2010 subject to condition printed below.

Issued on 09/05/2025 at New Delhi by

(Atul Garg)

Director

Delhi Fire Service

Tel: 011-23414000

**Copy to:-**

1. The Commissioner, MCD, Delhi:- with a request to kindly ensure the occupancy as detailed above & deviation, if any.
2. The Joint Commissioner of Police (Licensing), 1<sup>st</sup> Floor, Police Station Defence Colony, New Delhi. w.r.to ID No. 2025042006765 dated 20.04.2025.
3. The Licensee, M/s Samir Guest House at 5937-38, Ballimaran, Delhi.

**Conditions for the validity of fire safety certificate**

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry".
8. Any change in the occupancy shall be intimated to this Deptt. and approval shall be obtained thereto before occupancy of the same.
9. The occupancy of above 3<sup>rd</sup> floor not allowed as per clause 7.31 in UBBL-2016.

INSPECTION REPORT				
1	Name & address of the building			
2	Building is comprised of			
3	Type of occupancy			
4	Type of case			
5	Details of previous FSC			
6	Fire safety direction letter no.			
7	Date of inspection			
8	Name of the inspecting officers			
9	Name of the designation of officer from the building side			
10	Year of construction			
11	Applicant's letter no.			
S.No	Minimum Standards on fire Prevention and fire safety requirements U/R 33	Requirement/ Existing fire safety arrangements	Provided at Site	Remarks MR/ NMR
1	<b>Access To Building:</b>			
	Road width	NA	06 m Approx.	NA
	Gate width	NA	NA	NA
	Width of internal road	NA	NA	NA
2	<b>Number, Width, Type and Arrangement of Exits:</b>			
A	Number of staircases			
a	Upper floor	01 no.	01 no.	MR
b	Basement	NA	NA	NA
B	Width of staircases			
a	Upper floor	106 cms.	106 cms.	MR
b	Basement	NA	NA	NA
C	Protection of exits			
a	Fire check door	Required	Provided	MR
b	Pressurization	NA	NA	NA
D	No. of continuous staircases to terrace	01 no.	01 no.	MR
E	Width of corridor	1.80 mtr.	1.90 mtr.	MR
F	Door size	1.0 mtr.	1.0 mtr.	MR
3	<b>Compartmentation:</b>			
A	Fire check door	NA	NA	NA
B	Sealing of electrical shafts	NA	NA	NA
C	Fire rating of shaft door	NA	NA	NA
D	Water curtain	NA	NA	NA
E	Fire dampers	NA	NA	NA
4	<b>Smoke Management System:</b>			
A	Upper floors	12 ACPH	Provided	MR
B	Basements	NA	NA	NA



5.	<b>Fire Extinguisher:</b>				
	A	Total numbers	14 nos.	14 nos.	MR
	B	Types	CO <sub>2</sub> & ABC	CO <sub>2</sub> & ABC	MR
	C	ISI marking	Required	Provided	MR
6	<b>First-Aid-Hose Reels:</b>				
	A	Total numbers of each floor	01 no.	01 no.	MR
	B	Length of hose reel hose	30 m	30 m	MR
	C	Nozzle diameter	05 mm	05 mm	MR
7	<b>Automatic Fire Detection And Alarming System:</b>				
	A	Type of detectors (CO type)	Required	Provided	MR
	B	Location of main panel	Required	Provided	MR
	C	Location of repeater panel	NA	NA	NA
	D	Alternate source of power	Required	Provided	MR
	E	Hooters	Required	Provided	MR
8	<b>MOEFA:</b>		Required	Provided	MR
9	<b>Public Address System:</b>		Required	Provided	MR
10	<b>Automatic Sprinkler System:</b>				
	A	Basement	NA	NA	NA
	B	Upper floor	NA	NA	NA
	C	Sprinkler above false ceiling	NA	NA	NA
11	<b>Internal Hydrants:</b>				
	A	size of riser/down-comer	NA	NA	NA
	B	Number of hydrants per floor	NA	NA	NA
	C	Hose box	NA	NA	NA
12	<b>Yard Hydrants:</b>				
	A	Total number of hydrants	NA	NA	NA
	B	Hose box	NA	NA	NA
13	<b>Pumping Arrangements:</b>				
	A	Ground level			
	a)	Discharge of main pump	NA	NA	NA
	b)	Head of main pump	NA	NA	NA
	c)	Number of main pumps	NA	NA	NA
	d)	Jockey pump out put	NA	NA	NA
	e)	Jockey pump head	NA	NA	NA
	f)	Standby pump out put	NA	NA	NA
	g)	Standby pump head	NA	NA	NA
	h)	Auto starting /manual stopping	NA	NA	NA
	i)	Pump house access	NA	NA	NA
	B	Terrace level			
	a)	Discharge of pump	450 LPM	450 LPM	MR
	b)	Head of the pump	30 m	30 m	MR
	c)	Power supply	Required	Provided	MR
	d)	Auto starting of pump	Required	Provided	MR

N/39			
14	<b>Captive Water Storage For Fire Fighting:</b>		
A	Underground tank capacity	NA	NA
B	Draw-off connection	NA	NA
C	Fire service inlet	NA	NA
D	Access to tank	NA	NA
E	Overhead tank capacity	NA	NA
15	<b>Exit Signage:</b>	10,000 ltrs.	10,000 ltrs.
16	<b>Provision of Lifts:</b>	Required	Provided
A	Pressurization of lift shaft	NA	NA
B	Pressurization of lift lobby	NA	NA
C	Communication in lift car	NA	NA
D	Firemen's grounding switch	NA	NA
E	Lift signage	NA	NA
17	<b>Standby Power Supply:</b>	Required	Provided
18	<b>Refuge Area:</b>		
A	Total area	NA	NA
B	Location	NA	NA
19	<b>Fire Control Room :</b>		
A	Detector system panel	NA	NA
B	Flow switch panel	NA	NA
C	Pa system panel	NA	NA
D	Battery backup	NA	NA
E	Building floor plans	NA	NA
20	<b>Special Fire Protection Systems For Protection of Special Risks, If Any:</b>	NA	NA

The fire protection systems provided in the building were tested, checked at random and found functional at the time of inspection.

Keeping in view of the deemed compliance of minimum standards of fire prevention and fire safety measures as required under the Rules, the FSC issued vide letter No F6/DFS/MS/GH/NDZ/2021/333 dated 24.08.2021 is recommended to be renewed upto 3<sup>rd</sup> floor only, under Rule 35 of the Delhi Fire Service Rules 2010.

Signature of the Inspecting Officer  
Name Suman Kumar  
Designation ADO

DO (CD)

5/5/25

Sycho (no 2)

div

06/05/25

C.F.O.

7/5/25

Director

5/5/25

Adm/Suman