

C-11

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE**  
**NEW DELHI- 110001**

No. F6/DFS/MS/School/2025/SZ/ 589

Dated: 11/07/2025

To,

The Principal,  
Sanjeevan Public School, D-276,  
Dashrathpuri, New Delhi- 110058.

**Sub:** -Regarding renewal of "Fire Safety Certificate" from fire safety point of view in r/o Sanjeevan Public School at D-276, Dashrathpuri, New Delhi- 110058.

Sir,

Please refer to your letter received through online Email Id [sanjeevanpublicschool2013@gmail.com](mailto:sanjeevanpublicschool2013@gmail.com) dated. 03.04.2025, on the subject cited above. In this connection this is to inform you that officer concerned of this department inspected the school building on dated 01.07.2025 to verify the fire safety arrangements in accordance with the rules. At the time of inspection Sh. Sanjeev Gupta was present and it was observed that the school building comprised of ground plus one upper floor, and have following shortcomings:-

1. Previously, school building having two staircases with width of 1.0 meter each but now The School Management removed one staircase width of 1.0 meter.

In view of the above, renewal of 'Fire Safety Certificate' cannot be granted at this stage. You are requested to rectify the above-mentioned shortcomings under intimation to this department for taking further necessary action in this matter and running school in absence of requisite fire safety arrangements shall be at the risk & liability of the school management.

Yours faithfully

  
(Atul Garg)  
Director

Delhi Fire Service

Copy to:-

1. Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054.