

C/60

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE

NEW DELHI- 110001
No. F.6/DFS/MS/EH/2025/SZ/ 260

Dated: 07/07/2025

FIRE SAFETY CERTIFICATE

Certified that the M/s Sanjha Chulha at A-31, GF, Shop No. 17, 18, 20, 21 & 22, Kailash Colony, New Delhi- 110048, running at ground floor only in a building comprised of ground plus two upper floors, was issued FSC by this department vide Letter No. F.6/DFS/MS/EH/2022/SZ/321 dated 18.11.2022. The restaurant building was re-inspected by the officer concerned of this department on dated 03.07.2025 in the presence of Sh. Nand Kishore, and found that the restaurant have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the restaurant building/premises (**Ground floor only**) is fit for occupancy class **Group "D" Assembly Building** w.e.f. 07/07/2025 and valid up-to 31.03.2028, accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule-38 of the Delhi Fire Service Rules, 2010 printed below.
Issued on 07/07/2025 at New Delhi.

(Anur Garg)
Director
Delhi Fire Service

Copy to: -

- 1 The Commissioner, MCD, Delhi: with a request to ensure the occupancy as detailed above and deviation, if any.
- 2 Online application Id 2025060709795 dated 11.06.2025.

Conditions for validity of Fire Safety Certificate:-

1. This NOC is valid only for Ground floor.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
3. The means of escape shall be kept unlocked and unobstructed for unhindered evacuation of occupants in case of emergency.
4. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
5. The trained staff should be available round the clock.
6. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
7. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
9. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in the Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

INSPECTION REPORT

1. Name & address of the building : M/s Sanjha Chulha at A-31, Shop No. 17, 18, 20, 21 & 22, Kailash Colony, New Delhi- 110048.
2. Building is comprised of : Ground plus two upper floors
3. Type of Occupancy : Group D (Assembly) Restaurant running at Ground floor only
4. Type of Case : Renewal
5. Details of Previous NOC : F.6/DFS/MS/EH/2022/SZ/321 dated 18.11.2022
6. Fire Safety directives letter No : Nil
7. Date of inspection : 03.07.2025
8. Name of Inspecting : A.D.O. R.K. Yadav (JKP)
9. Name and designation of officers
From the building side : Sh. Nand Kishore
10. Year of Construction : 1967
11. Applicant's letter No. : MHA Portal ID 2025060709795 dated 11.06.2025

| S. No. | Minimum Standards on fire prevention and fire safety U/R 33 | Requirements | Provided at site | Remarks MR/NMR |
|--------|-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|-----------------------------------------------|-------------------------------------------|---------------------------------|
| 1. | Access to building | | | |
| | <ul style="list-style-type: none"> Road width Gate width Width of internal road | 06 m N/A N/A | Provided N/A N/A | M/R N/A N/A |
| 2. | Number, Width, Type & Arrangement of Exits (Restaurant at Ground floor only) | | | |
| | a. Number of staircases | | | |
| | <ul style="list-style-type: none"> Upper Floors Basements | N/A N/A | N/A N/A | N/A N/A |
| | b. Width of staircases | | | |
| | <ul style="list-style-type: none"> Upper Floor Basements | N/A N/A | N/A N/A | N/A N/A |
| | c. Protection of exits | | | |
| | <ul style="list-style-type: none"> Fire check door Pressurization | N/A N/A | N/A N/A | N/A N/A |
| | d. No. of continuous staircases to terrace | N/A | N/A | N/A |
| | e. Width of Corridor | N/A | N/A | N/A |
| | f. Door Size | 02 Exits | 2.0 & 0.93 m | MR, old case |
| 3. | Compartmentation | | | |
| | <ul style="list-style-type: none"> Fire check door Sealing of electrical shafts Fire Rating of shaft door Water Curtain Fire Dampers | N/A N/A N/A N/A N/A | N/A N/A N/A N/A N/A | N/A N/A N/A N/A N/A |
| 4. | Smoke Management System | | | |
| | <ul style="list-style-type: none"> Basements Upper floors | N/A 12 ACPH | N/A Exhaust Fan Provided | N/A MR |
| 5. | Fire Extinguishers | | | |
| | <ul style="list-style-type: none"> Total numbers in restaurant Types IS marking | 12 no.'s ABC/CO ₂ ISI marked | Provided ABC- 04 & Co2- 04 Provided | M/R M/R M/R |
| 6. | First-Aid Hose Reels | | | |
| | <ul style="list-style-type: none"> Total numbers at each floor Length of hose reel hose Nozzle diameter | 1 Nos. 30 mtrs 5 mm | Provided Provided Provided | M/R M/R M/R |

(* OHT-2 and 1/6/2020)

N/24

| | | | | |
|-----|-------------------------------------------------------------------------|----------|----------|-----|
| 17. | Standby power supply | Required | Provided | M/R |
| 18. | Refuge Area. | | | |
| | ➤ Total Area | N/A | N/A | N/A |
| | ➤ Location | N/A | N/A | N/A |
| 19. | Fire Control Room | | | |
| | • Detector System Panel | N/A | N/A | N/A |
| | • Flow Switch Panel | N/A | N/A | N/A |
| | • PA System Panel | N/A | N/A | N/A |
| | • Battery backup | N/A | N/A | N/A |
| | • Building Floor Plans | N/A | N/A | N/A |
| 20. | Special Fire Protection System for Protection of special Risks, if any: | N/A | N/A | N/A |

The fire protection systems provided in the building were tested, checked and found not functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the FSC issued vide letter No. F.6/DFS/MS/EH/2022/SZ/321 dated 18.11.2022, renewal under rule 37 of the Delhi Fire Service Rules 2010 is recommended.

R.K. Yadav
31/7/2025
Signature of the Inspecting Officer
Name: - R.K. Yadav
Designation: - ADO (JKP)

DO (SD)

Out Station

CFO/

[Signature]
4/7/2025

Director

Uploded
07/7/25
Q2