



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

No. F.6/DFS/MS/CGHS/2025/SZ/ 198

Dated: 29/04/2025

To

Sh. Sunil Kumar,  
Hony. Vice President,  
The Sanmati CGHS Limited  
Plot No. 19A, Sector-6,  
Dwarka, New Delhi-110075

**Sub: Renewal of Fire Safety Certificate in r/o "The Sanmati CGHS Ltd" situated at Plot No. 19A, Sector-6, Dwarka, New Delhi.**

Sir,

Please refer to your letter No. Sanmati/2025/Feb/25/L-2 dated 21/02/2025 received through outdoor diary No. 12196 dated 21/02/2025, on the subject cited above. In this connection, the said residential complex was visited by the officer concerned of this department on 23/04/2025 in the presence of Sh. Rahul Chaudhary (Manager) to verify the status of the shortcomings issued by this office vide letter No. F.6/DFS/MS/CGHS/2019/SZ/7208 dated 05/12/2019 and the observation is as mentioned below.

S. No.	Shortcomings issued	Present Status
1.	Width of internal road all around the building is 5.80m instead of required width of 6 meter.	Not Complied
2.	Width of staircase is 1.10m in each block instead of required width of 1.25 meter.	Not Complied
3.	Public address system is provided but not found functional.	Complied
4.	MOEFA is provided but not functional.	Complied
5.	Fire pumps not found on auto-operation.	Complied
6.	Exit signage found removed at some locations.	Complied

In view of above, application for renewal of fire safety certificate is rejected. You are advised to rectify the left-over shortcomings under intimation to this department for further action.

Yours faithfully,

(ATUL GARG)  
DIRECTOR  
Ph 011-23414000

Copy to: -

1. The Joint Director (Bldg), DDA, Vikas Sadan, INA, New Delhi-110023