No: F.6/DFS/MS/School/2025/WZ/ 172

Dated: 26/03/2025

To,

The Principal,
Sant Ganga Ram Global School,
Kh. No. 135, Main Road,
Village Ghoga, Delhi-110039.

Sub: - Regarding issuance of Fire Safety Certificate in r/o Sant Ganga Ram Global School located
at Kh. No. 135, Main Road, Village GhogaDelhi- 110039.

Sir,

This has reference to your letter no. nil dated 05.03.2025 received through outdoor diary no. 14114 dated 05.03.2025 on the subject cited above. In this connection, it is to inform you that the inspection of above said school building has been carried out by officer concerned of this department on 18.03.2025 in presence of Smt. Madhu Bala (Head Mistress) to verify the fire safety arrangements provided therein.

During the course of inspection it was observed that previously this department had issued FSC vide letter no. F6/DFS/MS/2018/School/532 for a building of ground floor only but now the school management had constructed new building of ground and first floor and the previous building of ground floor is not in use. Your request for issuance of FSC is rejected due to the following shortcomings:-

1. There is only one staircase of width 1.50 m provided against the requirement of two staircases of width 1.50 m each.
2. Fire extinguishers found provided but not functional.
3. First aid hose reel is not provided.
4. Terrace level pump of 450 lpm discharge capacity is not provided.
5. Terrace level fire water tank of 10,000 ltrs capacity is not provided.
6. Exit signage's not provided.

Keeping in view of above, the application for issuance of fire safety certificate cannot be considered at this stage & rejected. You are requested to rectify the above-mentioned shortcomings under intimation to this department; till such time running of school premises is at your own risk & responsibility.

Yours Faithfully

(Atul Garg)
Director
Ph. 011-23414000

Copy to:-

1. Director of Education, Govt. Of NCT of Delhi, Old Secretariat, Delhi.