



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001



No. F6/DFS/MS/2025/School/ 477

Dated: 06/06/2025

To

Sh. Rajiv Sharma (Manager)
Sant Gyan Public School located
at Khasra No-252/81, Gali No-11,
Block-C, Part-I, Mukundpur, Delhi-42.

Sub: - Regarding renewal of fire safety certificate in r/o Sant Gyan Public School located at Khasra No-252/81, Gali No-11, Block-C, Part-I, Mukundpur, Delhi-110042.

Sir,

Please refer to your letter received through online e-mail dated: 19/05/2025 on the subject cited above. In this connection this is to inform you that the above mentioned site was visited by the officer concerned of this department on 26/05/2025 to check the existing fire safety measures. During inspection it has been observed that the school premise is comprised of ground & first floor. At the time of inspection Sh. Rajiv Sharma (Manager) was also present at site. During the course of inspection the observations/ shortcomings made are as under:-

1. Hose reel hose is provided but not functional and damaged condition.
2. Terrace level fire pump capacity of 220 lpm found removed at site.
3. Terrace level fire water tank capacity of 1000 ltr is provided against the requirement of 2500 ltr.

Keeping in view of above, renewal of Fire Safety Certificate cannot be considered at this stage & rejected. You are requested to rectify the above mentioned shortcomings under intimation to this department; till such time running of school building is at your own risk & responsibility.

Yours faithfully

(M.K. Chattopadhyay)
Dy. Chief Fire Officer
Delhi Fire Service

Copy to:-

1. The Deputy Director of Education, GNCT of Delhi, Zone-VII, District North Lucknow Road, Timarpur, Delhi - 110054.