



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001



No. F6/DFS/MS/2025/School/ 198

Dated: 28 /02/2025

FIRE SAFETY CERTIFICATE

Certified that the Sant Nirankari Girls Sr. Sec. School located at Sant Nirankari Colony, Delhi-110009 comprised of 04 New blocks interconnected (Ground & 03 upper floors each) owned/ occupied by Sant Nirankari Girls Sr. Sec. School was issued Fire Safety Certificated vide this office letter no. F6/DFS/MS/School/2022/WZ/560 dated 20.05.2022. The premise was inspected by the officer concerned of this department on 03.01.2025 in the presence of Smt. Rishika (Sr. Accountant) and observed that all the fire prevention and fire safety arrangements as provided in the premise found in good working condition The premise have therefore deemed complied with the requirements under rule 33 of the Delhi Fire Service Rules, 2010 and the building premise is fit for occupancy class "Educational Group B (School)" with effect from28/02/2025 for a period of three years, in accordance with the rule 36 unless renewed under rule 37 or sooner cancelled under rule 40, subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010,

Issued on28/02/2025 at New Delhi

(Atul Garg)
Director

Ph: 011-23414000

Copy to: -

1. The Dy. Director of Education, Zone-IX, DNW-A, Shalimar Bagh, BL Block, Delhi-110088.
2. The Principal, Sant Nirankari Girls Sr. Sec. School located at Sant Nirankari Colony, Delhi-110009.

Conditions for the validity of Fire Safety Certificate:

1. All the means of escape shall be kept free from any type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipment and method of smooth and speedy safe evacuation of occupants in case of emergency
3. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seem during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities. This Fire Safety Certificate is valid only for permanent building structure as per plan.
5. This fire safety certificate may not be treated in any case of regularizations of unauthorized construction/unauthorized use of land or activities, if any.
6. The owner / occupier shall submit a declaration **every year** in **Form "K"** provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on the official website of Delhi Fire Service i.e. www.dfs.delhigovt.nic.in.
7. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in **Form 'J'** [sub rule (1) of rule 37] along with a copy of this Certificate, **six months** prior to its expiry".

INSPECTION REPORT

1. Name & address of the building : Sant Nirankari Girls Sr. Sec. School at Sant Nirankari Colony, Delhi-110009.
2. Type of Occupancy : Educational
3. Composition of building : 04 blocks interconnected, (Ground & 03 upper floor)
4. Type of Case : Renewal
5. Details of previous NOC : F6/DFS/MS/School/2022/WZ/560 dated 20.05.2022
6. Fire Safety directives letter No : NBC Part-4
7. Date of inspection : 20.05.2025
8. Name of the Inspecting Officers : ADO (RN)
9. Name and designation of officers
from the building side : Smt. Meena Kumari (Principal)
10. Year of Construction : 2008
11. Applicant's letter No. : Letter No. SNGSSS/2024-25/679 dated: 11.02.2025

	Minimum Standards on fire prevention and fire safety U/R 33	NBC Part-IV/UBBL-2016 Requirements	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	06m	06m	MR
	• Gate width	4.50m	4.50 m	MR
	• Width of internal road	NA	NA	NA
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	03	03 & 01 ramp	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper Floors	1.50m	1.55m each & 01 ramp from G to 2 nd floor 1.60m	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	02	03	MR
	e. Width of Corridor	NA	NA	NA
	f. Door Size	1.20m	Provided	MR
3	Compartmentation.			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	Smoke Management System.			
	• Basements	NA	NA	NA
	• Upper floors	Required	Natural Ventilation	MR
5	Fire Extinguishers			
	• Total numbers	28nos	Provided	MR
	• Types	ABC/Co2	Provided	MR
	• ISI marking	ISI Marked	Yes	MR
6	First-Aid Hose Reels.			

	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	04	04	
		30m	30m	MR
		5mm	5mm	MR
7	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
8	MOEFA	NA	NA	NA
9	Public Address System.	NA	NA	NA
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> Basement Upper Floor Sprinkler above false ceiling 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
11	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-corer Number of hydrants per floor Hose Box 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
12	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	NA	NA	NA
		NA	NA	NA
13	Pumping Arrangements.			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/ Manual stopping Pump House Access Terrace level <ul style="list-style-type: none"> Discharge of pump Head of the pump Power Supply Auto Starting of pump 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		450 LPM	450 LPM Each	MR
		40m	40m	MR
		Required	Provided	MR
		Required	Provided	MR
14	Captive Water Storage for fire fighting			
	<ul style="list-style-type: none"> Underground tank capacity <ul style="list-style-type: none"> Draw-off connection Fire service inlet Access to tank Overhead Tank capacity 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		10,000 LTR	Provided	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			

N/17

	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication In lift Car	N/A	N/A	N/A
	• Fireman's Grounding Switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Batter backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested/ checked randomly and found in working condition at the time of inspection. The management has complied all the shortcomings issued and communicated by this department vide letter of even no. F6/DFS/MS/2025/School/31 dated 15.01.2025.

Keeping in view the satisfactory compliance of the minimum standards on fire prevention and fire safety required as stipulated in NBC Part 4/UBBL-2016, the FSC issued vide letter of even no. F6/DFS/MS/School/2022/WZ/560 dated 20.05.2022, renewal under rule 37 of the Delhi Fire Service Rules, 2010.

Signature of the Inspecting Officer

Name :- C.L. Meena

Designation :- ADO/RN

D.B. Mukharjee (DO/NW) - on leave

(By CFO (WZ))

25/2/2025

CFO
25/2/2025

Director
25/2/2025

ADO/RN

conf - - - P.T.O.

DCFO/.....1057/2025
Dated.....25/2/2025