

C 30



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No. F.6/DFS/MS/School/2025/SZ/615

Dated: 06/05/2025

FIRE SAFETY CERTIFICATE

Certified that the **M/s Sant Nirankari Public School** located Opp. Gali No-15, Govind Puri, New Delhi-110019 having three interconnected Blocks, **Block A:** Ground + Two upper floors, **Block B & C:** Ground + Three upper floors each was issued FSC by this department vide letter No. F6/DFS/MS/School/2022/SZ/893 Dated 17/08/2022. The premise was re-inspected by the officer concerned of this department on 30/04/2025 in the presence of Ms. Neeraj Mahipal Chawla (Head Mistress) and found that the school have deemed complied with the fire prevention and fire safety arrangements in accordance with Directorate of Education circular No F.16//Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011 issued by Director of Education, Govt. of NCT of Delhi and that the premises is fit for occupancy class "**Educational Building, Group-B**" with effect from 06/05/2025 for a period of **Three years** subject to compliance of the conditions as mentioned below.

Issued on 06/05/2025 at New Delhi by

(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE

Copy to: -

1. Sant Nirankari Public School, Opp. Gali No-15, Govind Puri, New Delhi-110019
2. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi -54.

Conditions for the validity of Fire Safety Certificate

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of firefighting system.
4. This certificate cannot be treated as regularization of unauthorized construction, if any.
5. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in the form 'J' [sub rule (1) of rule 37] along with copy of this certificate, six months prior to its expiry."

INSPECTION REPORT				
1	Name & Address of the Building	Sant Nirankari Public School, Opp. Gali No-15, Govind Puri, New Delhi-110019		
2	Type of Occupancy	Educational Building, Group-B (School)		
3	Building Comprised of	Block A= G+2, Block B & C= G+3 upper floors. All the three blocks are interconnected.		
4	Type of Case	Renewal		
5	Details of Previous NOC	F.6/DFS/MS/School/2022/SZ/893 Dated 17/08/2022		
6	Fire Safety Directives Letter No	F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011		
7	Date of Inspection	30-04-2025		
8	Name of the Inspecting Officers	Sh. Rajesh Kumar ADO (BCP)		
9	Name & Designation of Officers from the building side	Ms. Neeraj Mahipal Chawla (Headmistress)		
10	Year of construction	1987, 2000, 2015		
11	Applicant letter No.	DFS Outdoor diary no 839 dated 21/04/2025		
S. No.	Minimum standards on Fire Prevention and Fire Safety U/R 33	Requirements Old NOC	Provided at Site	Remarks MR/NMR
1	Access to Building.			
	• Road width	Accessible	6 mts	MR
	• Gate width	-NA-	4.5m	-NA-
	• Width of internal road	-NA-	-NA-	-NA-
2	Number, width, type & arrangement of exits.			
	a) Number of Staircase			
	➤ Upper floors.	3 Nos	4 Nos	MR
	➤ Basement floor.	-NA-	-NA-	-NA-
	b) Width of Staircase			
	➤ Upper floors	1.5m/ 0.75m	Blk A=1.5m x 1, Blk B= 1.5m x 2 and Blk C= 1.5m x 1	MR
	➤ Basement floor	-NA-	-NA-	-NA-
	c) Protection of exits			
	➤ Fire check door	-NA-	-NA-	-NA-
	➤ Pressurization	-NA-	-NA-	-NA-
	d) No. of continuous staircase to terrace	Two	Four	MR
	e) Width of corridor	-NA-	-NA-	-NA-
	f) Door size	1m	1m	MR
3	Compartmentation.			
	• Fire check door.	-NA-	-NA-	-NA-
	• Sealing of electrical shafts.	-NA-	-NA-	-NA-
	• Fire rating of shaft door.	-NA-	-NA-	-NA-
	• Water curtain	-NA-	-NA-	-NA-
	• Fire dampers.	-NA-	-NA-	-NA-
4	Smoke Management system.			
	• Basement	30 ACPH	-NA-	-NA-
	• Upper floors	12 ACPH	-NA-	-NA-
5	Fire Extinguishers.			
	• Total numbers	15 Nos	18 Nos	MR
	• Types	ISI marked	ABC & CO ₂	MR
	• ISI Marking		Provided	MR
6	First Aid Hose Reels.			
	• Total numbers on each floor.		Gd. to 2 nd Floor=3 Nos, 3 rd Floor= 2 Nos	MR
	• Length of hose-reel hose.	Hose Reel	30m	MR
	• Nozzle Diameter		5mm	MR
7	Automatic fire detection & alarming system.			
	• Type of detectors	-NA-	-NA-	-NA-
	• Location of Main Panel	-NA-	-NA-	-NA-
	• Location of Repeater Panel	-NA-	-NA-	-NA-
	• Alternate source of power	-NA-	-NA-	-NA-
	• Hooter's location	-NA-	-NA-	-NA-

Sant Nirankari Public School, Govind Puri, New Delhi

Renewal

N.

21/17

8	MOEFA	-NA-	-NA-	-NA-
9	Public Address System	-NA-	-NA-	-NA-
10	Automatic Sprinkler System			-NA-
	• Basement	-NA-	-NA-	-NA-
	• Upper floors	-NA-	-NA-	-NA-
	• Sprinkler above false ceiling	-NA-	-NA-	-NA-
11	Internal Hydrants.			
	• Size of Riser/Down-comer	Required	100 mm	MR
	• Number of Hydrant per floor	-NA-	One	-NA-
	• Hose box.	-NA-	One	-NA-
12	Yard Hydrants.			
	• Total number of hydrants.	-NA-	-NA-	-NA-
	• Hose box.	-NA-	-NA-	-NA-
13	Pumping arrangements.			
	• Ground Level			
	➤ Discharge of main pump.	-NA-	-NA-	-NA-
	➤ Head of main pump.	-NA-	-NA-	-NA-
	➤ Number of main pumps.	-NA-	-NA-	-NA-
	➤ Jockey Pump output.	-NA-	-NA-	-NA-
	➤ Jockey Pump head.	-NA-	-NA-	-NA-
	➤ Standby Pump output.	-NA-	-NA-	-NA-
	➤ Standby Pump head.	-NA-	-NA-	-NA-
	➤ Auto Starting/Manual Stopping.	-NA-	-NA-	-NA-
	➤ Pump house access.	-NA-	-NA-	-NA-
	• Terrace Level			
	➤ Discharge of pump.	Required	450 LPM x 3 Nos	MR
	➤ Head of pump.	40m	40m (each)	MR
	➤ Power supply.	Required	Provided	MR
	➤ Auto starting of pump.	Required	Provided	MR
14	Captive water storage for fire fighting.			
	• Underground tank capacity.	-NA-	-NA-	-NA-
	➤ Draw-off connection.	-NA-	-NA-	-NA-
	➤ Fire Service Inlet.	-NA-	-NA-	-NA-
	➤ Access to tank.	-NA-	-NA-	-NA-
	• Overhead tank capacity.	Required	15,000 Lts	MR (old case)
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	• Pressurization of lift shaft.	-NA-	-NA-	-NA-
	• Pressurization of lift lobby.	-NA-	-NA-	-NA-
	• Communication in lift car.	-NA-	-NA-	-NA-
	• Fireman's switch.	-NA-	-NA-	-NA-
	• Lift signage.	-NA-	-NA-	-NA-
17	Standby Power Supply	-NA-	-NA-	-NA-
18	Refuge Area			
	• Total area	-NA-	-NA-	-NA-
	• Location	-NA-	-NA-	-NA-
19	Fire Control Room.			
	• Detector system panel.	-NA-	-NA-	-NA-
	• Flow switch panel.	-NA-	-NA-	-NA-
	• PA system panel.	-NA-	-NA-	-NA-
	• Battery backup.	-NA-	-NA-	-NA-
	• Building floor plan.	-NA-	-NA-	-NA-
20	Special Fire Protection System for the Protection of special Risk, if any.	-NA-	One CO ₂ type fire extinguisher provided near electrical panel	-NA-

N/18

Sant Nirankari Public School, Opp. Gali No-15, Govind Puri, New Delhi-110019

The Fire protection systems provided in the building/premise were test checked at random and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the rules, the FSC issued vide letter No. F6/DFS/MS/School/2022/SZ/893 Dated 17/08/2022, renewal under rule 37 of the Delhi Fire Service Rules, 2010 is recommended.

Accordingly DFA is put up for approval and signature please.

Sh. Rajesh Kumar
01/09/22

Signature of the Inspecting Officer

Name: Sh. Rajesh Kumar

Design: ADO (SJ)

DO (South)

Sh. Rajesh Kumar
11/5/2022
(F6/DFS)
Sh. Rajesh Kumar
21/5/2022
Director
Sh. Rajesh Kumar
21/5/22
ADO (SJ)

As approved f.p. letter is
put up for your signature

Sh. Rajesh Kumar
01/09/22

Director
Sh. Rajesh Kumar
Sh. Rajesh Kumar