



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

C39
7/5
आज़ादी का
अमृत महोत्सव

No.F6/DFS/MS/EH/NDZ/2026/ 408

Dated: 24/04/2026

FIRE SAFETY CERTIFICATE

Certified that the Sapphire Foods India Ltd is running on Ground floor of the building which is comprised of Ground + 03 upper floors located at F-25 Preet Vihar, Delhi-110092 & was granted Fire Safety Certificate by this department vide letter no. F6/DFS/MS/EH/NDZ/2023/209 dated 04/07/2023. The Restaurant was re-inspected by officer concerned of this department on 07/04/2026 in the presence of Mr. Shankar (Manager) and found that the building/premises has deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of Delhi Fire Service Rules, 2010. The building/premises is fit for occupancy of Group D "Assembly Building" (Eating House /Restaurant at Ground floor only) with effect from....24/04/2026...and valid upto 31.03.2029 in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to conditions under Rule 38 of Delhi Fire service Rules, 2010 printed below.

Issued on24/04/2026.....at New Delhi by


(Dr. S.K. Tomar)
Chief Fire Officer
Delhi Fire Service
7/5

Reference: etl.mcdonline application no. 2026033104005.

Conditions for the validity of Fire Safety Certificate

1. This Fire Safety Certificate is valid for Restaurant at Ground floor only.
2. The means of escape shall be kept unobstructed/unlocked for unhindered evacuation in case of an emergency.
3. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
4. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
5. The trained fire fighting staff should be available round the clock.
6. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
7. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
8. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
9. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry".
10. Any change in the occupancy shall be intimated to this Deptt. and approval shall be obtained thereto before occupancy of the same.

INSPECTION REPORT				
1.	Name and address of the building:	M/s Sapphire Foods India Ltd located at Ground floor, F-25 Preet Vihar, Delhi-110092.		
2.	Building is comprised of	Ground + 03 upper floors		
3.	Type of occupancy	(Restaurant running at Ground floor only)		
4.	Type of case:	Group D - Assembly (Restaurant)		
5.	Details of previous FSC:	Renewal		
6.	Fire safety directives no.:	F6/DFS/MS/EH/NDZ/2023/209 dated 04.07.2023		
7.	Date of inspection:	NBC Part-IV		
8.	Name of the inspecting officer:	07.04.2026		
9.	Name and designation of the officer from the building side:	Rajesh Kumar Shukla, ADO (L.N) Mr. Shankar (Manager)		
10.	Year of construction:	1988		
11.	Reference letter no.:	etl.mcdonline application no. 2026033104005		
S.No	Minimum standard of Fire Prevention and Fire Safety U/R 33	Requirements as per Rule 35(6), DFS Rule 2010	Provide at site	Remarks MR/NMR
1	Access to Building:			
A	Road width	6.0 m	30 m	MR
B	Gate width	NA	NA	NA
C	Width of internal roads	NA	NA	NA
2	Number, Width, Type & Arrangement of Exits:			
A	No. of Staircase:	Restaurant at Ground floor only		
	a) Upper floor	NA	NA	NA
	b) Basements	NA	NA	NA
B	Width of the Staircase	Restaurant at Ground floor only		
	a) Upper floors	NA	NA	NA
	b) Basements	NA	NA	NA
C	Protection of Exits			
	a) Fire check door	NA	NA	NA
	b) Pressurization	NA	NA	NA
D	No. of continuous staircase to terrace	1 no.	2 nos.	MR
E	Width of the corridor	NA	NA	NA
F	Door size/exits	2.0 m	2.0 m x 2 nos. & 0.53 m from kitchen (on rear side)	MR
3	Compartmentation:			
A	Fire check doors	NA	NA	NA
B	Sealing of horizontal & vertical opening	NA	NA	NA
C	Fire rating of shaft doors	NA	NA	NA
D	Water curtain	NA	NA	NA
E	Fire dampers	NA	NA	NA
4	Smoke Management System:			
A	Basements	NA	NA	NA
B	Upper floors	NA	NA	NA
5	Fire Extinguishers:			
A	Total numbers	04 nos.	04 nos.	MR
B	Types	ABC +CO ₂	ABC +CO ₂	MR
C	ISI marking	ISI marked	ISI marked	MR
6	First Aid Hose Reel:			
A	Total no. at each floor	01 no.	01 no.	MR
B	Length of hose reel	30 m	30 m	MR
C	Nozzle diameter	5 mm	5 mm	MR

7	Automatic Fire Detection and Alarm System (ADAS):				
	A	Type of detectors	NA	Smoke	NA
	B	Location of main panel	NA	Provided	NA
	C	Location of repeater panel	NA	NA	NA
	D	Alternate power source	NA	Provided	NA
	E	Hooter's location	NA	Provided	NA
8	MOEFA:		Required	Provided	MR
9	Public Address System:		NA	NA	NA
10	Automatic Sprinkler System:				
	A	Basement	NA	NA	NA
	B	Upper floor	NA	NA	NA
	C	Sprinklers above false ceiling	NA	NA	NA
11	Internal Hydrants:				
	A	Size of down comer	100 mm	100 mm	MR
	B	No. of hydrants per floor	01 no.	01 no.	MR
	C	Hose box	01 no.	01 no.	MR
12	Yard Hydrants:				
	A	Total no. of hydrants	NA	NA	NA
	B	Hose box	NA	NA	NA
13	Pumping arrangements:				
	A	Ground Level			
		a) Discharge & head of main pump	NA	NA	NA
		b) Number of main pump	NA	NA	NA
		c) Discharge & head of jockey pump	NA	NA	NA
		d) Discharge & head of standby pump	NA	NA	NA
		e) Auto starting/ manual stopping	NA	NA	NA
	B	Terrace Level			
		a) Discharge of terrace pump	450 LPM	450 LPM	MR
		b) Head of terrace pump	40 m	40 m	MR
		c) Alternate power supply	Required	Provided	MR
		d) Auto starting of pump	Required	Provided	MR
14	Captive Water Storage for Fire Fighting:				
	A	Underground tank capacity	NA	NA	NA
	B	Draw off connection	NA	NA	NA
	C	Fire service inlet	NA	NA	NA
	E	Access to tank	NA	NA	NA
	D	Overhead tank capacity	10,000 ltrs	10,000 ltrs	MR
15	Exit Signage:		Required	Provided	MR
16	Provision of lift:				
	A	Pressurization of lift shaft	NA	NA	NA
	B	Pressurization of lift lobby	NA	NA	NA
	C	Communication in lift car	NA	NA	NA
	D	Fireman switch	NA	NA	NA
	E	Lift signage	NA	NA	NA
17	Standby Power Supply:		Required	Provided	MR
18	Refuge Area:				
	A	location	NA	NA	NA
	B	Total area	NA	NA	NA
19	Fire Control Room:				
	A	Fire detection system panel	NA	NA	NA
	B	Flow switch panel	NA	NA	NA
	C	P a system panel	NA	NA	NA
	D	Battery backup	NA	NA	NA
	E	Building floor plan	NA	NA	NA

2/19

M/s Sapphire Foods India Ltd located at Ground floor, F-25 Preet Vihar, Delhi-1100922.

20	Special Fire Protection for special risk if any		
A	Special Fire Protection system for Protection of Special Risk, if any:	NA	

LEGENDS:- Meeting Requirement (MR), Not Meeting Requirement (NMR), Not Applicable (NA), Not Provided (NP) Provide but Not Functional (PNF).

The fire protection systems provided in the building were tested, checked at random and found functional at the time of inspections.

In view of the deemed compliance of minimum standards of fire prevention and fire safety measures as required under the Rules, the FSC issued vide letter no. F6/DFS/MS/EH/NDZ/2023/209 dated 04.07.2023 is recommended to be renewed under Rule 37 of the Delhi Fire Service Rules 2010.

[Signature]
10/4/26

Signature of the Inspecting Officer

Name Rajesh Kumar Shukla

Designation ADO (L.N)

DO (East)

[Signature]
15/4/26

CFO (NDZ) *[Signature]*
17/4/26

Principal Director

CFO to *[Signature]*

CFO (NDZ)

[Signature]
13/04/26

ADO/LN

[Signature]
20/4/26

FI is put up as approved

[Signature]
22/4/26

CFO (NDZ)

[Signature]
23/4/26

MS

Updated
24/4/26

[Signature]