

C-13

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001**

No. F.6/DFS/MS/NDZ/school/2025/ 604

Dated: 31.07.2025

To

The Principal,  
Sarada Ukil School of Art,  
66/1, Janpath, New Delhi.

**Sub:** Application for issuance of fire safety certificate in respect of M/s Sarada Ukil School of Art, 66/1, Janpath, New Delhi -110001.

Sir,

This has reference to your letter no. nil dated 27.06.2025, on the subject cited above. In this regard, it is to inform you that the site was visited by officers concerned of this department on dated 16.07.2025 in presence of Mr. Shyam Bihari and observed that shortcomings issued earlier vide letter no. F6/DFS/MS/School/2023/26 dated 13.01.2023 (copy enclosed) have not been complied so far. However, installation work of firefighting is under progress.

In view of above, FSC can't be issued till the compliance of all the shortcomings issued vide aforesaid letter.

Encl: As above.

Yours faithfully,

  
(Virendra Singh)  
Chief Fire Officer  
Delhi Fire Service

**Copy to :**

1. The Director (Education), Govt. of NCT, Old Sectt. Delhi -54.

C-6

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001**

No. F6/DFS/MS/School/2023/ 26

Dated: 13 10/2023

To

Authorized Signatory,  
Sarada Ukil School of Art,  
(Governed & Finance by Govt. of NCT of Delhi),  
66/1, Janpath, New Delhi -110001.

Sub: Regarding issuance of FSC in r/o Sarada Ukil School of Art, 66/1, Janpath, New Delhi -110001.

Sir,

This has reference to your letter no. nil dated nil on the subject cited above. In this regard, it is to inform you that the site was visited by officer concerned of this department on 03.01.2023 in the presence of Smt. Bhawna Sharma and following shortcomings are observed.

1. Hose reel is not provided.
2. Overhead tank of 10,000 liter is not provided.
3. Fire Pump of 450 LPM capacity is not provided.

In view of above, fire safety certificate (FSC) cannot be considered at this stage. Therefore, it is requested to rectify the above shortcomings at the earliest for further consideration in the matter. Running school without valid Fire Safety Certificate is at the risk and liability of school management concerned authority may take action at their end.

Yours faithfully,

  
(Atul Garg)  
DIRECTOR  
Delhi Fire Service

Copy to:-

1. The Director (Education), Govt. of NCT, Old Sectt. Delhi - 54.