

C-17

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001

No. F6/DFS/MS/School/2025/ 700

Dated: 08/09/2025

To

The Head of School,
Sarada Ukil School of Art,
(Governed & Finance by Govt. of NCT of Delhi),
66/1, Janpath, New Delhi -110001.

Sub: Regarding issuance of FSC in r/o Sarada Ukil School of Art, 66/1, Janpath, New Delhi -110001.


Sir,

This has reference to your letter no.F1/SUSA/Fire safety /2025-25/22 dated 21.08.2025 on the subject cited above. In this regard, it is to inform you that the site was visited by officer concerned of this department on 28/08/2025 in the presence of Sh. Shyam, LDC and following shortcomings are observed.

1. Hose reel is provided but found nonfunctional.
2. Fire pump is provided but found nonfunctional due to not providing of electric supply to pump and pump panel is also not provided.

In view of above, fire safety certificate (FSC) cannot be issued at this stage. Therefore, it is requested to rectify the above shortcomings at the earliest under intimation to this department for further consideration in the matter.

Yours faithfully,


6/9/2025
(Virendra Singh)
Chief Fire Officer
Delhi Fire Service

Copy to:-

1. The Chief Secretary, NDMC , Palika Kendra, New Delhi.
2. The Director (Education), Govt. of NCT, Old Sectt. Delhi - 54.