

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110001

No. F6/DFS/MS/School/2022/SZ/1044

Dated: 21/08/2025

FIRE SAFETY CERTIFICATE

Certified that the **Saraswati Model School** at Street No.-5, East Sagarpur, New Delhi-110046, comprised of ground plus three upper floors owned/occupied by Saraswati Model School, was issued FSC by this department vide letter No. F.6/DFS/MS/School/2022/SZ/891 dated 11.08.2022. The School building was re-inspected by the officer concerned of this department on dated 30.07.2025 in the presence of Sh. Sanjay Jain (Principal), and found that the school building have deemed complied the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the **building/premises (ground plus three upper floors) is fit for occupancy class "Educational Building" w.e.f. 21/08/2025** for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule-38 of the Delhi Fire Service Rules, 2010 printed as below.

Issued on 21/08/2025 at New Delhi by.


 21/08/2025
 (Virendra Singh)
 Chief Fire Officer

Copy to: -

1. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054
2. The Principal, Saraswati Model School at Street No.-5, East Sagarpur, New Delhi- 46.

Conditions for the validity of fire safety certificate: -

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. The means of escape shall be kept unlocked and unobstructed for unhindered evacuation of occupants in case of emergency.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
4. The trained staff should be available round the clock.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in the Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

INSPECTION REPORT

1. Name & address of the building : Saraswati Model School, Street No.-5, East Sagarpur, New Delhi-46
2. Building comprised of : G+3 Upper floors
3. Type of Occupancy : Educational
4. Type of Case : Addition/alteration (Renewal)
5. Details of Previous NOC : F.6/DFS/MS/School/2022/SZ/891 dated 11.08.2022
6. Fire Safety directives letter No : N/A
7. Date of inspection : 04.08.2025
8. Name of Inspecting Officer : A.D.O. R.K. Yadav
9. Name and designation of officers
From the building side : Principal
10. Year of Construction : 1987 & 2003
11. Applicant's letter No. : SMS/2025/146 dated 21.07.2025

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Requirement NBC	Provided at site	Remarks MR/NMR
1.	Access to building			
	<ul style="list-style-type: none"> Road width Gate width Width of internal road 	Accessible 06 mtrs 4.5 mtrs N/A	05 mtrs Directly accessible from road N/A	MR, old case M/R N/A
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			MR
	<ul style="list-style-type: none"> Upper Floors Basements 	02 no. N/A	02 no.'s N/A	N/A N/A
	b. Width of staircases			MR,
	<ul style="list-style-type: none"> Upper Floor Basements 	1.5 m each N/A	1.50 & 1.02m N/A	N/A N/A
	c. Protection of exits			N/A
	<ul style="list-style-type: none"> Fire check door Pressurization 	N/A N/A	N/A N/A	N/A N/A
	d. No. of continuous staircases to terrace	N/A	N/A	N/A
	e. Width of Corridor	N/A	N/A	N/A
	f. Door Size	1.0 m	0.89 to 1.03 m (Single door)	MR old existing bldg.
3.	Compartmentation			
	<ul style="list-style-type: none"> Fire check door Sealing of electrical shafts Fire Rating of shaft door Water Curtain Fire Dampers 	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A
4.	Smoke Management System			
	<ul style="list-style-type: none"> Basements Upper floors 	N/A Required	N/A Natural Ventilation provided	N/A MR
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers Types ISI marking 	04 No's ABC/CO ₂ type ISI marked	Provided Provided ISI marked	MR MR MR
6.	First-Aid Hose Reels			
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	01 Nos. 30 m 05 mm	Provided Provided Provided	MR MR MR

7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
8.	MOEFA	N/A	N/A	N/A
9.	Public Address System	N/A	N/A	N/A
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basement Ground Floor Sprinkler above false ceiling 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
11.	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 	N/A	Provided	N/A
		N/A	Provided	N/A
		N/A	Provided	N/A
12.	Yard Hydrants			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	N/A	N/A	N/A
		N/A	N/A	N/A
13.	Pumping Arrangements			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/Manual Stopping 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
	<ul style="list-style-type: none"> Pump House Access Terrace level <ul style="list-style-type: none"> Discharge of pump Head of the pump Power Supply Auto Starting of pump 	N/A	N/A	N/A
		450 LPM	Provided	MR
		40 M	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
14.	Captive Water Storage for fire fighting			
	<ul style="list-style-type: none"> Underground tank capacity <ul style="list-style-type: none"> Draw-off connection Fire service inlet Access to tank Overhead Tank capacity 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		10,000 Ltrs	Provided	MR
		Required	Provided	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts. (No Lift)			
	<ul style="list-style-type: none"> Pressurization of Lift Shaft Pressurization of Lift lobby Communication In lift Car Fireman's Grounding Switch Lift Signage 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A

N/22

17.	Standby power supply	N/A	N/A	N/A
18.	Refuge Area.			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19.	Fire Control Room			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the FSC issued vide letter No. F.6/DFS/MS/School/2022/SZ/891 dated 11.08.2022 is recommended to be renewed under rule 37, of the Delhi Fire Service Rules, 2010.

R.K. Yadav
 Signature of Inspecting Officer
 Name: - R.K. Yadav
 Designation: - ADO (JKP)

~~DO (South West)~~

[Signature]
 7/8/25

CFO

[Signature]
 16/8/2025

~~Principal Director~~

Cfo to Pm.

CFO
 2/

[Signature]
 13/08/25

~~ADO (JKP)~~

[Signature]
 20/8/2025