

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F6/DFS/MS/School/NDZ/2025/129

Dated: 03/03/2025

To

The Principal,
Sardar Patel Pub. Sr. Sec. School,
Karawal Nagar, Delhi-110094.

Sub: Regarding Fire Safety Certificate in r/o Sardar Patel Pub. Sr. Sec. School, Karawal Nagar, Delhi-110094.

Sir,

This has reference to your letter No. SPPSSS/798/2025 dated 29/01/2025 on the subject cited above. In this regard, it is to inform you that the premises was inspected by the officer concerned of this department on 24/02/2025 in the presence of Mr. Satvir to ascertain the availability and operability of the fire prevention and fire safety measures and observed that at present building comprised of **Ground Floor, 1st Floor, 2nd Floor & 3rd Floor**. However previous Fire Safety Certificate was issued to this premises vide letter No. F6/DFS/MS/School/2022/NDZ/64 dated 24/01/2022 for **Ground, 1st Floor & 2nd Floor only**. Following shortcomings were observed during the inspection:-

1. One more staircase of width 1.50mtr is required to be provided up to 3rd floor or width of the one of the existing staircases (1.05mtr & 0.95mtr) may be widened upto 1.50mtr terrace.
2. Hose reel hose provided up to 3rd floor but found non-functional.
3. Fire Pump of capacity 450LPM provided on terrace but found non-functional.
4. Overhead tank capacity of 8,000 ltr is provided against requirement of 10,000ltr.
5. Exit signage found removed.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected under sub rule (3) of Rule 37 of DFS Rules-2010. The occupancy of the building/premises in absence of requisite fire safety arrangement shall be at the risk and liability of the management. The Statutory Authority may take suitable necessary action as deemed fit.

In this regard as stipulated in sub Rule 37 of DFS Rules, 2010 you may apply with a fresh application for renewal of fire safety certificate under sub-rule (2) on Form "J" with compliance of above shortcomings. The web links for DFS Act-2007 / Rules 2010 & Form "J" are as under :
http://www.delhi.gov.in/wps/wcm/connect/doit_fire/Fire/Home_Fire+Safety+Acts+and+Rules/
http://www.delhi.gov.in/wps/wcm/connect/doit_fire/Fire/Home/Forms

Yours faithfully

(ATUL KARG)
DIRECTOR

DELHI FIRE SERVICE

Copy to:-

The Dy. Director of Education, B-Block, Yamuna Vihar, Delhi-110053.