

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI- 110001

No. F.6/DFS/MS/School/2025/SZ/ 372

Dated: 13/05/2025

To

The Principal,
Sardar Patel Vidya Niketan,
Mandi Village, New Delhi 110047

Sub: Regarding issuance of FSC in r/o M/s Sardar Patel Vidya Niketan, located at Mandi Village, New Delhi 110047

Sir,

This has reference to your letter no nil dated 19/04/2025 received through outdoor diary no 766 dated 21/04/2025 on the subject cited above. In this connection, this is to inform you that the above mentioned premise was visited by the officer concerned of this department on 06.05.2025 in the presence of Mrs. Sangeeta Sharma (HOS) to verify the fire safety measures installed in the building. Accordingly fire safety arrangement were tested / checked and found following observation.

1. There is addition of First Floor in 4th block, only one staircase is provided having width of 1.50 mtr against the requirement of two staircase having width of 1.50 mtr each.
2. Service staircase to access of terrace tank is needed to be provided for verification of terrace tank & terrace pumps.
3. Hose reel hose not working.
4. Fire fighting pumps are not working.
5. Exit signage found removed at some places.

The same observations has already been issued and communicated earlier by this department vide letter of even no 150 dated 12/03/2025.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier.

Yours faithfully,

(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE

Copy to:-

1. The Directorate of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi 110054.