

C-185

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No. F6/DFS/MS/WZ/Hospital/2025/ 74  
To,

Dated: 21/02/2025

Mr. Satish Chandra Yadav (Sr. Manager-Administration, Authorized Signatory),  
M/s Saroj Super Specialty Hospital,  
Sector-14, Madhuban Chowk, Rohini,  
Delhi-110085,

**Sub:** Renewal of FSC in r/o M/s Saroj Super Specialty Hospital, Plot No.2, PSP, Sector-14, Madhuban Chowk, Rohini, Delhi-110085.

Sir,

Kindly reference to letter received in this department through outdoor diary no. 3273 dated 30.06.2023 on the subject cited above. The premise was inspected by the concern nominated authority of this department on 13.02.2025, in presence of **Mr. Rajesh Bhardwaj, Chief Engineer** to ascertain the availability and operability of the fire prevention and fire safety measures. Your request for renewal of FSC is rejected under sub rule (3) of Rule 37 of DFS Rules-2010 due to following reason:

1. Pressurization in one staircase found removed.
2. FCD found removed in one of the staircase.
3. Some FCD auto closer found removed & stopper found installed in some FCD.
4. Fire control room found shifted from ground to basement.

In this regard as stipulated in sub Rule 37 of DFS Rules, 2010 you may apply with a fresh application for renewal of fire safety certificate under sub-rule (2) on Form "J" with compliance of above shortcomings. The web links for DFS Act-2007/ Rules 2010 & Form "J" are as under:  
[http://www.delhi.gov.in/wps/wcm/connect/doit\\_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/http://www.delhi.gov.in/wps/wcm/connect/doit\\_fire/FIRE/Home/Forms](http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Forms)

Yours faithfully

(Atul Garg)  
DIRECTOR  
Ph; 011-23414000

me  
Sgt