



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

c/o  
OFFICE

No: F.6/DFS/MS/School/2025/WZ/ 310

Dated: 01/05/2025

To,  
The Manager,  
The Sarthi School,  
Kh. No. 31/19, Village Harewali,  
Delhi-110039.

Sub: - Regarding issuance of Fire Safety Certificate in r/o The Sarthi School located at  
Kh. No. 31/19, Village Harewali, Delhi- 110039.

Sir,

This has reference to your application no. Nil received through outdoor diary no. 14348 dated 11.03.2025 on the subject cited above. In this connection, it is to inform you that the above said school building was inspected by officer concerned of this department on 15.04.2025 to ascertain the availability and operability of the fire prevention and fire safety measure, Sh. Lalit Kumar Gupta was present at the time of inspection. During the course of visit it was observed that building is comprised of Two Blocks (Block 1- Ground plus first floor & Block 2- Ground floor only). Block-1 is used as office and residential purpose and school is running in Block-2.

Your request for issuance of FSC is rejected due to the following shortcoming:-

1. Gate width found 3 m against the required width of 4.5 m.

You are advised to rectify the above-mentioned shortcomings under intimation to this department.

Yours Faithfully

(Atul Garg)  
Director

Ph. 011-23414000

Copy to:-

1. Director of Education, Govt. Of NCT of Delhi, Old Secretariat, New Delhi.