

C-95

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001

No.F.6/DFS/MS/GH/2025/ 316

Dated:-28/07/2025

To,

The Manager,
Sarvana Bhawan (A unit of Thanigai Murugan Restaurant P. Ltd),
P-13/90, Connaught Place, New Delhi.

Sub: Regarding grant of FSC in r/o Sarvana Bhawan (A unit of Thanigai Murugan Restaurant P. Ltd) P-13/90, Connaught Place, New Delhi.

Sir,

This has reference to ID No 2025062610652 dated 26/06/25, on the subject cited above, it is to inform you that the site was inspected by the officer concerned of this department on 14/07/25 in the presence of Swami Singh, Manager and the following shortcomings were observed:-

1. Hose reel, MOEFA & Pumps found nonfunctional & also not in auto start provision.
2. Further, number of specific floor on which the establishment is situated is wrongly mentioned in application form and building plan of mezzanine floor is also not uploaded on the portal.

In view of above, the case is rejected and Fire Safety Certificate (FSC) cannot be issued. Therefore, you are requested to rectify the above shortcomings and re-submit for further consideration in the matter.

Yours faithfully


(Virendra Singh)
Chief Fire Officer
Delhi Fire Service

Copy to:-

The Addl. Commissioner of Police (Lic.), Licensing Unit, Defense Colony Police Station,
New Delhi.