

255

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS, DELHI FIRE SERVICE, NEW DELHI - 110001

No. F6/DFS/MS/EH/NDZ/2026/ 430

Dated: 30/04/2026

FIRE SAFETY CERTIFICATE

Certified that the **M/s Sarvana Bhawan Restaurant**, located at **50, Janpath, New Delhi - 110001** comprised of **Ground, Mezzanine and 02 Upper Floors** but Restaurant running at **Ground and Mezzanine Floor only** was issued FSC vide letter No. F6/DFS/MS/EH/2024/03 dated 02.01.2024. Now, the premises was re-inspected by the officer concerned of this department on **17/04/2026** in the presence of **Sh. Suresh, Manager** and found that the said restaurant premises has complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class - **Assembly (Group D) for Restaurant at Ground and Mezzanine Floor only** with effect from 30/04/2026 for period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules 2010, printed below.

Issued 30/04/2026 at New Delhi by.


(Dr. S. K. Tomar)
Chief Fire Officer
Delhi Fire Service
O/c BX

Copy to: -

1. The Chairman, NDMC, Palika Kendra, New Delhi: 2026041104818 dated 11/04/2026.
2. The Commissioner, MCD, Civic Centre, New Delhi.: Online ID – 2026041104818 dated 11/04/2026.
3. The Manager, M/s Sarvana Bhawan Restaurant, 50, Janpath, New Delhi - 110001.

Conditions for the validity of Fire Safety Certificate

1. **This FSC is valid for Restaurant at Ground and Mezzanine Floor only.**
2. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
3. Any loss of life or property due to nonfunctional fire safety measures shall be at the responsibility of the management.
4. The trained firefighting staff should be available round the clock.
5. Any deviation w.r.t. construction, electric installation, set bac area etc. shall be verified by the concerned building sanctioning authority.
6. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
8. The means of escape shall be kept unobstructed / unlocked for unhindered evacuation in case of an emergency.
9. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six months prior to its expiry.
10. Any flammable material for interior decoration is prohibited.

INSPECTION REPORT

1.	Name & address of the building	M/s Sarvana Bhawan Restaurant, 50, Janpath, New Delhi - 110001.		
2.	Type of occupancy	Assembly Occupancy - Eating House (Restaurant)		
3.	Building is Comprised of	Ground, Mezzanine and 02 Upper Floors Only But Restaurant running at Ground and Mezzanine Floor only		
4.	Type of case	Renewal		
5.	Details of previous FSC No.: -	F6/DFS/MS/EH/2024/03 dated 02.01.2024		
6.	Fire safety directives No.-	N/A		
7.	Date of inspection: -	17/04/2026		
8.	Name of the inspecting officer: -	Sh. Bhupender Prakash, ADO (CC)		
9.	Name & designation of officer From the building side: -	Sh. Suresh, Manager		
10.	Year of construction: -	1947		
11.	Applicant's letter No: -	MCD Online ID 2026041104818 dated 11/04/2026		
S. No.	Minimum Standards on fire Prevention and fire safety U/R	Requirement/ Existing fire safety arrangements	Provided at site	Remarks MR/NMR
1.	Access to Building			
	• Road width	9.00 mtr.	18.00 mtr.	MR*
	• Gate width	N/A	N/A	N/A
	• Width of internal road	N/A	N/A	N/A
2.	Number, Width Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper floors (Mezz. Floor)	02 nos.	02 nos.	MR
	• Basements	N/A	N/A	N/A
	b. Width of staircase			
	• Upper floors (Mezz. Floor)	1.50 mtr.	1.54 mtr. & 1.47 mtr.	MR
	• Basements	N/A	N/A	N/A
	c. Protection of exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	d. No. of continuous staircase to terrace	01 no.	01 no.	MR
	e. Width of corridor	N/A	N/A	N/A
	f. Door size	2.00 mtr.	2.00 mtr.	MR
3.	Compartmentation			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire rating of shaft door	N/A	N/A	N/A
	• Water curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4.	Smoke Management System			
	• Basements	N/A	N/A	N/A
	• Upper floors	Required	Provided Exhaust Fan	MR
5.	Fire Extinguishers			
	• Total numbers	10 nos.	10 nos.	MR
	• Types	ABC/CO ₂	ABC/CO ₂	MR
	• ISI marking	Required	Provided	MR
6.	First-Aid Hose Reel			
	• Total number of each floor	02 nos.	02 nos.	MR
	• Length of hose reel hose	30 mtr.	30 mtr.	MR
	• Nozzle diameter	05 mm	05 mm	MR
7.	Automatic Fire Detection & Alarming System.			
	• Type of detectors	Required	Provided	MR
	• Location of main panel	Ground Floor	Provided	MR
	• Location of repeater panel	N/A	N/A	N/A

	• Alternate source of power	Required	Provided		MR
	• Hooter's Location	Ground Floor	Provided		MR
8.	MOEFA				
9.	Public Address System	Required	Provided		MR
10.	Automatic Sprinkler System	N/A	N/A		N/A
	• Basement	N/A	N/A		N/A
	• Upper Floors	Required	Provided		MR
	• Sprinkler above false ceiling	N/A	N/A		N/A
11.	Internal Hydrants				
	• Size of riser/down-comer	100 mm	100 mm		MR
	• Number of hydrants per floor	01 no.	01 no.		MR
	• Hose box per floor	01 no.	01 no.		MR
12.	Yard Hydrants				
	• Total number of hydrants	N/A	N/A		N/A
	• Hose box	N/A	N/A		N/A
13.	Pumping Arrangement				
	Ground level				
	• Discharge of main pump	N/A	N/A		N/A
	• Head of main pump	N/A	N/A		N/A
	• Number of main pumps	N/A	N/A		N/A
	• Jockey pump out put	N/A	N/A		N/A
	• Jockey pump head	N/A	N/A		N/A
	• Stand by pump output	N/A	N/A		N/A
	• Stand by pump head	N/A	N/A		N/A
	• Auto starting/Manual stopping	N/A	N/A		N/A
	Terrace level				
	• Discharge of pump	450 LPM	450 & 180 LPM		MR
	• Head of pump	40 mtr.	40 mtr.		MR
	• Power supply	Required	Provided		MR
	• Auto starting of pump	Required	Provided		MR
14.	Captive Water Storage for Fire Fighting				
	• Underground tank capacity	N/A	N/A		N/A
	• Draw-off connection	N/A	N/A		N/A
	• Fire service inlet	Required	Provided		MR
	• Access to tank	Required	Provided		MR
	• Overhead tank capacity	10,000 Ltr.	10,000 Ltr.		MR
15.	Exit Signage.	Required	Provided		MR
16.	Provision of Lifts.				
	• Pressurization of lift shaft	N/A	N/A		N/A
	• Pressurization of lift lobby	N/A	N/A		N/A
	• Communication in lift car	N/A	N/A		N/A
	• Fireman's switch	N/A	N/A		N/A
	• Lift signage	N/A	N/A		N/A
17.	Stand by Power Supply	Required	Provided		MR
18.	Refuge Area				
	• Total area	N/A	N/A		N/A
	• Location	N/A	N/A		N/A
19.	Fire Control Room				
	• Detector system panel	N/A	N/A		N/A
	• Flow switch panel	N/A	N/A		N/A
	• PA system panel	N/A	N/A		N/A
	• Battery backup	N/A	N/A		N/A
	• Building floor plan	N/A	N/A		N/A
20.	Special Fire Protection System for Protection of special Risk, if any:				N/A

*PNF – Provided but Non-Functional, *MR – Meeting Requirement, *NMR – Not Meeting Requirement

N/18

M/s Sarvana Bhawan Restaurant, 50, Janpath, New Delhi - 110001

The fire protection system provided in the building were randomly checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the Rules, if approved, we may renew the FSC issued vide letter No. F6/DFS/MS/EH/2024/03 dated 02.01.2024 to the Restaurant. The last date for deemed approval is 10/05/2026.

Accordingly, DFA is prepared and put up for perusal and signature please.

Bhupender Prakash
21/4/2026
Bhupender Prakash
ADO (CC)

DO (CD)

[Signature]
23/04/26

CFO (NDZ)

[Signature]
23/4/26

Principal Director

CFO to Secy.

[Signature]
27/04/26

CFO (NDZ)

[Signature]
27/4/26

ADP/CC

As approved F.T. letter is put up for signature please

CFO (NDZ)

[Signature]
30/4/26

Bhupender Prakash
28/4/2026

ms

[Signature]
30/4/26
[Signature]