e-38

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001 No F 6 / DFS / MS / 2025/ School/WZ/ 77.3 Dated:

12/06/2025

FIRE SAFETY CERTIFICATE

Issued on ... 12 06 2 25 at New Delhi, by

(Virendra Singh) Chief Fire Officer Delhi Fire Service

ar 2

Copy to: -

- 1. The Director, Education, Government of NCT of Delhi. Old Sect. Delhi-110054.
- 2. The Principal, Sarvodaya Bal Vidyalaya (ID- 1413323) located at Bakhtawarpur, Delhi-110036. Conditions for the validity of Fire Safety Certificate:
 - 1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
 - 2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
 - 3. The trained fire fighting staff should be available round the clock.
 - 4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
 - 5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
 - 6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
 - 7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in

INSPECTION REPORT 1. Name & address of the building: Sarvodaya Bal Vidyalaya (ID-1413323) located at B- Block, Sawda

(Ghevra) Colony, Delhi- 110081.

2. Type of Occupancy : Educational 3. Building Comprised of

Ground plus Three Upper Floors. 4. Type of Case Renewal

5. Details of Previous NOC : F6/DFS/MS/School/WZ/2022/759 Dated- 15/07/2022 6. Fire Safety directives letter No : NBC Part IV

7. Date of inspection 04/06/2025 8. Name of Inspecting Officer

: R.K.Sinha, ADO (BW) 9. Name and designation of officers

OC

From the building side : Sh. Manoj Kumar (Vice-Principal)

10. Year of Construction : 2022

1	1. Applicant's letter No.	Z022 F Mail ID dated 17/04/20	206			
	Minimum Standards on fire	E Mail ID dated 17/04/20 NBC/Inspection report		Domento		
lo.	prevention and fire safety U/R 33	dated 05/07/2022	r rovided at site	Remarks MR/NMR		
	Access to building	unica 05/01/2022		MICHAIN		
	 Road width 	6 m	Provided	MR		
	 Gate width 	4.5 m	Provided	MR		
	 Width of internal road 	NA	NA	NA		
2.	Number, Width, Type & Arrangement of Exits					
	a. Number of staircases					
	Upper Floors	02	02	MR		
	Basements	NA	NA	NA		
	b. Width of staircases					
	Upper Floor	1.50 m each	Provided	MR		
	Basements	NA	NA	NA		
	c. Protection of exits	3.9000300				
	Fire check door	NA	NA	NA		
	Pressurization	NA	NA	NA		
	d. No. of continuous staircases to terrace	02	Provided	MR		
	500406 Ti	1.50 m	Provided	MR		
	e. Width of Corridor	NA NA	NA	NA		
	f. Door Size	0.00003866				
3.	Compartmentation		NTA I	NA		
	Fire check door	NA	NA			
	Sealing of electrical shafts	NA	NA	NA		
	Fire Rating of shaft door	NA	NA	NA		
	Water Curtain	NA	NA	NA NA		
	Fire Dampers	NA	NA	NA		
4.	Smoke Management System					
	Basements	NA	NA	NA		
	Upper floors	Required	Naturally Ventilated	MR		
5.	Fire Extinguishers					
- A	Total numbers	20 Nos.	40 Nos.	MR		
	Types	ABC/ Co2 Type	Provided	MR		
	IS marking	Required	Provided	MR		
6.	First-Aid Hose Reels	1 00 1	nid.d	MR		
	Total numbers on each floor	02	Provided Provided	MR		
	Length of hose reel hose	30 m				
	Nozzle diameter	5 mm	Provided	MR		
7.	Automatic fire detection and alarming system					
	Type of detectors	NA	NA	NA		
	Location of Main Panel	NA	NA	NA		
	Location of Repeater Panel	NA	NA	NA		
	Alternate source of power	NA	NA	NA		
	Hooters' Location	NA NA	NA	NA		
_		9/				

			Carrie Town	
		1-19	The Late	
8.	MOEFA	NA NA	NA	NA NA
9.	Public Address System	NA	NA	NA NA
10.	Automatic Sprinkler System		NA NA	l NA
	Basement	NA NA	NA NA	NA
	Ground Floor	NA NA	NA	NA
	Sprinkler above false ceiling			-
11.	Size of riser/down-comer	NA NA	NA	NA
	Number of hydrants per floor		NA	NA
	Hose Box	NA	NA	NA
12.	Yard Hydrants			774
F	Total number of hydrants	NA	NA NA	NA NA
13.	Hose Box Pumping Arrangements	NA	NA	- NA
10.	Ground Level	1		7
	➤ Discharge of main Pump	NA	NA	NA
	➤ Head of Main pump	NA	NA	NA
-		NA	NA	NA
	 Number of main pumps Jockey Pump out put 	NA NA	NA NA	NA NA
	> Jockey pump head	NA NA	NA NA	NA NA
	Standby Pump out put	NA NA	NA NA	NA NA
	Standby Pump Head	NA	NA	NA NA
	Auto Starting/Manual Stopping	NA	NA	, NA
	> Pump House Access	NA NA	NA	NA
	Terrace level			(r)
	Discharge of pump	450 lpm	2 × 450 lpm	MR
	➤ Head of the pump	40 m	Provided	MR
-	➤ Power Supply ➤ Auto Starting of pump	Required Required	Provided	MR
. Ca	ptive Water Storage for fire fighting		Provided	MR
	Underground tank capacity	NA NA	NA	NA
	> Draw-off connection	NA NA	NA NA	NA NA
	> Fire service inlet	NA NA	NA NA	
	> Access to tank	NA NA	NA NA	NA NA
	Overhead Tank capacity	10,000 ltrs	Provided	MR
Exi	t Signage.	Required	Provided	MR
			-0513818	
Pro	vision of Lifts.			47
	Pressurization of Lift Shaft	NA	NA	NA
	Pressurization of Lift lobby	NA NA	NA NA	NA NA
	Communication In lift Car	NA NA	NA NA	NA NA
8		NA NA	NA NA	NA NA
		NA NA	NA NA	
	Lift Signage dby power supply	Tet 1/15 (2)	7,100,000	NA
Stall	and hower subbis	NA	NA	NA
Refu	ge Area.	1	<u> </u>	
A	7 5 Tal. 7 17 Va	NA	NA	NA
>		NA	NA	NA.
Fire (Control Room			10.00
•	Detector System Panel	NA	NA	NA
	Flow Switch Panel	NA	NA NA	NA NA
•	PA System Panel	NA	NA	NA NA
2000	Battery backup	NA	NA	NA NA
•				

Building Floor Plans	NA	NIA	
Special Fire Protection System for	MA	NA	NA
Protection of special Risks, if any:	NA	NA	NA

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

Keeping in view of deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules, it is recommended to renew the Fire Safety Certificate issued vide letter no. F6/DFS/MS/School/WZ/2022/759 dated 15/07/2022 under rule 37 of the Delhi Fire Service Rules, 2010.

Signature of Inspecting Officer Name: Rajeev Kumar Sinha Designation: ADO/B.W.

05/06/2025 05/06/2025 05/06/2025 05/06/2025

Dy CFO (405)

ADO (Bawana)

fr. It lotte

9/6/4

Cfo (0/1) f aller gors

M S cell