

c/32

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE**  
**NEW DELHI- 110001**

No. F6/DFS/MS/School/2025/SZ/ 390

Dated: 14/05/2025

To,  
The Principal,  
Sarvodaya Bal Vidyalaya,  
Subhash Nagar, New Delhi-110027.

**Sub: - Regarding renewal of "Fire Safety Certificate" from fire safety point of view in r/o Sarvodaya Bal Vidyalaya at Subhash Nagar, New Delhi-110027.**

Sir,

Please refer to your letter No. SBV/SN/2025/455, dated 28.02.2025, on the subject cited above. In this connection this is to inform you that officer concerned of this department inspected the school building on dated 05.05.2025 to verify the fire safety arrangements in accordance with the rules. At the time of inspection Sh. Manoj Kumar (HOS) was present and it was observed that the school having three blocks, namely A, B & C block, A block comprised of ground floor, B block comprised of ground plus one upper floor & C block is comprised of ground plus three upper floors, and have following shortcomings: -

1. Hose reels/hydrant found provided but not functional in C- block.
2. Terrace fire pump of 450 LPM × 2 found provided but not functional in C- block.
3. Exit signage's are found removed at some places.

In view of the above, renewal of 'Fire Safety Certificate' cannot be granted at this stage. You are requested to rectify the above-mentioned shortcomings under intimation to this department for taking further necessary action in this matter and running school in absence of requisite fire safety arrangements shall be at the risk & liability of the school management.

Yours faithfully

(Atul Garg)  
Director  
Delhi Fire Service

Copy to: -

1. Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054.