



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F6/DFS/MS/2025/WZ/School/1257

Dated: 17/10/2025

FIRE SAFETY CERTIFICATE

Certified that the Sarvodaya Bal Vidyalaya School Located at, BT Block, Shalimar Bagh, New Delhi-110088. (School ID-1309005), comprised of 02 blocks, (ground + 01 upper floor & ground + 03 upper floors) has already been issued FSC by this department vide letter No. F.6/DFS/MS/School/WZ/2021/624 dated 19.08.2021 for Gr.+01 upper floor & F6/DFS/MS/School/WZ/2023/37 dated-17.01.2023 for Gr.+03 upper floors. The premises was re-inspected by the officer concerned of this department on 06.10.2025 in the presence of Mrs. Sunita Ahlawat (In-charge) and found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the premises fit for occupancy class "Educational" Group-B for 02 blocks, ground + 01 upper floor & ground + 03 upper floors only with effect from 17/10/2025 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subjected to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 17/10/2025 at New Delhi by


(S. K. Dua)

Dy. Chief Fire Officer (WZ)
Delhi Fire Service

Copy to: -

1. The Director, Education, Government of N.C.T of Delhi. Old Sect. Delhi - 54.
2. The Principal, Sarvodaya Bal Vidyalaya School Located at, BT Block, Shalimar Bagh, New Delhi-110088. (School ID-1309005).

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on
8. All the means of escape shall be kept free of any obstruction all the time to evacuate the occupant, in a safe manner, in the event of emergency.

http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/ http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Forms

INSPECTION REPORT

INSPECTION REPORT				
1. Name & address of the building		Sarvodaya Bal Vidyalaya School Located at, BT Block, Shalimar Bagh, New Delhi-110088. (School-ID-1309005)		
2. Type of Occupancy		Educational		
3. Type of Case		Renewal (02 Blocks, Ground + 01 upper floors & Ground Floor + 03 Upper Floor)		
4. Details of Previous NOC		F.6/DFS/MS/School/WZ/2021/624 dated 19.08.2021 for-Gr.+1 F6/DFS/MS/School/WZ/2023/37 Dated-17.01.2023 for-Gr.+3		
5. Fire Safety directives letter No		NBC Part-IV & Director of Education Cir. Dated 01.03.2011		
6. Date of inspection		06.10.2025		
7. Name of Inspecting Officer		Sh. Ajay Kumar Sharma (Wazirpur)		
8. Name and designation of officers From the building side		Mrs. Sunita Ahlawat (In-Charge)		
9. Year of Construction		2021-2022		
10. Applicant's letter No.		Online e-mail dated 09.09.2025		
S. No	Minimum Standards on fire prevention and fire safety U/R 33	NBC Part-IV & DOE Cir.	Provided at site	Remarks MR/NMR
1.	Access to building			MR
	• Road width	06 m	Provided	MR
	• Gate width	4.5 m	Provided	MR
	• Width of internal road	NA	NA	NA
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			MR
	• Upper Floors	G+03=2nos. G+01=06nos.	02nos. 06nos.	MR
	• Basements	NA	NA	NA
	b. Width of staircases			MR
	• Upper Floor	G+1=1.5m each G+3=1.5m each	Provided Provided	MR
	• Basements	NA	NA	NA
	c. Protection of exits			NA
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	Gr+01-02nos.	Provided	MR
	e. Width of Corridor	G+1=1.5 m G+3=1.5m	Provided Provided	MR
	f. Door Size	G+3=2 x 1.20 m G+1=1m	Provided 1m including door frame	MR
3.	Compartmentation			NA
	a) Fire check door	NA	NA	NA
	b) Sealing of electrical shafts	NA	NA	NA
	c) Fire Rating of shaft door	NA	NA	NA
	d) Water Curtain	NA	NA	NA
	e) Fire Dampers	NA	NA	NA
4.	Smoke Management System			
	a) Basements	NA	NA	NA
	b) Upper floors	NA	NA	NA
5.	Fire Extinguishers			
	a) Total numbers	G+3=18 nos. G+1=17nos.	Provided Provided	MR MR

	b) Types	ABC/CO2	Provided	MR
	c) IS marking	ISI marked	Provided	MR
6.	First-Aid Hose Reels			
	a) Total numbers on each floor	G+3=02nos.	Provided	MR
	b) Length of hose reel hose	30 m	Provided	MR
	c) Nozzle diameter	5 m	Provided	MR
7.	Automatic fire detection and alarming system			
	a) Type of detectors	NA	NA	NA
	b) Location of Main Panel	NA	NA	NA
	c) Location of Repeater Panel	NA	NA	NA
	d) Alternate source of power	NA	NA	NA
	e) Hooters' Location	NA	NA	NA
8.	MOEFA	NA	NA	NA
9.	Public Address System	NA	NA	NA
10.	Automatic Sprinkler System			
	a) Basement	NA	NA	NA
	b) Ground & Upper Floors	NA	NA	NA
	c) Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants			
	a) Size of riser/down-comer	NR	G+3=Provided	NR
	b) Number of hydrants per floor	NR	G+3=Provided	NR
	c) Hose Box	NR	G+3=Provided	NR
12.	Yard Hydrants			
	a) Total number of hydrants	NA	NA	NA
	b) Hose Box	NA	NA	NA
13.	Pumping Arrangements			
	• Ground Level	NA	NA	NA
	➤ Discharge of main Pump	NA	NA	NA
	➤ Head of Main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey Pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Starting/Manual Stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	Terrace level			
	➤ Discharge of pump	G+3=450 LPM	Provided	MR
	➤ Head of the pump	40 m	Provided	MR
	➤ Power Supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR
14.	Captive Water Storage for fire fighting			
	• Underground tank capacity	NA	NA	NA
	➤ Draw-off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	G+3=10,000 Ltrs	Provided	MR
15.	Exit Signage.	G+3= Required	Provided	MR
		G+1=Required	Provided	MR

N/20

Provision of Lifts.			
a)	Pressurization of Lift Shaft	NA	NA
b)	Pressurization of Lift lobby	NA	NA
c)	Communication In lift Car	NA	NA
d)	Fireman's Grounding Switch	NA	NA
e)	Lift Signage	NA	NA
17.	Standby power supply	NA	NA
18.	Refuge Area.		
a)	Total Area	NA	NA
b)	Location	NA	NA
19.	Fire Control Room		
a)	Detector System Panel	NA	NA
b)	Flow Switch Panel	NA	NA
c)	PA System Panel	NA	NA
d)	Battery backup	NA	NA
e)	Building Floor Plans	NA	NA
20.	Special Fire Protection System for Protection of special Risks, if any:	NA	NA

Accordingly, the fire protection systems provided in the building were tested/ checked randomly and found in working condition at the time of inspection.

In view of the deemed compliance of the minimum standards of the fire prevention and fire safety measures as required under the rules the FSC issued vide letter no. F.6/DFS/MS/School/WZ/2021/624 dated 19.08.2021 for-Gr.+1 & F6/DFS/MS/School/WZ/2023/37 Dated-17.01.2023 for-Gr.+3 is recommended for renewal of FSC under rule 37 of the Delhi Fire Service rules 2010.

Signature of the Inspecting Officer
Name Ajay Kumar Sharma
Designation ADO(Wazirpur)

DO(W)

DY C/O WZ

Principal Director

Rings
10/10/25

DY. C/O to Secy.

DY. C/O (WZ)

14/10/25

ADD(WP)

FT letter to put up for (LW)
Personal and Signature please.

Rings
14/10