



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F.6/DFS/MS/School/2025/SZ/83

Dated: 31 / 01 / 2025

To

Dr. Hitender Yadav (HOS),
Sarvodaya Bal Vidyalaya,
(Earlier known as GBSSS No. 4),
Sarojini Nagar, New Delhi-110023

Sub: Request for renewal of Fire Safety Certificate in r/o Sarvodaya Bal Vidyalaya, Sarojini Nagar, New Delhi-110023 (School ID: 1719006)

Sir,

This has a reference to your email received from Id. gbsssno4sarojininagar@gmail.com dated 02/01/2025, on the subject cited above. In this connection, it is to inform you that the premise was inspected by the officer concerned of this department from fire safety point of view on dated 22/01/2025 in your presence. During course of inspection, following shortcomings are observed.

1. The hose-reel provided found non-functional.
2. Terrace pump was not on auto mode.

In view of above, application for renewal of fire safety certificate cannot be considered. You are requested to rectify the shortcomings under intimation to this department for further action in the matter.

Yours faithfully,

(ATUL GARG)

Director

T. No. 011-23414000

Copy to: -

1. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054.