



75 ^{c/40}
Azadi Ka
Amrit Mahotsav

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F.6/DFS/MS/School/2025/SZ/ 403

Dated: 15 / 05 / 2025

To

The Head of School,
Sarvodaya Co-Ed. Sr. Sec. School,
Kitchner Road, (Malcha Marg),
New Delhi-110021

Sub: Renewal of Fire Safety Certificate in r/o Sarvodaya Co-Ed. Sr. Sec. School at Kitchner Road, (Malcha Marg) New Delhi-110021 (School ID: 2026002)

Sir,

This is with reference to your letter No. SV/KR/2025-26/10556 dated 22/04/2025 received through outdoor diary No. 895 dated 23/04/2025. In this connection, it is to inform you that the premise was inspected by the officer concerned of this department from fire safety point of view on 05/05/2025 in your presence. During course of inspection, the shortcomings observed are as below.

1. The hose-reel hose provided found non-functional (Nozzle missing).
2. Terrace level fire provided but non-functional.
3. Overhead captive water tank found empty.
4. Exit Signage found removed at some places.

In view of above, application for renewal of fire safety certificate cannot be considered at this stage. You are requested to rectify the shortcomings under intimation to this department for further action in the matter.

Yours faithfully,

(ATUL GARG)
DIRECTOR

Ph. 011-23414333

Copy to: -

1. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054.