



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F.6/DFS/MS/School/2025/SZ/ 54

Dated: 22/01/2025

FIRE SAFETY CERTIFICATE

Certified that the **Sarvodaya Co-Ed. Vidyalaya** located at Masjid Moth, South Extn-II, New Delhi-110049 (New Building SPS Shed School ID: 1925246), comprised of Ground + One upper floor, owned/occupied by Sarvodaya Co-Ed. Vidyalaya, was issued Fire Safety Certificate by this department vide letter No. F.6/DFS/MS/2022/SZ/School/13 dated 05/01/2022. The premise was re-inspected by the officer concerned of this department on dated 10/01/2025 in the presence of Dr. Shakti Raj (Principal) and observed that said premises have deemed complied with the fire prevention and fire safety requirements in accordance with Director of Education Circular dated 01/03/2011 and that the premise/building is fit for occupancy class "**Educational**" (Group B) with effect from 22/01/2025 for a period of **three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 22/01/2025 at New Delhi by

(ATUL GARG)
DIRECTOR

T. No. 011-23414000

Copy to: -

1. The Principal, Sarvodaya Co-Ed. Vidyalaya (School ID: 1925246), Masjid Moth, South Extn-II, New Delhi-110049
2. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054

Conditions for the validity of Fire Safety Certificate:

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided therein shall be maintained in good working conditions at all time as seen during inspection.
3. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
4. All the staff members must know the correct method of operation of fire-fighting system.
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or alteration (Clause 1.4.3 of UBBL-2016), if any.
6. The owner/occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, prior to its expiry.

N-12

INSPECTION REPORT				
1.	Name & address of the building	Sarvodaya Co-Ed. Vidyalaya, New Building SPS Shed, Masjid Moth, South Extension-II, New Delhi-110049 (School ID: 1925246)		
2.	Type of Occupancy	Educational (Group-B)		
3.	Building Comprised of	Ground + One upper floor (SPS Shed).		
4.	Type of Case	Renewal		
5.	Details of previous NOC No.	F.6/DFS/MS/2022/SZ/School/13 dated 05/01/2022		
6.	Fire Safety directives Letter No.	DOE Cir. 3298-3398 dated 01/03/2021		
7.	Date of inspection	10/01/2025		
8.	Name of the Inspecting Officer	ADO (SJ)		
9.	Name and designation of Officer from the building side	Dr. Shakti Raj (Principal)		
10.	Year of Construction	2020		
11.	Applicant's letter No.	SC-ED/V/MM/1273 dated 03.01.2025 Outdoor diary No. 11008 dated 06/01/2025		
S. No.	Minimum standards on fire prevention and fire safety U/R 33	Old NOC Requirement	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	06 mtr	06 mtr	MR
	• Gate width	4.5 mtr	4.5 mtr	MR
	• Width of internal road	-NA-	-NA-	-NA-
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	02 Nos	04 Nos	MR
	• Basements	-NA-	-NA-	-NA-
	b. Width of staircases			
	• Upper floors	1.50 mtr	1.80m x 4	MR
	• Basements	-NA-	-NA-	-NA-
	c. Protection of exits			
	• Fire check door	-NA-	-NA-	-NA-
	• Pressurization	-NA-	-NA-	-NA-
	d. No of continuous staircase to terrace	One	Four	MR
	e. Width of Corridor	1.5m	Provided	MR
	f. Door Size	1.0m	1.10m x 2	MR
3.	Compartmentation			
	• Fire check door	-NA-	-NA-	-NA-
	• Sealing of electrical shafts	-NA-	-NA-	-NA-
	• Fire Rating of shaft door	-NA-	-NA-	-NA-
	• Water Curtain	-NA-	-NA-	-NA-
	• Fire Dampers	-NA-	-NA-	-NA-
4.	Smoke Managements System			
	• Basements	-NA-	-NA-	-NA-
	• Upper floors	-NA-	-NA-	-NA-
5.	Fire Extinguishers			
	• Total numbers	10 Nos	20 Nos	MR
	• Types	ABC/CO ₂	ABC & CO ₂	MR
	• ISI marking	ISI Marked	Provided	MR
6.	First-Aid Hose Reels			
	• Total numbers on each floor	-NA-	04 Nos	-NA-
	• Length of hose reel hose	-NA-	30m	-NA-
	• Nozzle diameter	-NA-	5mm	-NA-

✓

7.	Automatic fire detection and alarming system			
	• Type of detector	-NA-	-NA-	-NA-
	• Location of Main Panel	-NA-	-NA-	-NA-
	• Location of Repeater Panel	-NA-	-NA-	-NA-
	• Alternate source of power	-NA-	-NA-	-NA-
	• Hooters' Location	-NA-	-NA-	-NA-
8.	MOEFA	-NA-	-NA-	-NA-
9.	Public Address System	-NA-	-NA-	-NA-
10.	Automatic Sprinkler System			
	• Basements	-NA-	-NA-	-NA-
	• Upper Floor	-NA-	-NA-	-NA-
	• Sprinkler above false ceiling	-NA-	-NA-	-NA-
11.	Internal Hydrants			
	• Size of riser/down- comer	-NA-	-NA-	-NA-
	• Number of hydrants per floor	-NA-	-NA-	-NA-
	• Hose Box	-NA-	-NA-	-NA-
12.	Yard Hydrants			
	• Total number of hydrants	-NA-	-NA-	-NA-
	• Hose Box	-NA-	-NA-	-NA-
13.	Pumping Arrangements			
	• Ground Level			
	➤ Discharge of main pump	-NA-	-NA-	-NA-
	➤ Head of main pump	-NA-	-NA-	-NA-
	➤ Number of main pumps	-NA-	-NA-	-NA-
	➤ Jockey pump out put	-NA-	-NA-	-NA-
	➤ Jockey pump head	-NA-	-NA-	-NA-
	➤ Standby Pump out put	-NA-	-NA-	-NA-
	➤ Standby Pump Head	-NA-	-NA-	-NA-
	➤ Auto Staring/Manual stopping	-NA-	-NA-	-NA-
	➤ Pump House Access	-NA-	-NA-	-NA-
	• Terrace level			
	➤ Discharge of pump	-NA-	450 LPM x 2	-NA-
	➤ Head of the pump	-NA-	40m	-NA-
	➤ Power supply	-NA-	Provided	-NA-
	➤ Auto starting of pump	-NA-	Provided	-NA-
14.	Captive water storage for firefighting			
	• Underground tank capacity ,	-NA-	-NA-	-NA-
	➤ Draw of connection	-NA-	-NA-	-NA-
	➤ Fire service inlet	-NA-	-NA-	-NA-
	➤ Access to tank	-NA-	-NA-	-NA-
	• Overhead Tank capacity	-NA-	10,000 Ltr	-NA-
15.	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	-NA-	-NA-	-NA-
	➤ Pressurization of lift lobby	-NA-	-NA-	-NA-
	➤ Communication in lift Car	-NA-	-NA-	-NA-
	➤ Fireman's Grounding Switch	-NA-	-NA-	-NA-
	➤ Lift Signage	-NA-	-NA-	-NA-
17.	Standby Power Supply	-NA-	-NA-	-NA-
18.	Refuge Area			
	➤ Total area	-NA-	-NA-	-NA-
	➤ Location	-NA-	-NA-	-NA-

N-14

19.	Fire Control Room			
	➤ Detector system panel	-NA-	-NA-	-NA-
	➤ Flow Switch Panel	-NA-	-NA-	-NA-
	➤ PA System Panel	-NA-	-NA-	-NA-
	➤ Battery backup	-NA-	-NA-	-NA-
	➤ Building Floor Plans	-NA-	-NA-	-NA-
20.	Special Fire Protection Systems for Protection of Special Risks, if any;	-NA-	-NA-	-NA-

The fire protection systems provided in the building were test checked at random and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standards on fire prevention and fire safety required under the rules, the fire safety certificate issued vide letter No. F.6/DFS/MS/2022/SZ/School/13 dated 05/01/2022, renewal under rule 37 of the Delhi Fire Service Rules, 2010 is recommended.

Accordingly, DFA is put up for perusal/approval and signature please.

Santosh Kumar
15.01.25
Signature of the Inspecting Officer
Name: Santosh Kumar
Designation: ADO (SJ)

DO (SD) *Santosh Kumar 15/1/25*

15/01/2025
Director
12/1/25
ADP/SJ

Sir, F.T letter is put up for your sign. pl

Director
12/1/25
ADP/SJ

Santosh Kumar
21/01/25