



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001



No. F6/DFS/MS/2025/School/ 137

Dated: 11/02/2025

FIRE SAFETY CERTIFICATE

Certified that the Sarvodaya Co-Ed Vidyalaya (I.D No-1208014) located at Pratap Nagar, Delhi-110084 comprised of 03 Blocks, one old block comprised of Ground + 03 upper floors & 02 New blocks comprised of Ground + first floor & 01 Hall at ground floor only owned/ occupied by Sarvodaya Co-Ed Vidyalaya was issued Fire Safety Certificated vide this office letter no. F.6/DFS/MS/2022/School/WZ/193 dated 18.02.2022. The premise was re-inspected by the officer concerned of this department on 28.01.2025 in the presence of Sh. Mangal Singh chauhan (Vice-Principal) and observed that all the fire prevention and fire safety arrangements as provided in the premise found in good working condition. The premise have therefore deemed complied with the requirements under rule 33 of the Delhi Fire Service Rules, 2010 and the building premise is fit for occupancy under "Group B Educational (School)" with effect from11/02/2025 for a period of three years, in accordance with the rule 36 unless renewed under rule 37 or sooner cancelled under rule 40, subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010,

Issued on11/02/2025 at New Delhi

(Atul Garg)
Director

Ph: 011-23414000

Copy to: -

1. The Director, Education, Government of N.C.T of Delhi. Old Sectt. Delhi - 110054.
2. The Principal, Sarvodaya Co-Ed Vidyalaya (I.D No-1208014) located at Pratap Nagar, Delhi-110084.

Conditions for the validity of Fire Safety Certificate:

1. All the means of escape shall be kept free from any type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipment and method of smooth and speedy safe evacuation of occupants in case of emergency
3. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seem during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities. This Fire Safety Certificate is valid only for permanent building structure as per plan.
5. This fire safety certificate may not be treated in any case of regularizations of unauthorized construction/unauthorized use of land or activities, if any.
6. The owner / occupier shall submit a declaration every year in Form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on the official website of Delhi Fire Service i.e. www.dfs.delhigovt.nic.in.
7. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, **six months** prior to its expiry".

INSPECTION REPORT

1. Name & address of the building : Sarvodaya Co-ed Vidhyalaya at Pratap Nagar, Delhi -110007.
2. Composition of building : 03 blocks (01 block, G+03 upper floors, 02 blocks- G+first floor & 01 Hall at GF)
3. Type of Occupancy : Educational
4. Type of Case : Renewal.
5. Details of previous NOC : F.6/DFS/MS/2022/School/WZ/193 dated 18.02.2022
6. Fire Safety directives letter No : Director of Education Circular dated 01.03.2011/ NBC Part-4
7. Date of inspection : 28.01.2025
8. Name of the Inspecting Officers : ADO (RN)
9. Name and designation of officers from the building side : Sh. Mangal Singh Chauhan (Vice-Principal)
10. Year of Construction : 1989/2016
11. Applicant's letter No. : Letter No- Nil & DFS Dairy No-11419 dated 14.01.2025

	Minimum Standards on fire prevention and fire safety U/R 33	D.O.E dated 01.03.2011/NBC Part-IV Requirements	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	06	12m	MR
	• Gate width	4.5m	5.1m	MR
	• Width of internal road	NA	06m	NA
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	04	07	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper Floors	1.50m	Gr+03 block -1.41m each G to 3 rd floor, 05m Gr to 1 st floor & G+01 block- 02 nos. of 1.50m & 02 nos. of 01m	MR (being old case)
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	02	02	MR
	e. Width of Corridor	Required	2.17m	MR
	f. Door Size	01m for classroom & 1 Hall-03exits	1.15 m double door & Hall-1.50m each	MR (being old case)
3	Compartmentation.			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	Smoke Management System.			
	• Basements	NA	NA	NA
	• Upper floors	Required	Natural Ventilation	MR
5	Fire Extinguishers			

	<ul style="list-style-type: none"> Total numbers Types ISI marking 	18nos.	33nos	MR
		ABC/Co2	ABC-30/Co2-03	MR
		ISI Marked	Yes	MR
6	First-Aid Hose Reels.			
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	02	02	MR
		30m	30m	MR
		5mm	5mm	MR
7	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
8	MOEFA	NA	NA	NA
9	Public Address System.	NA	NA	NA
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> Basement Upper Floor Sprinkler above false ceiling 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
11	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
12	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	NA	NA	NA
		NA	NA	NA
13	Pumping Arrangements.			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/ Manual stopping Pump House Access 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
	<ul style="list-style-type: none"> Terrace level <ul style="list-style-type: none"> Discharge of pump Head of the pump Power Supply Auto Starting of pump 	450 LPM	450 LPM	MR
		40m	40m	MR
		Required	Provided	MR
		Required	Provided	MR
14	Captive Water Storage for fire fighting.			
	<ul style="list-style-type: none"> Underground tank capacity Draw-off connection Fire service inlet 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA

	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	10,000 LTR	Provided	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication In lift Car	N/A	N/A	N/A
	• Fireman's Grounding Switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Batter backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested/ checked randomly and found in working condition at the time of inspection. The management has complied all the shortcomings issued and communicated by this department vide letter of even no. F6/DFS/MS/2025/School/13 dated 03.01.2025.

Keeping in view the satisfactory compliance of the minimum standards on fire prevention and fire safety required as stipulated in Director of education dated 01.03.2011/NBC Part-4, the FSC issued vide letter of even no. F.6/DFS/MS/2022/School/WZ/193 dated 18.02.2022 renewal under rule 37 of the Delhi Fire Service Rules, 2010.

Signature of the Inspecting Officer
Name :- C.L. Meena
Designation :- ADO/RN

D.B. Mukharjee (DO/NW)

By cfo (w2) - MIR

cfo / *[Signature]*
6/21/2025

Director *[Signature]*

[Signature]