



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

c/28



No. F6/DFS/MS/2025/School/ 13

Dated: 03/01/2025

To

The Principal,
Sarvodaya Co-ed Vidyalaya
Pratap Nagar, Delhi-110084.

Sub: - Regarding renewal of fire safety certificate in r/o Sarvodaya Co-ed Vidyalaya (I.D No.1208014 & 1208232) located at Pratap Nagar, Delhi-110084

Sir,

Please refer to your letter no. nil received in this department vide outdoor dairy no-10162 dated: 10.12.2024 on the subject cited above. In this connection this is to inform you that the above mentioned site was re-inspected by the officer concerned of this department on 18.12.2024 to check the existing fire safety measures. During inspection it has been observed that the school premise is comprised of 03 block, one block comprised of ground + 03 upper floors, 02 block comprised of ground + first floor each & one hall at ground floor. At the time of inspection Sh. Rajinder Kumar (Incharge) was also present at site. During the course of inspection the observations/ shortcomings made are as under:-

1. Hose reel hose is provided but not functional.
2. Terrace level fire pump is provided but not functional.
3. Terrace level fire water tank is provided but empty.
4. Exit & floor signage's found removed at strategic locations in the building.

Keeping in view of above, renewal of Fire Safety Certificate cannot be considered at this stage & rejected. You are requested to rectify the above mentioned shortcomings under intimation to this department; till such time running of school is at your own risk & responsibility.

Yours faithfully

(Atul Garg)
Director

Ph:-011-23414000

Copy to:-

1. The Director, Education, Government of N.C.T of Delhi. Old Sectt. Delhi - 110054.

01/01/2025