

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F.6/DFS/MS/2025/School/WZ/ 182

Dated: 21/02/2025

FIRE SAFETY CERTIFICATE

Certified that the Sarvodaya Kanya Vidyalaya, Prashant Vihar, D-Block, Delhi-85 (School ID-1413067), comprised of Ground + 03 upper floor & Auditorium hall has already been issued FSC by this department vide letter No. F.6/DFS/MS/2022/School/WZ/216 dated 25.02.2022. The premises was re-inspected by the officer concerned of this department on 11.02.2025 in the presence of Smt. Parul Bharti (In-Charge) and found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the premises fit for occupancy class Educational "Group-B" with effect from 21/02/2025 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subjected to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 21/02/2025 at New Delhi by

(Atul Garg)
DIRECTOR
 Ph: 011-23414000

Copy to :-

1. The Principal, Sarvodaya Kanya Vidyalaya, Prashant Vihar, D-Block, Delhi-85.(School ID-1413067)

2. The Director of Education, GNCT of Delhi Old Secretariat, Delhi-110054.

Conditions for the validity of fire safety certificate:

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection.
3. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
4. All the staff members must know the correct method of operation of firefighting system.
5. The owner/ occupier shall submit a declaration every year in Form 'K'[sub rule (2) of Rule 38] provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on http://delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Forms
6. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction (Clause 2.9.2 of UBBL-2016) or Alteration (Clause 1.4.3 of UBBL-2016), if any.
7. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of Rule 37] along with a copy of this Certificate, six months prior to its expiry."

N/12

INSPECTION REPORT

1. Name & address of the building : Sarvodaya Kanya Vidyalaya, Prashant Vihar, D-Block, Delhi-85
 2. Type of Occupancy : Educational
 3. Type of Case : Renewal (Ground + 03 upper floor & Auditorium)
 4. Details of Previous NOC : F.6/DFS/MS/2022/School/WZ/216 dated 25.02.2022.
 5. Fire Safety directives letter No : NBC Part-IV
 6. Date of inspection : 11.02.2025
 7. Name of Inspecting Officer : A.K.Sharma ADO(Rohini)
 8. Name and designation of officers
 From the building side : Smt. Paural Bharti (In-charge)
 9. Year of Construction : 2004
 10. Applicant's letter No. : Online e-mail dated 20.01.2025.

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1.	Access to building			
	• Road width	Accessible	Accessible	MR
	• Gate width	Accessible	4.5m	MR
	• Width of internal road	-NA-	-NA-	-NA-
2.	Number, Width, Type & Arrangement of Exits			
	d. Number of staircases			
	• Upper Floors	04nos.	04nos.	MR
	• Basements	NA	NA	NA
	e. Width of staircases			
	• Upper Floor	1.5m	Provided	MR
	• Basements	Audi-1.5m	Provided	MR
	f. Protection of exits	-NA-	-NA-	-NA-
	Fire check door	-NA-	-NA-	-NA-
	• Pressurization	-NA-	-NA-	-NA-
	d. No. of continuous staircases to terrace	01nos.	01nos.	MR
	e. Width of Corridor	-NA-	-NA-	-NA-
	f. Door Size	Class room doors-1.0m	1.0m (2 exits)	MR
		Audi -2.0m	Audi- 2m x 2	MR
3.	Compartmentation			
	• Fire check door	-NA-	-NA-	-NA-
	• Sealing of electrical shafts	-NA-	-NA-	-NA-
	• Fire Rating of shaft door	-NA-	-NA-	-NA-
	• Water Curtain	-NA-	-NA-	-NA-
	• Fire Dampers	-NA-	-NA-	-NA-
4.	Smoke Management System			
	• Basements	-NA-	-NA-	-NA-
	• Upper floors	12 a/c per hour	Natural ventilated	MR
5.	Fire Extinguishers			
	• Total numbers	23nos.	Provided	MR
	• Types	ABC/CO2	ABC/CO2	MR
	• IS marking	ISI marked	Yes	MR
6.	First-Aid Hose Reels			
	• Total numbers on each floor	01nos.	Provided	MR
	• Length of hose reel hose	30mm	Provided	MR
	• Nozzle diameter	5m	Provided	MR
7.	Automatic fire detection and alarming system			
	• Type of detectors	-NA-	-NA-	-NA-
	• Location of Main Panel	-NA-	-NA-	-NA-
	• Location of Repeater Panel	-NA-	-NA-	-NA-

My


	• Alternate source of power	-NA-	-NA-	-NA-
	• Hooters' Location	-NA-	-NA-	-NA-
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	• Basement	-NA-	-NA-	-NA-
	• Ground & Upper Floors	-NA-	-NA-	-NA-
	• Sprinkler above false ceiling	-NA-	-NA-	-NA-
11.	Internal Hydrants			
	• Size of riser/down-comer	04no.	Provided	MR
	• Number of hydrants per floor	03nos.	Provided	MR
	• Hose Box	03nos.	Provided	MR
12.	Yard Hydrants			
	• Total number of hydrants	-NA-	-NA-	-NA-
	• Hose Box	-NA-	-NA-	-NA-
13.	Pumping Arrangements			
	• Ground Level	-NA-	-NA-	-NA-
	➤ Discharge of main Pump	-NA-	-NA-	-NA-
	➤ Head of Main pump	-NA-	-NA-	-NA-
	➤ Number of main pumps	-NA-	-NA-	-NA-
	➤ Jockey Pump out put	-NA-	-NA-	-NA-
	➤ Jockey pump head	-NA-	-NA-	-NA-
	➤ Standby Pump out put	-NA-	-NA-	-NA-
	➤ Standby Pump Head	-NA-	-NA-	-NA-
	➤ Auto Starting/Manual Stopping	-NA-	-NA-	-NA-
	➤ Pump House Access	-NA-	-NA-	-NA-
	• Terrace level			
	➤ Discharge of pump	450lpm x 2	Provided	MR
	➤ Head of the pump	40m	Provided	MR
	➤ Power Supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR
14.	Captive Water Storage for fire fighting			
	• Underground tank capacity	25,000ltr	25,000ltr	MR
	➤ Draw-off connection	Required	Provided	MR
	➤ Fire service inlet	Required	Provided	MR
	➤ Access to tank	Required	Provided	MR
	• Overhead Tank capacity	10,000ltr	10,000ltr	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	• Pressurization of Lift Shaft	-NA-	-NA-	-NA-
	• Pressurization of Lift lobby	-NA-	-NA-	-NA-
	• Communication In lift Car	-NA-	-NA-	-NA-
	• Fireman's Grounding Switch	-NA-	-NA-	-NA-
	• Lift Signage	-NA-	-NA-	-NA-
17.	Standby power supply	-NA-	-NA-	-NA-
18.	Refuge Area.			
	➤ Total Area	-NA-	-NA-	-NA-
	➤ Location	-NA-	-NA-	-NA-
19.	Fire Control Room			
	• Detector System Panel	-NA-	-NA-	-NA-
	• Flow Switch Panel	-NA-	-NA-	-NA-
	• PA System Panel	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-

N/20


	• Battery backup	-NA-	-NA-	-NA-
	• Building Floor Plans			
20.	Special Fire Protection System for Protection of special Risks, if any:	-NA-	-NA-	-NA-


Accordingly, the fire protection systems provided in the building were tested/ checked randomly and found in working condition at the time of inspection.


In view of the deemed compliance of the minimum standards of the fire prevention and fire safety measures as required under the rules the NOC issued vide letter no. F.6/DFS/MS/2022/School/WZ/216 dated 25.02.2022 is recommended for renewal under rule 37 of the Delhi Fire Service rules 2010.



 Signature of the Inspecting Officer
 Name Ajay Kumar Sharma
 Designation ADO(Rohini)


DO (N/W)


 14/02/2025


 02/02/2025


 04/2/2025


 17/2/2025


 18/2/25



FT letter is put up for kind perusal and signature please.


 Director


 28/2/25

985 NW
 17/2/2025