

c48

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE

NEW DELHI- 110001

No. F6/DFS/MS/School/2025/SZ/ 696

Dated: 22/05/2025

FIRE SAFETY CERTIFICATE

Certified that the **Sarvodaya Kanya Vidyalaya**, B-Block, Janakpuri, New Delhi-110058, having two blocks, namely Old Block comprised of ground plus two upper floors & New Block comprised of ground plus three upper floors, owned/occupied by Sarvodaya Kanya Vidyalaya was issued FSC by this department vide letter No. F.6/DFS/MS/School/2021/SZ/1073 dated 24.12.2021 (for new block G+3) & letter No. .6/DFS/MS/School/SZ/2021/105 dated 08.02.2021 (for old block G+2). The school building was re-inspected by the officer concerned of this department on dated 14.05.2025 in the presence of Sh. Ved Parkash (Estate Manager), and found that the School have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the building/premises is fit for occupancy class "**Educational Building**" w.e.f. 22/05/2025 for a period of **three years** in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule-38 of the Delhi Fire Service Rules, 2010 printed as below.

Issued on 22/05/2025 at New Delhi by.


(Atul Garg)
Director
Delhi Fire Service

Copy to: -

1. Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054.
2. The Principal, Sarvodaya Kanya Vidyalaya, at B-Block, Janakpuri, New Delhi-110058

Conditions for the validity of fire safety certificate: -

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. The means of escape shall be kept unlocked and unobstructed for unhindered evacuation of occupants in case of emergency.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
4. The trained staff should be available round the clock.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in the Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

INSPECTION REPORT

1. Name & address of the building : Sarvodaya Kanya Vidyalaya, B-Block, Janakpuri, New Delhi-58.
2. Building is comprised of : Old Block (G+2) & New Block (G+3)
3. Type of Occupancy : Educational
4. Type of Case : Renewal
5. Details of Previous FSC letter : F.6/DFS/MS/School/2021/SZ/1073 dated 24.12.2021 (for new block G+3)
F.6/DFS/MS/School/SZ/2021/105 dated 08.02.2021 (for old block G+2)
6. Fire Safety direction letter No : Nil
7. Date of Inspection : 14.05.2025
8. Name of the Inspecting officers : ADO R.K. Yadav
9. Name and designation of Officer:
From the building side : Sh. Ved Parkash (Estate Manager)
10. Year of Construction : 2004-05 (Old Block) & 2019-20 (New Block)
11. Applicant's letter No : Online email Id thv3012qoot@gmail.com dated 11.02.2025

S. No.	Minimum Standards on fire prevention and fire safety U/R33	Requirement	Provided at Site	Remarks MR/NMR
1	Access to building			MR
	• Road width	06 m.	Provided	MR
	• Gate width	4.5 m	Directly accessible from road	MR
	• Width of internal road	N/A	N/A	N/A
2	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases	02 Nos.	03 Nos. (old blk) & 02 nos. (New blk)	MR
	• Upper Floor	N/A	N/A	N/A
	• Basement			
	B. Width of Staircases	1.50 m each	1.80 M each (new blk) & 1.42, 1.26 m (GF to SF) & 1.26 GF to FF in old blk	MR, old case in old blk
	• Upper Floor	N/A	N/A	N/A
	• Basement			
	c. Protection of exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	d. No. of continuous staircases to terrace	02 No.	02 No. at each blk	MR
	e. Width of Corridor	1.5 m.	1.7 m. (new blk) & 2.55 m (old blk)	MR
	f. Door Size	1.20 m	1.35 m (new blk) & 1.0 m (double door in old blk)	MR
3	Compartmentation.			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire rating of shaft door	N/A	N/A	N/A
	• Water curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4	Smoke Management System.			
	• Basement	N/A	N/A	N/A
	• Upper floor	Required	Natural Ventilation	MR
5.	Fire Extinguishers			
	• Total numbers	50 nos.	Provided	MR
	• Types	ABC /CO ₂	ABC /CO ₂	MR
	• IS marking	ISI marked	ISI marked	MR

N/34

6	First-aid-Hose Reels.			
	Total numbers of each floor	02 Nos.	Provided	
	• Length of hose reel hose	30 mtr.	Provided	
	• Nozzle diameter	05mm	Provided	
7	Automatic fire detection and alarming system.			
	• Type of detectors	N/A	N/A	N
	• Location of main panel	N/A	N/A	N
	• Location of repeater panel	N/A	N/A	N
	• Alternate source of power	N/A	N/A	N
	• Hooter's location	N/A	N/A	N
8	MOEFA	N/A	N/A	N/
9	Public address System.	N/A	N/A	N/
10	Automatic Sprinkler System.			
	• Basement	N/A	N/A	N/
	• upper floor	N/A	N/A	N/
	• sprinkler above false ceiling	N/A	N/A	N/
11	Internal Hydrants			
	• size of riser/down-comer	N/A	N/A	N/A
	• Number of hydrants per floor	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
12	Yard Hydrants.			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13	Pumping Arrangements.			
	• Ground Level			
	➤ Discharge of main Pump	N/A	N/A	N/A
	➤ Head of Main Pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby pump out put	N/A	N/A	N/A
	➤ Standby pump Head	N/A	N/A	N/A
	➤ Auto Starting /Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace Level			
	➤ Discharge of pump	450 LPM	450 X2 LPM (new blk) & 450 lpm (old blk)	MR
	➤ Head of the Pump	40 M	Provided	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR
14	Captive Water Storage for Fire Fighting.			
	• Underground tank capacity	N/A	N/A	N/A
	➤ Draw-off connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	N/A	N/A
	➤ Access to tank	N/A	N/A	N/A
	• Overhead Tank capacity	10,000 Ltr.	10,000 ltrs. in each blk	MR
15	Exit Signage.	Required	Provided	MR

N/35

16	Provision of Lifts.			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication in lift car	N/A	N/A	N/A
	• Firemen's grounding switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.			
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector system panel	N/A	N/A	N/A
	• Flow switch panel	N/A	N/A	N/A
	• PA system panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested, checked and found not functional at the time of inspection. The shortcomings was issued by this department vide letter No. F.6/DFS/MS/School/2024/SZ/813 dated 10.12.2024 have been rectified.

Note: - Earlier FSC issued by this department vide letter No. F.6/DFS/MS/School/2021/SZ/1073 dated 24.12.2021 for new block comprised of ground plus three upper floors & F.6/DFS/MS/School/SZ/2021/105 dated 08.02.2021 for old block G+2 for old block comprised of ground plus two upper floors.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the Fire Safety Certificate issued vide letter No. F.6/DFS/MS/School/2021/SZ/1073 dated 24.12.2021 (for new block G+3) & letter No. F.6/DFS/MS/School/SZ/2021/105 dated 08.02.2021 (for old block G+2) renewal under rule 37 of the Delhi Fire Service Rules 2010 is recommended.

R.K. Yadav
19/5/2025
Signature of Inspecting Officer
Name: - R.K. Yadav
Designation: - ADO (JKP)

~~DO (South West)~~

R.K.
19/5/25
CFO
16/5/2025
Director
17/5/25

R.K.