



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001**



No. F6/DFS/MS/2025/School/ 114

Dated: 04/02/2025

**FIRE SAFETY CERTIFICATE**

Certified that the Sarvodaya Kanya Vidyalaya (I.D No-1309025) located at Dhakka, Delhi-110009 comprised of 02 blocks, 01 block comprised of ground + 01 upper floors & 01 comprised of ground + 03 upper floors only owned/ occupied by Sarvodaya Kanya Vidyalaya was issued Fire Safety Certificated vide this office letter no. F6/DFS/MS/2021/School/1061 dated 23.12.2021 the premise was re-inspected by the officer concerned of this department on 24.01.2025 in the presence of Smt. Anita Verma (Principal) and observed that all the fire prevention and fire safety arrangements as provided in the premise found in good working condition. The premise have therefore deemed complied with the requirements under rule 33 of the Delhi Fire Service Rules, 2010 and the building premise is fit for occupancy under "Group B Educational (School)" with effect from 04/02/2025 for a period of three years, in accordance with the rule 36 unless renewed under rule 37 or sooner cancelled under rule 40, subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010,

Issued on 04/02/2025 at New Delhi by

*(Signature)*  
 (Atul Garg)  
 Director  
 Ph:-011-23414000  
*(Signature)*

Copy to :-

1. The Director, Education, Government of N.C.T of Delhi. Old Sectt. Delhi - 110054.
2. The Principal, Sarvodaya Kanya Vidyalaya (I.D No-1309025) located at Dhakka, Delhi-09

Conditions for the validity of Fire Safety Certificate:

1. All the means of escape shall be kept free from any type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipment and method of smooth and speedy safe evacuation of occupants in case of emergency
3. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seem during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities. This Fire Safety Certificate is valid only for permanent building structure as per plan.
5. This fire safety certificate may not be treated in any case of regularizations of unauthorized construction/unauthorized use of land or activities, if any.
6. The owner / occupier shall submit a declaration **every year** in **Form "K"** provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on the official website of Delhi Fire Service i.e. [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
7. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in **Form 'J'** [sub rule (1) of rule 37] along with a copy of this Certificate, **six months** prior to its expiry".

**INSPECTION REPORT**

1. Name & address of the building : Sarvodaya Kanya Vidyalaya, Dhakka, Delhi-110009. (I.D No. 1309025)
2. Type of Occupancy : Educational
3. Type of Case : Renewal
4. Composition of building : 02 blocks, Ground + first floor & Ground+03 upper floors
5. Details of previous NOC : F6/DFS/MS/2021/School/1061 dated 23.12.2021
6. Fire Safety directives letter No : NBC Part-4/ D.O.E dated 01.03.2021
7. Date of inspection : 24.01.2025
8. Name of the Inspecting Officers : ADO (RN)
9. Name and designation of officers  
from the building side : Smt. Anita Verma (Principal)
10. Year of Construction : 2004
11. Applicant's letter No. : Online E-mail I.D dated: 03.01.202524

	Minimum Standards on fire prevention and fire safety U/R 33	NBC Part-IV/ D.O.E dated 01.03.2011 Requirement	Provided at site	Remarks MR/NMR
1	<b>Access to building</b>			
	• Road width	06m	09m	MR
	• Gate width	4.5m	4.5m	MR
	• Width of internal road	NA	NA	NA
2	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases	04	04	MR
	• Upper Floors	NA	NA	NA
	• Basements			
	b. Width of staircases	1.50m each	G+1 floor= 1.50m & 1.60m & G+03 floor= 02m & 1.50m	MR
	• Upper Floors	NA	NA	NA
	• Basements			
	c. Protection of exits	NA	NA	NA
	• Fire check door	NA	NA	NA
	• Pressurization			
	d. No. of continuous staircases to terrace	01	01	MR (being old case)
	e. Width of Corridor	1.50m	Provided	MR
	f. Door Size	1m	1m double door	MR (being old case)
3	<b>Compartmentation.</b>			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	<b>Smoke Management System.</b>			
	• Basements	NA	NA	NA
	• Upper floors	Required	Natural Ventilation	MR
5	<b>Fire Extinguishers</b>			
	• Total numbers	16nos	28nos	MR
	• Types	ABC/Co2	ABC/Co2	MR
	• ISI marking	ISI Marked	Provided	MR



6	First-Aid Hose Reels.			
	<ul style="list-style-type: none"><li>• Total numbers on each floor</li><li>• Length of hose reel hose</li><li>• Nozzle diameter</li></ul>	01	01	MR
		30m	30m	MR
		5mm	5mm	MR
7	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"><li>• Type of detectors</li><li>• Location of Main Panel</li><li>• Location of Repeater Panel</li><li>• Alternate source of power</li><li>• Hooters' Location</li></ul>	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
8	MOEFA	NA	NA	NA
9	Public Address System.			
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"><li>• Basement</li><li>• Upper Floor</li><li>• Sprinkler above false ceiling</li></ul>	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
11	Internal Hydrants.			
	<ul style="list-style-type: none"><li>• Size of riser/down-comer</li><li>• Number of hydrants per floor</li><li>• Hose Box</li></ul>	01	01	MR
		30m	30m	MR
		5mm	5mm	MR
12	Yard Hydrants.			
	<ul style="list-style-type: none"><li>• Total number of hydrants</li><li>• Hose Box</li></ul>	NA	NA	NA
		NA	NA	NA
13	Pumping Arrangements.			
	<ul style="list-style-type: none"><li>• Ground Level<ul style="list-style-type: none"><li>➤ Discharge of main Pump</li><li>➤ Head of Main pump</li><li>➤ Number of main pumps</li><li>➤ Jockey Pump out put</li><li>➤ Jockey pump head</li><li>➤ Standby Pump out put</li><li>➤ Standby Pump Head</li><li>➤ Auto Starting/ Manual stopping</li><li>➤ Pump House Access</li></ul></li></ul>	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		NA	NA	NA
		NA	NA	NA
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
	<ul style="list-style-type: none"><li>• Terrace level<ul style="list-style-type: none"><li>➤ Discharge of pump</li><li>➤ Head of the pump</li><li>➤ Power Supply</li><li>➤ Auto Starting of pump</li></ul></li></ul>	450 LPM	450 LPM	MR
		40m	40m	MR
		Required	Provided	MR
		Required	Provided	MR
14	Captive Water Storage for fire fighting.			
	<ul style="list-style-type: none"><li>• Underground tank capacity<ul style="list-style-type: none"><li>➤ Draw-off connection</li><li>➤ Fire service inlet</li><li>➤ Access to tank</li></ul></li></ul>	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
	Overhead Tank capacity	10,000 LTR	10,000 LTR	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			

4/46

	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication In lift Car	N/A	N/A	N/A
	• Fireman's Grounding Switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Batter backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested/ checked randomly and found in working condition at the time of inspection. The management has complied all the shortcomings issued and communicated by this department vide letter of even no. F6/DFS/MS/2024/School/836 dated 19.12.2024.

Keeping in view the satisfactory compliance of the minimum standards on fire prevention and fire safety required as stipulated in NBC Part 4/Director of educational dated 01.03.2011, the FSC issued vide letter of even no. F6/DFS/MS/2021/School/1061 dated 23.12.2021, renewal under rule 37 of the Delhi Fire Service Rules, 2010.

Signature of the Inspecting Officer  
 Name :- C.L. Meena  
 Designation:- ADO/RN

D.B. Mukharjee (DO/NW)

24/01/2025  
 Dy CFA (W2)

28/1/2025

29/01/2025  
 Director

ADO/RN

CONF - - - P.T.O -