

FORM 'H': FORM FOR ISSUING FIRE SAFETY CERTIFICATE  
[See sub-rule (1) of rule 35]  
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No.F.6/DFS/MS/School/2025/ 846

Dated: 02/07/2025

**FIRE SAFETY CERTIFICATE**

Certified that the Sarvodaya Kanya Vidyalaya located at Mandoli, Delhi-110094 comprised of ground plus two upper floor & ground plus one upper floor (old building block) owned / occupied by Sarvodaya Kanya Vidyalaya was issued FSC vide letter No. F6/DFS/MS/School/2022/NDZ/548 dated 20/05/2022. The school building was re-inspected by the officer concerned of this department on 26/06/2025 in presence of Mrs. Shikha Jain (Principal) and observed that all the Fire Prevention and Fire Safety arrangements provided in the premises found in good working condition. The premises have therefore deemed complied with rule 33 of Delhi Fire Service Rules, 2010 and that the building / premises is fit for occupancy class "Educational" (Group-B) with effect from 02/07/2025 for a period of three years in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the DFS rules, 2010.

**Issued on** 02/07/2025 **at New Delhi by.**

(ATUL GARG)  
DIRECTOR  
DELHI FIRE SERVICE.

Copy to :-

1. Principal, Sarvodaya Kanya Vidyalaya, Mandoli, Delhi – 110093.
2. The Dy. Director of Education, B-Block, Yamuna Vihar, Delhi-110053.

**Conditions for the validity of Fire Safety Certificate:**

1. All the fire safety arrangement provided their in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non-functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc. shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. "The owner / Occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [WWW.dfs.Delhigovt.nic.in](http://WWW.dfs.Delhigovt.nic.in)

# INSPECTION REPORT

MR

1. Name & address of the building: Sarvodaya Kanya Vidyalaya, Mandoli, Delhi-110093.
2. Type of Occupancy : Educational, Group-B (School)
3. Building Comprised of : M Block-(G+2) & 2 block (G+1)
4. Type of Case : Renewal
5. Details of previous NOC No. F6/DFS/MS/School/2022/NDZ/548 dated 20/05/2022
6. Fire Safety directives Letter No. : NBC (Part-IV)
7. Date of inspection : 26/06/2025
8. Name of the Inspecting Officer : A.K. Jaiswal (D.O.)
9. Name and designation of Officer from the building side : Mrs. Shikha Jain (Principal)
10. Year of Construction : 1984-2013
11. Applicant's letter No. : email dated 24/06/2025

| S No | Minimum standards on fire prevention and fire safety U/R 33 | NBC (Part-IV) Requirement | Provided at site | Remarks MR/NMR |
|------|---|---------------------------|------------------|----------------|
| 1.   | Access of building  |                           |                  |                |
|      | • Road width  | 06 m                      | 06 m             | MR             |
|      | • Gate width  | NA                        | NA               | NA             |
|      | • Width of internal road                                    | NA                        | NA               | NA             |
| 2.   | Number, width, Type & Arrangements of exits                 |                           |                  |                |
|      | a. Number of staircases                                     |                           |                  |                |
|      | • Upper floor block-M                                       | 2                         | 2                | MR             |
|      | • Upper floor block-A                                       | 4                         | 5                | MR             |
|      | • Upper floor block-S                                       | 1                         | 1                | MR             |
|      | • Basements   | NA                        | NA               | NA             |
|      | Width of staircases   |                           |                  |                |
|      | • Upper floors  | 1.50m                     | 1.50m each       | MR             |
|      | • Basements   | NA                        | NA               | NA             |
|      | Protection of exits   |                           |                  |                |
|      | • Fire check door   | NA                        | NA               | NA             |
|      | • Pressurization  | NA                        | NA               | NA             |
|      | b. No of continuous staircase to terrace                    | 1                         | 1                | MR             |
|      | c. Width Of Corridor  | 1.50 m                    | 1.50 m           | MR             |
|      | d. Door Size  | 01 m                      | 01 m             | MR             |
| 3.   | Compartmentation  |                           |                  |                |
|      | • Fire check door   | NA                        | NA               | NA             |
|      | • Sealing of electrical shafts                              | NA                        | NA               | NA             |
|      | • Fire Rating of shaft door                                 | NA                        | NA               | NA             |
|      | • Water Curtain   | NA                        | NA               | NA             |
|      | • Fire Dampers  | NA                        | NA               | NA             |
| 4.   | Smoke managements System                                    |                           |                  |                |
|      | • Basements   | NA                        | NA               | NA             |
|      | • Upper floors  | NA                        | NA               | NA             |
| 5.   | Fire Extinguishers  |                           |                  |                |
|      | • Total numbers   | 30 Nos                    | 36 Nos           | MR             |
|      | • Types   | ABC /Co2                  | Provided         | MR             |
|      | • ISI marking   | ISI Marked                | Provided         | MR             |



|     |  |            |            |    |
|-----|--|------------|------------|----|
| 6.  | First – Aid Hose Reels                       |            |            |    |
|     | • Total numbers on each floor                | 2          | 2          | MR |
|     | • Length of hose reel hose                   | 30mtr      | 30mtr      | MR |
|     | • Nozzle diameter                            | 5mm        | 5mm        | MR |
| 7.  | Automatic fire detection and alarming system |            |            |    |
|     | • Type of detector                           | NA         | NA         | NA |
|     | • Location of Main Panel                     | NA         | NA         | NA |
|     | • Location of Repeater Panel                 | NA         | NA         | NA |
|     | • Alternate source of power                  | NA         | NA         | NA |
|     | • Hooters' Location                          | NA         | NA         | NA |
| 8.  | MOEFA  | NA         | NA         | NA |
| 9.  | Public Address System                        | NA         | NA         | NA |
| 10. | Automatic Sprinkler System                   |            |            |    |
|     | • Basements                                  | NA         | NA         | NA |
|     | • Upper Floor                                | NA         | NA         | NA |
|     | • Sprinkler above false ceiling              | NA         | NA         | NA |
| 11. | Internal Hydrants                            |            |            |    |
|     | • Size of riser/down- comer                  | NA         | NA         | NA |
|     | • Number of hydrants per floor               | NA         | NA         | NA |
|     | • Hose Box                                   | NA         | NA         | NA |
| 12. | Yard Hydrants                                |            |            |    |
|     | • Total number of hydrants                   | NA         | NA         | NA |
|     | • Hose Box                                   | NA         | NA         | NA |
| 13. | Pumping Arrangements                         |            |            |    |
|     | • Ground Level                               |            |            |    |
|     | • Discharge of main pump                     | NA         | NA         | NA |
|     | ➤ Head of main pump                          | NA         | NA         | NA |
|     | ➤ Number of main pumps                       | NA         | NA         | NA |
|     | ➤ Jockey pump out put                        | NA         | NA         | NA |
|     | ➤ Jockey pump head                           | NA         | NA         | NA |
|     | ➤ Standby Pump out put                       | NA         | NA         | NA |
|     | ➤ Standby Pump Head                          | NA         | NA         | NA |
|     | ➤ Auto Staring/Manual stopping               | NA         | NA         | NA |
|     | ➤ Pump House Access                          | NA         | NA         | NA |
|     | • Terrace level                              |            |            |    |
|     | ➤ Discharge of pump                          | 450 LPM    | 450 LPM    | MR |
|     | ➤ Head of the pump                           | 40 M       | 40 M       | MR |
|     | ➤ Power supply                               | Required   | Provided   | MR |
|     | ➤ Auto starting of pump                      | Required   | Provided   | MR |
| 14. | Captive water Storage for fire fighting      |            |            |    |
|     | • Under ground tank capacity                 | NA         | NA         | NA |
|     | ➤ Draw of connection                         | NA         | NA         | NA |
|     | ➤ Fire service inlet                         | NA         | NA         | NA |
|     | ➤ Access to tank                             | NA         | NA         | NA |
|     | • Overhead Tank capacity                     | 10,000 ltr | 10,000 ltr | MR |

|     |  |                    |          |    |
|-----|--|--------------------|----------|----|
| 15  | Exit Signage   | Required <i>NA</i> | Provided | MR |
| 16. | Provision of Lifts   |                    |          |    |
|     | ➤ Pressurization of Lift Shaft   | NA                 | NA       | NA |
|     | ➤ Pressurization of lift lobby   | NA                 | NA       | NA |
|     | ➤ Communication in lift Car  | NA                 | NA       | NA |
|     | ➤ Fireman's Grounding Switch   | NA                 | NA       | NA |
|     | ➤ Lift Signage   | NA                 | NA       | NA |
| 17. | Standby power supply   | NA                 | NA       | NA |
| 18. | Refuge Area  |                    |          |    |
|     | ➤ Total area   | NA                 | NA       | NA |
|     | ➤ Location   | NA                 | NA       | NA |
| 19. | Fire control room  |                    |          |    |
|     | ➤ Detector system panel  | NA                 | NA       | NA |
|     | ➤ Flow Switch Panel  | NA                 | NA       | NA |
|     | ➤ PA System Panel  | NA                 | NA       | NA |
|     | ➤ Battery backup   | NA                 | NA       | NA |
|     | ➤ Building Floor Plans   | NA                 | NA       | NA |
| 20. | Special Fire Protection Systems for Protection of special Risks, if any; | NA                 | NA       | NA |

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the NOC issued vide letter No F6/DFS/MS/School/2022/NDZ/548 dated 20/05/2022 renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.

*Ashok Kumar Jaiswal*  
26/6/2025  
Signature of the Inspecting Officer  
Name : Ashok Kumar Jaiswal  
Designation: D.O. (East)

Dy. C.F.O. (NDZ)

*C.F.O.*  
*11/07/25*  
*27/06/25*  
*Director*  
*11/07/25*  
*m*