



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

7/5-19
आज़ादी का
अमृत महोत्सव

No. F6 /DFS/MS/School/SZ/2025/ 774
/2025

Dated: 16/10/2025

To,

The Principal,
Sarvodaya Kanya Vidyalaya No. 2,
Madanpur Khadar, New Delhi,
School ID no. 1925449.

Sub: - Regarding renewal of Fire Safety Certificate in r/o Sarvodaya Kanya Vidyalaya No. 2 located at
Madanpur Khadar, New Delhi, School ID no. 1925449.

Sir,

With reference to the letter bearing outdoor Diary no. 4038 dated 23.07.2025, on the subject cited above, it is informed that the school building was inspected by Assistant Divisional Officer (M. Road) from this department on 23.09.2025 in the presence of Mrs. Seema Wadhwa (In-charge) and following shortcomings were observed:-

1. Hose reels found non function at each block.
2. Fire pump found non functional at each block.

In view of above shortcomings, the application for renewal of Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the school management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,


(A.K. Malik)
Dy. Chief Fire Officer
o/c Delhi Fire Service

Copy to: -

1. The Directorate of Education, Govt. of NCT of Delhi, Old Secretariat, Delhi.