



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

C-58



No. F6/DFS/MS/WZ/2025/School/ 776

Dated: 16/10/2025

To,

The Principal,
Sarvodaya Kanya Vidyalaya,
Old block, J. J. Colony Wazirpur,
Delhi-110052.

Sub: Issue of FSC in r/o Sarvodaya Kanya Vidyalaya, Old block, J. J. Colony Wazirpur, Delhi-110052. (School ID-1411034).

Sir,

Kindly refer to your letter no.nil dated 15.09.2025, received in this department on the subject cited above. The premise was inspected by the concern nominated authority of this department on 06.10.2025 in presence of Mrs. Kalpna Basumatri (Principal) to ascertain the availability and operability of the fire prevention and fire safety measures. Your request for renewal of FSC is rejected under sub rule (3) of Rule 37 of DFS Rules-2010 due to following reason:

1. Hose reel hose provided but not functional.
2. Terrace Fire pump with capacity of 450 LPM provided but not functional.

In this regard as stipulated in sub Rule 37 of DFS Rules, 2010 you may apply with a fresh application for renewal of fire safety certificate under sub-rule (2) on Form "J" with compliance of above shortcomings. The web links for DFS Act-2007/ Rules 2010 & Form "J" are as under:

http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Forms

Yours faithfully

(S. K. Dua)

Dy. Chief Fire Officer (WZ)
Delhi Fire Service