



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F6/DFS/MS/2025/WZ/ 1335

Dated: 20/11/2025

FIRE SAFETY CERTIFICATE

Certified that the Sarvodaya Kanya Vidyalaya, Old block, J. J. Colony, Wazirpur, Delhi-110052. Colony (School ID-1411034), comprised of 02 Blocks (Blk-1= Ground + 03 Floors & Blk-2= Ground Floor Only) has already been issued FSC by this department vide letter No. F6/DFS/MS/School/WZ/2022/1040 dated 20/09/2022. The premises was re-inspected by the officer concerned of this department on 07.11.2025 in the presence of Mrs. Kalpna Basumatari (Principal) and found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the premises fit for occupancy class "Educational" Group-B with effect from 20/11/2025 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subjected to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 20/11/2025 at New Delhi by

[Signature]
18/11/25

Dr. S. K. Tomar
 Dy. Chief Fire Officer
 Delhi Fire Service

Copy to: -

1. The Director, Education, Government of N.C.T of Delhi. Old Sect. Delhi - 54.
2. The Principal, Sarvodaya Kanya Vidyalaya, Old block, J. J. Colony, Wazirpur, Delhi-110052. Colony (School ID-1411034).

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on
8. All the means of escape shall be kept free of any obstruction all the time to evacuate the occupant, in a safe manner, in the event of emergency.

http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/ http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Forms

INSPECTION REPORT

1. Name & address of the building	Sarvodaya Kanya Vidyalaya, Old block, J. J. Colony, Wazirpur, Delhi-110052. Colony (School ID-1411034).			
2. Type of Occupancy	Educational			
3. Type of Case	Renewal, 02 Blocks (Blk-1= Ground + 03 Floors & Blk-2= Ground Floor Only)			
4. Details of Previous NOC	F6/DFS/MS/School/WZ/2022/1040 Dated-20/09/2022.			
5. Fire Safety directives letter No	DOE Circular No.3298-3398 Dated-01/03/2011			
6. Date of inspection	07.11.2025.			
7. Name of Inspecting Officer	Sh. Ajay Kumar Sharma ADO (Wazirpur)			
8. Name and designation of officers From the building side	Mrs. Kalpna Basumatari (Principal)			
9. Year of Construction	1989			
10. Applicant's letter No.	OD No.7475 dated 28.10.2025 & Online e-mail dated 24.10.2025.			
S. No	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1.	Access to building			
	• Road width	06 mtr	Provided	MR
	• Gate width	4.5 mtr	Provided	MR
	• Width of internal road	NA	NA	NA
2.	Number, Width, Type & Arrangement of Exits			
	d. Number of staircases			
	• Upper Floors	02	GF-TF-02, GF-FF-01, TF-Terrace-01	MR being old case
	• Basements	NA	NA	NA
	e. Width of staircases			
	• Upper Floor	2 x 1.5 m	GF-TF-1.39, 1.38 mts, GF-FF-1.63-5.16 mts, TF-Terrace-0.80 mt	MR being old case
	• Basements	NA	NA	NA
	f. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	01nos.	Provided from TF to Terrace	MR being old case
	e. Width of Corridor	1.5 mtr	2.30m	MR
	f. Door Size	1.0 mtr	Provided (including door frame)	MR being old case
3.	Compartmentation			
	f) Fire check door	NA	NA	NA
	g) Sealing of electrical shafts	NA	NA	NA
	h) Fire Rating of shaft door	NA	NA	NA
	i) Water Curtain	NA	NA	NA
	j) Fire Dampers	NA	NA	NA
4.	Smoke Management System			
	c) Basements	NA	NA	NA
	d) Upper floors	NA	NA	NA
5.	Fire Extinguishers			
	d) Total numbers	26 nos.	Provided	MR
	e) Types	ABC/CO2	ABC/CO2 Provided	MR
	f) ISI marking	ISI marked	Provided	MR
6.	First-Aid Hose Reels			
	d) Total numbers on each floor	02nos.	Provided	MR

	e) Length of hose reel hose	30mm	Provided	MR
	f) Nozzle diameter	5mm	Provided	MR
7.	Automatic fire detection and alarming system			NA
	f) Type of detectors	NA	NA	NA
	g) Location of Main Panel	NA	NA	NA
	h) Location of Repeater Panel	NA	NA	NA
	i) Alternate source of power	NA	NA	NA
	j) Hooters' Location	NA	NA	NA
8.	MOEFA	Required	Provided	MR
9.	Public Address System			
10.	Automatic Sprinkler System			NA
	d) Basement	NA	NA	NA
	e) Ground & Upper Floors	NA	NA	NA
	f) Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants			NA
	d) Size of riser/down-comer	NA	Provided	NA
	e) Number of hydrants per floor	NA	Provided	NA
	f) Hose Box	NA	Provided	NA
12.	Yard Hydrants			NA
	c) Total number of hydrants	NA	NA	NA
	d) Hose Box	NA	NA	NA
13.	Pumping Arrangements			NA
	• Ground Level	NA	NA	NA
	➤ Discharge of main Pump	NA	NA	NA
	➤ Head of Main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey Pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Starting/Manual Stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	Terrace level			MR
	➤ Discharge of pump	450 LPM	450 LPM	MR
	➤ Head of the pump	40 Mtr	40 Mtr	MR
	➤ Power Supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR
14.	Captive Water Storage for fire fighting			NA
	• Underground tank capacity	NA	NA	NA
	➤ Draw-off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	10,000 Ltrs.	Provided	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			NA
	f) Pressurization of Lift Shaft	NA	NA	NA
	g) Pressurization of Lift lobby	NA	NA	NA
	h) Communication In lift Car	NA	NA	NA
	i) Fireman's Grounding Switch	NA	NA	NA
	j) Lift Signage	NA	NA	NA
17.	Standby power supply	NA	NA	NA

18.	Refuge Area.			
	c) Total Area	NA	NA	NA
	d) Location	NA	NA	NA
19.	Fire Control Room			
	f) Detector System Panel	NA	NA	NA
	g) Flow Switch Panel	NA	NA	NA
	h) PA System Panel	NA	NA	NA
	i) Battery backup	NA	NA	NA
	j) Building Floor Plans	NA	NA	NA
20.	Special Fire Protection System for Protection of special Risks, if any:	NA	NA	NA

Accordingly, the fire protection systems provided in the building were tested/ checked randomly and found in working condition at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required as stipulated in NBC Part-IV/DOE Cir., and removal of shortcomings issued vide letter no. 776 dated 16.10.2025, the FSC issued vide letter no. F6/DFS/MS/School/WZ/2022/1040 dated-20/09/2022, renewal of FSC under rule 37 of the Delhi Fire Service Rules, 2010 is recommended.

Signature of the Inspecting Officer
Name Ajay Kumar Sharma
Designation ADO(Wazirpur)

DO (NW)

Dy. CPO (WZ)

Principal Director

Dy. CPO (WZ)

18/11/25

ADO (WZ)

FT letter to put up for kind perusal and signature please.

Dy. CPO (WZ)

18/11/25

MS