

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001

No.F6/DFS/MS/2025/ School/ 630

Dated: 08/05/2025

FIRE SAFETY CERTIFICATE

Certified that the **Sarvodya Kanya Vidyalaya (C0 ed)**, **Padam Nagar New Delhi-110007**(ID 1208018) comprised of Ground + 02 upper floors (old block) was earlier granted FSC by this department vide letter No. F6/DFS/MS/School/2013/WZ/757 dated 19/08/2013. Now, the old block premises was re-inspected by the officer concerned of this department on 28/04/2025 in the presence of the Ms, Snehlata (Principal) and found that the said building block has deemed complied with the fire prevention and fire safety requirements in accordance with Delhi Fire Service Act 2007 and Rules, 2010 and the old block premises is fit for occupancy class **Group B "Educational Building"** Sub-Div. B-I with effect from ...08/05/2025... for a period of **three years** subject to compliance of the conditions mentioned below:

Issued on08/05/2025..... at New Delhi by.

(Atul Garg)
 DIRECTOR
 Delhi Fire Service

Copy to:-

1. The Commissioner, MCD Civic center New Delhi.
2. Director of Education, Govt. of NCT, Delhi.
3. The Principal, S (Co-Ed) V, Padam Nagar New Delhi-110007.

Conditions for the validity of fire safety certificate:

1. This FSC is valid only for old block (G+2 upper floors).
2. All the means of escape shall be kept free of all types of obstruction all the time.
3. All the fire safety arrangements provided there in shall be maintained in good working condition at all time.
4. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
5. The compliance with regards to electrical installation, structural stability, set back area, occupancy and any deviation in construction etc. shall be verified from authority concerned.
6. This fire safety certificate may not be treated in any case for regularization of Unauthorized construction, if any.
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six months prior to its expiry.
8. Any flammable material for interior decoration shall strictly prohibit.

INSPECTION REPORT

- Name & address of the building:- Sarvodya Kanya Vidyalaya (C0 ed), Padam Nagar New Delhi.
- Type of occupancy:- Educational Group B-I
- Type of case:- old block (G+02),
Renewal
- Details of previous NOC:- F6/DFS/MS/School/2013/WZ/757 dated 19/08/2013
- Fire safety directives No.- N/A
- Date of inspection:- 28/04/25.
- Name of the inspecting officer:- Sh. Ravinder Singh (ADO/CC)
- Name & designation of officer
From the building side:- Ms, Snehlata (Principal)
- Year of construction:- 1965 (G+2),
- Applicant's letter No:- letter no. s(Co-Ed)V/PN/2024-25/02 dated 17.04.2025

Old Case (renewal)

S.No.	Minimum Standards on fire Prevention and fire safety U/R 33	Requirement Exiting	Provided at site	Remarks MR/NMR
1.	Access to Building			
	1) Road width	06 mtr.	provided	MR
	2) Gate width	4.5 mts	Directly assessable	MR
	3) Width of internal road	NA	NA	NA
2.	Number, Width Type & Arrangement of Exits			
	A. Number of staircases			
	1. Upper floors	02	02	MR
	2. Basements	N/A	N/A	N/A
	B. Width of staircase			
	1. Upper floors	1.50 mtr	1.50 mtr & 2.0 mtr	MR
	2. Basements	N/A	N/A	N/A
	C. Protection of exits			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	D. No. of continuous staircase to terrace	02	02	MR
	E. Width of corridor	1.5 mtr.	provided	MR
	F. Door size	1.0 mtr.	11.0	MR
3.	Compartmentation			
	1) Fire check door	N/A	N/A	N/A
	2) Sealing of electrical shafts	N/A	N/A	N/A
	3) Fire rating of shaft door	N/A	N/A	N/A
	4) Water curtain	N/A	N/A	N/A
	5) Fire Dampers	N/A	N/A	N/A
4.	Smoke Management System			
	1) Basements	N/A	N/A	N/A
	2) Upper floors	12 ACPH	Natural	MR
5.	Fire Extinguishers			
	1) Total numbers	22 Nos.	Provided	MR
	2) Types	ABC & CO2	Provided	MR
	3) ISI marking	Required	Provided	MR
6.	First-Aid Hose Reel			
	1) Total number of each floor	02	Provided	MR

	2) Length of hose reel hose	30 mtr.	Provided	
	3) Nozzle diameter	05 mm	Provided	MR
7.	Automatic Fire Detection & Alarming System			
	1) Type of detectors	N/A	N/A	N/A
	2) Location of main panel	N/A	N/A	N/A
	3) Location of repeater panel	N/A	N/A	N/A
	4) Alternate source of power	N/A	N/A	N/A
	5) Hooter's Location	N/A	N/A	N/A
8.	MOEFA	N/A	N/A	N/A
9.	Public Address System	Required	N/A	N/A
10.	Automatic Sprinkler System			
	1) Basement	N/A	N/A	N/A
	2) Upper floors	N/A	N/A	N/A
	3) Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	1) Size of riser/down-comer	N/A	provided	N/A
	2) Number of hydrants per floor	N/A	02	N/A
	3) Hose box	N/A	provided	N/A
12.	Yard Hydrants			
	1) Total number of hydrants	N/A	N/A	N/A
	2) Hose box	N/A	N/A	N/A
13.	Pumping Arrangement			
	1) Ground level	N/A	N/A	N/A
	a) Discharge of main pump	N/A	N/A	N/A
	b) Head of main pump	N/A	N/A	N/A
	c) Number of main pump	N/A	N/A	N/A
	d) Jockey pump out put	N/A	N/A	N/A
	e) Jockey pump head	N/A	N/A	N/A
	f) Stand by pump output	N/A	N/A	N/A
	g) Stand by pump head	N/A	N/A	N/A
	h) Auto starting/Manual stopping	N/A	N/A	N/A
	2) Terrace level			
	a) Discharge of pump	450 LPM	Provided	MR
	b) Head of pump	40 mtr.	40 mtr.	MR
	c) Power supply	Required	Provided	MR
	d) Auto starting of pump	Required	Provided	MR
14.	Captive Water Storage for Fire Fighting			
	1) Underground tank capacity	N/A	N/A	N/A
	a) Draw-off connection	N/A	N/A	N/A
	b) Fire service inlet	N/A	N/A	N/A
	c) Access to tank	N/A	N/A	N/A
	d) Over head tank capacity	10,000 ltr.	10,000 ltr.	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			

4/2

	a) Pressurization of lift	N/A	N/A	N/A
	b) Pressurization of lift lobby	N/A	N/A	N/A
	c) Communication in lift car	N/A	N/A	N/A
	d) Fireman's switch	N/A	N/A	N/A
	e) Lift signage	N/A	N/A	N/A
17.	Stand by Power Supply	N/A	N/A	N/A
18.	Refuge Area	N/A	N/A	N/A
	Total area location	N/A	N/A	N/A
19.	Fire Control Room	N/A	N/A	N/A
	a) Detector system panel	N/A	N/A	N/A
	b) Flow switch panel	N/A	N/A	N/A
	c) PA system panel	N/A	N/A	N/A
	d) Battery backup	N/A	N/A	N/A
	e) Building floor plan	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risk, if any:			N/A

The fire protection systems provided in the old building block were randomly tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules, if agreed, we may renew the FSC issued vide letter no. F6/DFS/MS/School/2013/WZ/757 dated 19/08/2013, under rule 35(6) of the Delhi Fire Service Rules 2010. Accordingly, DFA is put up for kind perusal and signature please.

Signature of the Inspecting Officer

[Handwritten Signature]
30/11/25

Name :- Ravinder Singh
Designation :- ADO (CC)

[Handwritten Signature]
1/5/25

[Handwritten Signature]
1/5/25

[Handwritten Signature]
C.F.O. (NDZ)

[Handwritten Signature]
02/05/25

[Handwritten Signature]
C.F.O.

[Handwritten Signature]
5/5/2025

[Handwritten Signature]
Director

[Handwritten Signature]